

/INITIATION OF SUBCOOLED POOL BOILING
DURING PRESSURE TRANSIENTS/

by

DONALD L. SCHMIDT

B.S., Kansas State University, 1983

A MASTER'S THESIS

submitted in partial fulfillment of the
requirements for the degree

MASTER OF SCIENCE

Department of Nuclear Engineering

KANSAS STATE UNIVERSITY

Manhattan, Kansas

1985

Approved by:

Richard E. Faw

Major Professor

LD
2668
TU
1985
S 337
C 2

TABLE OF CONTENTS

A11202 985100

	Page
1. INTRODUCTION	1
2. REVIEW OF PREVIOUS WORK	3
2.1 Convection Heat Transfer	3
2.2 Boiling Initiation	4
2.2.1 Steady-State Boiling Initiation	4
2.2.2 Transient Boiling Initiation	13
2.3 Nucleate Boiling	21
3. THEORY	23
3.1 Determination of Largest Potentially Active Cavity	23
3.2 Activation of a Nucleation Site	26
3.2.1 Decrease in Fluid Pressure	26
3.2.2 Increase in Vapor Pressure	27
3.3 Cavity Geometry	29
3.4 Effect of Contact Angles	30
4. APPARATUS AND EXPERIMENTAL PROCEDURE	35
4.1 Pressure System	35
4.1.1 Pressure Vessel	35
4.1.2 Pressure Measurement System	35
4.1.3 Pressurizer	42
4.2 Heating Element	44
4.3 Electrical System	46
4.4 Data Measurement System	46
4.5 Test Element Installation	49
4.6 Procedures	50
4.6.1 Preliminary Procedures	50
4.6.2 Experimental Procedures	51
5. RESULTS	53
5.1 Boiling Initiation	53
5.2 Pressure Runs	54
5.3 Temperature Runs	67
6. DISCUSSION OF RESULTS	83
6.1 Pressure Measurement	83
6.2 Estimation of Boiling Initiation Times	83
6.3 Effects of Pressure-Temperature History on Boiling Initiation	84
6.4 Approach to Steady-State Boiling	87
6.5 Conclusions	89
7. SUGGESTIONS FOR FURTHER STUDY	90
8. REFERENCES	92

	<u>Page</u>
APPENDIX A: Program BOIL: Temperature Data Analysis.	95
APPENDIX B: Program PRESSURE: Pressure Data Analysis	106
APPENDIX C: System Performance	113
APPENDIX D: Selected Listings of Experimental Pressure Data.	122
APPENDIX E: Selected Listings of Experimental Temperature Data	129

LIST OF FIGURES

	<u>Page</u>
2.1 Illustration of bubble growth from an active nucleation site.	7
2.2 Determination of boiling initiation superheat requirements based on Eqs. (2.13) and (2.16)	12
3.1 Illustration of vapor entrapment at a potential nucleation site.	24
3.2 Effect of surface temperature on incipient boiling pressure	32
3.3 Effect of selected changes in contact angle on incipient boiling pressure	34
4.1 Schematic diagram of the pressure vessel	36
4.2 Pressure vessel window housing	37
4.3 Pressure transducer cooling adaptor mounting to pressure vessel.	39
4.4 Pressure transducer cooling adaptor.	40
4.5 Pressure transducer adaptor for mounting the Model 603A to the cooling adaptor	41
4.6 Pressurization system.	43
4.7 Heating element construction	45
4.8 Control system and power amplifier schematic diagrams. .	47
5.1 Experimental pressure results for decompression from 0.377 to 0.101 MPa	57
5.2 Experimental pressure results for decompression from 0.515 to 0.101 MPa	58
5.3 Experimental pressure results for decompression from 0.446 to 0.101 MPa	59
5.4 Experimental pressure results for decompression from 0.584 to 0.101 MPa	60
5.5 Comparison of experimental pressure results for decompression from 0.377 to 0.101 MPa before and after partial draining of the pressurizer.	61

	<u>Page</u>
5.6 Experimental pressure results for decompression from 0.377 to 0.101 MPa: maximum system pressure 0.377 MPa.	62
5.7 Experimental pressure results for decompression from 0.377 to 0.101 MPa: maximum system pressure \geq 0.377 MPa.	63
5.8 Experimental pressure results for decompressions to 0.101 MPa: representative runs before removal of a quantity of water from the pressurizer	64
5.9 Experimental pressure results for decompressions from 0.377 to 0.101 MPa: representative runs after removal of a quantity of water from the pressurizer.	65
5.10 Experimental temperature results for decompression from 0.377 to 0.101 MPa: pressure reduction period \sim 4 s	69
5.11 Experimental temperature results for decompression from 0.515 to 0.101 MPa: pressure reduction period \sim 4 s	70
5.12 Experimental temperature results for decompression from 0.446 to 0.101 MPa: pressure reduction period \sim 4 s	71
5.13 Experimental temperature results for decompression from 0.584 to 0.101 MPa: pressure reduction period \sim 4 s	72
5.14 Experimental temperature results for decompression from 0.377 to 0.101 MPa: $p_{a,max} = 0.377 \text{ MPa}$, pressure reduction period \sim 6.6 s.	74
5.15 Experimental temperature results for decompression from 0.377 to 0.101 MPa: $p_{a,max} = 1.48 \text{ MPa}$, pressure reduction period \sim 6.6 s	75
5.16 Experimental temperature results for decompression from 0.377 to 0.101 MPa with $p_{a,max} = 1.48 \text{ MPa}$: (a) first 20 s of event; (b) long-term behavior.	77
5.17 Experimental temperature results for decompression from 0.377 to 0.101 MPa with $p_{a,max} = 0.791 \text{ MPa}$: (a) first 20 s of event; (b) long-term recovery to steady-state.	79

	<u>Page</u>
C1 Control system performance	114
C2 Effect of pressure transducer amplifier time constant	115
C3 Effect of ambient temperature on the pressure signal	116
C4 Representative measurements of the pressure transducer amplifier drift	118
C5 Drift corrected pressure signals	119
C6 Translation of data from units of voltage to units of pressure	120
C7 Effect of ambient temperature on a 0.377 to 0.101 MPa pressure drop.	121

LIST OF TABLES

	<u>Page</u>
2.1 Comparison of convective heat transfer correlations.	5
2.2 Minimum boiling superheat as a function of maximum cavity radius.	11
2.3 Maximum active site radius as a function of temperature and pressure	14
2.4 Boiling initiation system pressure values prescribed by the Fabic model.	19
5.1 Results of measurements made to determine the behavior of the pressure transients.	55
5.2 Approximate reduction periods for representative pressure runs.	66
5.3 Experimental conditions for measurements to determine the effects of pressure-temperature history on boiling initiation	68
5.4 Results of measurements made to determine the effects of pressure-temperature history on boiling initiation.	82
6.1 Summary of results of measurements made to determine the effects of pressure-temperature history on boiling initiation	85

ACKNOWLEDGEMENTS

The author is greatly indebted to Professor R. E. Faw for his guidance and suggestions throughout the study and the preparation of this thesis. The author also expresses his great appreciation to Mr. W. E. Starr for his assistance in the maintenance and repair of electrical apparatus, and to Mr. R. J. VanVleet for his effort in development of procedures for data collection and analysis. A special thanks is given to Mrs. Connie Schmidt for typing this thesis.

This work was funded in part by National Science Foundation Grant MEA 81-02193.

1. INTRODUCTION

Vapor bubble nucleation and growth phenomena have attracted the attention of researchers for many years. Nearly all of the attention has been placed on saturated nucleate boiling and the transition to film boiling. Studies of boiling under transient conditions have been devoted primarily to investigations of the transition to film boiling. The nature of boiling phenomena preceding the transition has received little attention. However, these phenomena are important aspects of the broader problem of understanding the sequence of events leading to boiling crises in high-pressure heat exchangers such as nuclear power reactors.

Transient initiation of boiling has been described by steady-state nucleation models, which use the size of active nucleation sites to determine superheats necessary for bubble nucleation from these sites. The required superheats for a simple transient situation can be achieved by an increase in the heater surface temperature or by a decrease in the fluid saturation temperature by means of a reduction in the fluid pressure.

Surface characteristics are important in the description of the sizes of cavities available as nucleation sites. The pressure and temperature conditions experienced prior to the initiation of boiling were also postulated to be of major importance by Fabic (1), since potential sites could be flooded by pre-pressurization. Studies performed to examine transient boiling caused by decompression (2-5) have employed conditions such that bulk liquid flashing occurs by the end of the decompression. Consequently, the behavior when boiling

initiation conditions are not met for the predicted cavity sizes and the reactivation of flooded surface cavities has not been thoroughly investigated.

In this work, the transition from convection to boiling during pressure transients was investigated for a horizontal, cylindrical platinum heating element submersed in a fluid. Maximum overpressures were applied to the system before subjecting the heating element to constant power delivery, maintained during transients by a custom made power supply driven by 12 volt wet cells. Separate runs were necessary to measure the system pressure as a function of time and the element temperature as a function of time. The element temperature was determined using resistance thermometry. The data were recorded using a digital oscilloscope, stored on a floppy disk, then transferred to a computer for analysis. The time at which the first bubble was seen or heard was recorded as the measured boiling initiation time. Initiation times were also estimated based on the point where the analyzed heater temperature began to decrease. Although these two methods did not always produce equivalent time values, ranges for true boiling initiation times were determined from these measurements.

Pressure transients displayed exponential reduction behavior over most of the pressure decrease, and they were reproducible in that region. Boiling initiation times provided conditions which tended to support the cavity deactivation by pre-pressurization hypothesis of Fabic, although the effects of initial pressures were not as pronounced as expected by the model. Boiling was observed even in cases where none was predicted, but subsequent nucleation site reactivation and recovery of the heater temperature to steady-state was impeded by increases in maximum pressure applied.

2. REVIEW OF PREVIOUS WORK

2.1 Convection Heat Transfer

In a system composed of a body immersed in a fluid, convection heat transfer will occur if the body and the bulk fluid temperature are at different temperatures. Quantifying the heat transfer analytically is not a simple matter because of the dependence not only on numerous fluid properties, but also on flow conditions and surface geometry.

Boundary-layer theory has been used to derive numerical solutions for horizontal cylinders. These solutions have been shown to be quite accurate for moderate Rayleigh numbers characterizing cases where the wake is confined to a small region at the rear of the cylinder. Churchill and Chu (6) examined a wide range of data on steady-state convective heat transfer from horizontal cylinders. They recommended the following correlation as being applicable to both constant cylinder surface temperature and constant heat flux for all Rayleigh and Prandtl numbers:

$$\text{Nu}^{\frac{1}{6}} = 0.60 + 0.387 f(\text{Pr}) \text{Ra}^{1/6} \quad (2.1)$$

where the Rayleigh and Nusselt numbers are based on cylinder diameter, and

$$f(\text{Pr}) = [1 + (0.559/\text{Pr})]^{9/16} - 8/27. \quad (2.2)$$

Morgan (7) also carried out a thorough analysis of published experimental data on steady-state convection from horizontal cylinders, and recommended the following correlation as being applicable for gases and liquids (except liquid metals):

$$\text{Nu} = B \text{ Ra}^m \quad (2.3)$$

where values of B and m are given in the following table:

Ra	B	m
$10^{-10} - 10^{-2}$	0.675	0.058
$10^{-2} - 10^{+2}$	1.02	0.148
$10^2 - 10^4$	0.850	0.188
$10^4 - 10^7$	0.480	0.250
$10^7 - 10^{12}$	0.125	0.333

Fujii, et al. (8) reported that for convection from horizontal cylinders, the following correlation shows good agreement with both calculated and measured heat transfer rates:

$$2/Nu = \ln [1 + 4.918g(\text{Pr})\text{Ra}^{-n}], \quad (2.4)$$

where

$$g(\text{Pr}) = [1 + (0.492/\text{Pr})^{9/16}]^{-4/9} \quad (2.5)$$

and

$$n = 0.25 + 1.0/(10 + 5\text{Ra}^{0.175}). \quad (2.6)$$

Table 2.1 shows a comparison of these three correlations for the Rayleigh number range of interest in this work.

2.2 Boiling Initiation

2.2.1 Steady-State Boiling Initiation

Many theoretical analyses and interpretations of experimental data on boiling initiation have been based on concepts introduced by Griffith and Wallis (9) and embellished by Hsu (10), Bergles and Rohsenow (11),

Table 2.1. Comparison of predictions of Churchill-Chu, Fujii, and Morgan correlations for natural convection heat transfer from a 0.25 mm diametric cylinder. Ambient conditions: $T_a = 20^\circ\text{C}$. Fluid properties are evaluated at the mean temperature between T_w and T_a .

$T_w - T_a$ ($^\circ\text{C}$)	Heat Flux (kW/m^2)		
	Churchill-Chu	Morgan	Fujii, et al.
10	26.2	29.4	31.1
20	60.3	68.0	72.5
30	100	113	121
40	145	163	176
50	195	218	237
60	249	278	304
70	308	341	376
80	371	409	453
90	438	483	535
100	509	564	622

Han and Griffith (12), Madejski (13), and Cole and co-workers (14, 15, 16). In its simplest form, the concept may be described as follows.

Consider present within a fluid a heating element within the surface of which is an active boiling initiation site with a circular aperture of radius r_c (Fig. 2.1). As the temperature of the heating element is increased beyond the saturation temperature of the fluid, a vapor bubble emerges from the aperture. The surface of the bubble is spherical shaped due to the effect of surface tension. The minimum radius of curvature of the bubble is r_c , the radius of the aperture. At this minimum radius, surface forces are maximum, and the excess of the vapor pressure within the bubble over the static fluid pressure must be maximum.

If the fluid surrounding the bubble is at temperature T_w , the excess pressure is given by

$$p_v(T_w) - p_v(T_s) = 2\sigma(T_w)/r_c, \quad (2.7)$$

in which T_s is the saturation temperature of the fluid at system pressure $p = p_v(T_s)$, $p_v(T_w)$ is the vapor pressure of the fluid at temperature T_w , and σ is the fluid-vapor surface tension evaluated at temperature T_w . The excess temperature of the fluid at the fluid-vapor interface of the bubble can be related to the excess pressure in the bubble through use of the Clausius-Clapeyron relation. Application of this relation leads to the approximation that

$$T_w = f_1(r_c) \equiv T_s + \frac{2\sigma T_s}{\lambda \rho_v r_c}, \quad (2.8)$$

where ρ_v is the vapor phase density, assumed to be much less than that of the liquid phase, and λ is the latent heat of vaporization. This is the




FIG. 2.1. Illustration of bubble growth from an active nucleation site.

threshold temperature which must be exceeded for the bubble to grow beyond radius r_c .

Now suppose that the fluid surrounding the heating element has a temperature distribution $T(r) = f_2(r)$, a function of distance r from the surface. Let T_w and T_a represent the surface temperature and the ambient temperature respectively. If q is the heat flux from the surface to the fluid, then approximately

$$f_2'(r) = dT/dr = -q/k, \quad (2.9)$$

and

$$f_2(r) = T(r) = T_w - qr/k, \quad (2.10)$$

where k is the thermal conductivity of the fluid.

Griffith and Wallis argued that for a bubble to grow in size beyond the radius r_c , the surface temperature of the heating element must exceed the threshold temperature, i.e., that $f_2(0) = f_1(r_c)$. Hsu contended that for the bubble to grow, it is necessary that the fluid temperature, not at the heating-element surface or base of the bubble, but at the cap of the bubble, exceed the threshold, i.e., that $f_2(r_c) = f_1(r_c)$. Han and Griffith argued that neither the temperature at the bubble base nor that at the bubble cap controlled the bubble growth. Rather, it was reasoned, the average liquid temperature surrounding the bubble was the controlling factor. This led to the criterion $f_2(ar_c) = f_1(r_c)$, where it was argued that $a = 3/2$. Sakurai and Shiotsu (17) accommodated in their arguments an empirical relationship between the cavity radius and the bubble radius at boiling inception, namely that the bubble radius is br_c . Allowing for this empiricism, the boiling initiation criterion may be stated as $f_2(ar_c) = f_1(br_c)$, or

$$T_w - T_s = \frac{qar_c}{k} + \frac{2\sigma T_s}{\lambda p_v b r_c}. \quad (2.11)$$

For the Griffith and Wallis approach, $a = 0$ and $b = 1$. For that of Hsu, $a = 1.6$ and $b = 1.25$. For that of Han and Griffith, $a = 1.5$ and $b = 1$. Sakurai and Shiotsu recommended that $a = 1.8$ and $b = 1.67$.

Suppose now that there are present on the heating element surface nucleation sites of a wide variety of radii. Cole (18), following the prescription of Bergles and Rohsenow (11), showed that, as the heat flux or surface temperature is increased, the first nucleation site to become active, i.e., from which the first bubble will emerge, is that one for which $r_c = r_*$ determined by $f_2'(ar_*) = f_1'(br_*)$. From Eqs. (2.8) and (2.9),

$$r_* = (2k\sigma T_s / \rho_v \lambda b^2 q)^{1/2}. \quad (2.12)$$

Substitution of this value into Eq. (2.11) leads to the following expression for the minimum surface superheat required for boiling from a surface with a full size range of nucleation sites:

$$(T_w - T_s)_{\min} = (8\sigma T_s q / k \lambda \rho_v)^{1/2}. \quad (2.13)$$

Bergles and Rohsenow offered the following correlation of computed values for water over the pressure range 15 to 2000 psia:

$$q = 1.55 \times 10^4 p^{1.156} [1.8(T_w - T_s)]^{2.047/p^{0.0234}} \quad (2.14)$$

where q is measured W/m^2 , T is K , and p is MPa . If, on the other hand, the largest nucleation site present has $r_c = r_m < r_*$, then the minimum surface superheat required for boiling initiation is the greater value

$$(T_w - T_s)_{\min} = \frac{q \sigma r_m}{k} + \frac{2cT_s}{\lambda \rho_v b r_m}. \quad (2.15)$$

Selected values of minimum boiling superheat for H_2O are given in Table 2.2. For each saturation temperature, the last four values of r_m listed are the r_* values for the heat fluxes listed. Thus, superheats above and to the left of the horizontal lines are for the cases $r_m < r_*$.

One may ask how the superheat at boiling inception is affected by the subcooling of the ambient liquid. Suppose that a full range of initiation sites is available, so that the boiling superheat is governed by Eq. (2.13). Suppose that natural convection is the heat transfer mechanism, so that

$$q = C(T_w - T_a)^n \quad (2.16)$$

where $n \approx 1.2$. By equating the heat fluxes in Eqs. (2.13) and (2.16), and noting that $T_w - T_a = T_w - T_s + \Delta T_{\text{sub}}$, one can show that $(T_w - T_s)_{\min}$ is given by solution of the equation

$$(T_w - T_s)_{\min} = C'[(T_w - T_s)_{\min} + \Delta T_{\text{sub}}]^{n/2} \quad (2.17)$$

where $C' = (8cT_s^2C/k\lambda\rho_v)^{1/2}$. Evaluation of $(T_w - T_s)_{\min}$ is illustrated in Fig. 2.2 where it may be seen that, as ΔT_{sub} increases, so also does the minimum boiling superheat. For example, for water at $T_s = 100^\circ\text{C}$, an increase in ΔT_{sub} from 10 to 30°C causes an increase of about 5°C in the minimum boiling superheat.

Madejski (13) developed a model for boiling initiation which allows for a non-spherical bubble shape and avoids specification of the distance from the heating surface at which the superheat criterion must be applied. As corrected by Schmidt and Cole (14), the result of the

Table 2.2. Minimum boiling superheat as a function of maximum cavity radius.

T_g (°C)	r_m (μm)	q (MW/m ²)	Minimum Boiling Superheat (K) for $a=b=1$			
			0.1	0.2	0.5	1.0
100	1		32.9	33.1	33.5	34.3
	2		16.7	17.0	17.9	19.3
	4.73		7.6	8.3	10.4	13.8
	6.69		5.9	6.9	9.8	13.8
	10.6		4.7	6.2	9.8	13.8
	15.0		4.4	6.2	9.8	13.8
150	0.5		15.4	15.5	15.7	16.1
	1		7.8	8.0	8.4	9.1
	2.31		3.7	4.0	5.0	6.6
	3.26		2.8	3.3	4.7	6.6
	5.16		2.2	3.0	4.7	6.6
	7.30		2.1	3.0	4.7	6.6
195	0.5		5.1	5.2	5.4	5.8
	1		2.7	2.8	3.3	4.0
	1.31		2.1	2.3	2.9	3.9
	1.86		1.6	1.9	2.7	3.9
	2.93		1.3	1.7	2.7	3.9
	4.15		1.2	1.7	2.7	3.9




FIG. 2.2. Determination of boiling initiation superheat requirements based on Eqs. (2.13) and (2.16).

analysis is expressed as the ratio of the minimum surface superheat in a variable temperature situation to that required if the liquid were uniformly superheated, namely

$$\frac{(T_w - T_s)_{\min}}{(T_w - T_s)_m} = \text{fctn}[r_m k(T_w - T_a)/q]. \quad (2.18)$$

The function increases monotonically with its argument, reaching a value of about 4.5 at an argument of 3. The utility of the Madejski approach is limited by the availability of data for boiling initiation temperatures in uniformly superheated liquids.

2.2.2 Transient Boiling Initiation

Most of the work performed concerning transient boiling phenomena has focused on constant pressure systems subjected to transient heating. Few are of interest here because pressure effects generally were not considered. Those studies that used pressure as a parameter (e.g., references 19, 20, and 21) reported that the superheat required for boiling initiation decreased with increasing pressure. However, these studies examined boiling at various constant system pressures and did not test the effects of applying a temporary overpressure before an experimental run.

Fabic (1) thoroughly examined the consequences of the pressure-temperature history of a heating element on boiling initiation. He argued that the maximum radius of an active (unflooded) initiation site at the time of a test is governed by the maximum value of the ratio $(p - p_v)/\sigma$ experienced prior to the test. Here p is the system pressure and p_v the fluid vapor pressure. Call this maximum ratio $(p_0 - p_{v0})/\sigma_0$. The maximum cavity radius is

$$r_c^+ = 2\sigma_o \frac{\cos(\pi-\theta_a)}{P_o - P_{vo}} \quad (2.19)$$

where θ_a ($>90^\circ$) is the contact angle between the cavity wall and the vapor-liquid interface within the cavity. The value of θ_a is taken as 108° for water at all temperatures and pressures. Values of the ratio and r_c^+ are given in Table 2.3 for water under various conditions.

Fablic noted that most test fluids at some time are at 20°C and atmospheric pressure. This leads to an upper bound of $r_c \equiv \hat{r}_c = 0.5 \mu\text{m}$, for radii of nucleation cavities. He argued that boiling initiation takes place with a contact angle θ_r between 0 and 66° , and at a surface temperature T_w which satisfies the equation

$$P_v(T_w) - p = 2\sigma \cos\theta_r / r_c^+, \quad r_c^+ < \hat{r}_c, \quad (2.20)$$

$$= 2\sigma \cos\theta_r / \hat{r}_c, \quad r_c^+ > \hat{r}_c, \quad (2.21)$$

where σ is evaluated at T_w . Upper and lower limits on T_w would depend on the choice of 0° or 66° for θ_r . If, in fact, the largest potential initiation site had a radius $r_m < r_c^+$, then that radius would apply.

One may inquire of the effect of boiling from the heating surface at test conditions for purposes of degassing the surface. Fablic argued that the process would "arm" previously inactive (flooded) sites with vapor and thus that the pressure and temperature under which the degassing took place would define r_c^+ .

One may also inquire of the effect of degassing at saturation conditions. Fablic is silent on this point. Presumably sites of all sizes would be activated and r_m would govern subsequent boiling initiation.

Table 2.3. Maximum active site radius as a function of temperature and pressure, computed using the Fabic Model [1].

Fluid Temp. (°C)	Pressure (MPa)	$(p-p_v)/\sigma \text{ } (\mu\text{m}^{-1})$	$r_c^+ \text{ } (\mu\text{m})$
20	0.101	1.35	0.46
	1.398	19.1	0.032
70	0.101	1.08	0.57
90	0.101	0.51	1.21
95	0.101	0.28	2.22
100	0.476	6.33	0.098
100	1.123	17.3	0.036
100	1.398	21.9	0.028
120	0.476	5.02	0.12
140	0.476	2.24	0.28
145	0.476	1.21	0.51
165	1.398	15.2	0.041
185	1.398	6.64	0.093
190	1.398	3.55	0.17

Winterton (2) also developed an expression for conditions at nucleation based on the pressure-temperature history of the heater,

$$p_v + p_g - p = \frac{1}{\gamma} \frac{\sigma}{\sigma_0} (p_o - p_{vo} - p_{go}) , \quad (2.22)$$

where p_g is the partial pressure of noncondensable gas, and γ is defined as

$$\gamma = \frac{\cos(\pi - \theta_a + \frac{\alpha}{2})}{\cos(\theta_r - \frac{\alpha}{2})} , \quad (2.23)$$

where α is the included apex angle of the cavity. It will be noted that Eq. (2.22) reduces to Eq. (2.20) for the case of a well degassed system and a cylindrical cavity ($\alpha = 0$). Winterton performed a number of experiments using vertical tubes to test theories of nucleation by surface cavities. He examined both transient heat flux - constant pressure and constant heat flux - transient pressure cases. Liquid pressures were in the range of approximately 0.01 to 0.1 MPa for both cases and true heat fluxes in the transient heat tests were 10 kW/m² maximum, resulting in a rate of rise in temperature of less than 1°C/s. For the transient heat case, he reported that the vapor pressure at nucleation increased with increasing overpressures, but that the effect was not as pronounced as indicated by the theory with γ set equal to unity. He reported that the order of magnitude of γ was 1, but his experiments indicated that the value was not constant. Instead, γ increased as the overpressure increased. The limitations of his experimental apparatus precluded making conclusions about the effect on the transient pressure case. However, for the conditions under which he was able to make both transient heat and transient pressure measurements,

he found no significant difference in the calculated cavity radius required for nucleation, thus confirming the equivalence of the two methods of nucleation. Gallagher and Winterton (4) performed a study which expanded on the power transient boiling work of Winterton. Again, a very low heat flux was used, and overpressures up to 0.7 MPa were applied before performing tests at 0.0122 MPa. They found that special preparation of the test section was necessary to produce consistent results. They reasoned that this preparation was associated with obtaining suitable and consistant values of contact angles within the surface cavities. Their results show a strong effect of pressure on deactivating cavities. They reported good agreement between their results and Eq. (2.22) using a constant value for γ of 5.4.

Faw and VanVleet (22), investigating boiling initiation from a horizontal wire in a subcooled pool of water, reported initiation conditions that were not consistent with any single size-distribution of nucleation sites. However, nearly all results were consistent with predictions made using Fabic's model. They also found that pre-pressurization well above saturation pressure led to greatly increased superheat requirements at boiling initiation consistent with the model. They noted that only the first test after pressurization was so affected; subsequent tests in the series had boiling initiation superheats approximately those expected in the absence of pre-pressurization. They postulated that the first test reactivated previously flooded sites.

Investigation of boiling phenomena during transient pressure conditions has been prompted by desire to determine the response of a high pressure, high temperature heat exchanger system (e.g., a nuclear

reactor) to a loss of pressure. Since the mechanical integrity of such a system can be breached by events resulting from inadequate heat transfer, most studies have examined the transition from nucleate to film boiling and critical heat fluxes (e.g., references 23, 24, and 25).

The initiation of boiling during decompression has received limited attention. Fabic argued that his pressure-temperature history modeling of boiling initiation would also apply to the pressure transient case. He noted that the nucleation event could occur due to a decrease in system pressure even if the surface temperature T_w did not change. In this case the system pressure p necessary for vapor nucleation could be predicted from Eqs. (2.20) and (2.21). Values of the boiling initiation pressure in water, based on the Fabic model, are given in Table 2.4 for water under various conditions.

It can be expected from Fabic's model that an increase in the initial overpressure applied to a system should cause an increase in the instantaneous surface superheat [$T_w - T_s(p)$] necessary to initiate boiling. This increase would manifest itself by producing a measurable delay between the time boiling initiation is predicted by steady-state considerations and when it is actually observed. Hooper and Abdelmessih (26) observed just such an occurrence in a study of liquid flashing. However, Kenning and Thirunavukkarasu (27) found no indication of delay in bubble growth in their study of bubble nucleation characteristics of surfaces.

Weisman, et al. (3), in a study of boiling initiation using heated and unheated ribbons, found that measurable delays in boiling initiation could be encountered under appropriate conditions. They suggested that the results of Kenning and Thirunavukkarasu could be explained by the

Table 2.4. Boiling initiation system pressure values prescribed by the Fabic model (1) at $T = 100^\circ\text{C}$ and using $\theta = 66^\circ\text{a}$:
 $T_w = T_b$ until after initial pressure is applied.

p_i (MPa)	T_w ($^\circ\text{C}$)	p_b (MPa)
0.239	140	0.204
0.273		0.165
0.308		0.125
0.308	150	0.250
0.377		0.175
0.411		0.137
0.377	160	0.330
0.446		0.258
0.515		0.186
0.584		0.114
0.515	170	0.380
0.584		0.312
0.653		0.243
0.790		0.106
0.584	180	0.546
0.653		0.481
0.790		0.350
0.997		0.155

fact that the pressure was released very rapidly to well below saturation pressure, thus activating unflooded cavities and allowing bubble growth to begin almost immediately. In their own investigation, the authors also found that the superheat required to initiate boiling on an unheated ribbon increased with increasing rate of depressurization. This is consistent with results obtained in studies of the response of hot water to rapid depressurization (28)(29). Furthermore, Weisman et al. found that at low decompression rates the superheats required to initiate boiling showed no effects due to the pressure history, and instead approached steady-state values. These superheats, in the 3 - 4°C range, were substantially below those predicted for the pressure-time histories considered. The authors reasoned that small bubbles of noncondensable gas could remain at a cavity base after application of an overpressure. As pressure is reduced, vapor diffuses into the bubble, which then fills the cavity. Thus, an active cavity is present with a radius larger than the maximum unflooded radius predicted, and boiling is possible at a superheat below that predicted using the maximum unflooded radius. The authors speculated that the finite time to fill such a cavity could be the reason for the delay. Heated ribbons were used to verify that the first boiling in the system occurred on the ribbon. The authors noted that the superheats were higher than for the tests without heating, but they did not comment on how these superheats compared to predicted values.

Sakurai, et al. (5), examined transient boiling of a test heater caused by depressurization with near-exponential reduction periods ranging from 3 to 60 ms. The platinum wire test heater was initially in a nonboiling state in a pool of water, and the heat generation rate at

the heater was held constant throughout the experimental run. They used initial pressures of 0.59, 1.08, and 1.9 MPa with water temperatures of 353 and 373 K. Rapid decompression was achieved using a rupture disc device to vent the test section to atmosphere. The authors found that the heater surface temperature and true heat flux remained constant until boiling initiated. The incipient boiling point was assumed to have been reached at the time the heater temperature began to decrease. They argued that this gave the criterion for boiling initiation even if it may not have been the true incipient boiling point. They found that the pressure p_b , and the instantaneous surface superheat, ΔT_b , at the incipient boiling point depended upon the heat flux, even if the initial overpressure and the reduction period were the same. They noted that ΔT_b increased with decreasing p_b and was little dependent on the pressure reduction period, consistent with the incipient boiling model of Sakurai and Shiotsu [Eq. (2.11)].

2.3 Nucleate Boiling

A well-known correlation for fully-developed subcooled and saturated nucleate pool boiling is that of Rohsenow (30), which may be expressed in the form

$$q = C_1(T_w - T_s)^3. \quad (2.24)$$

The factor C_1 is a function of pressure (fluid properties evaluated under saturation conditions) and fluid-surface combination, namely

$$C_1 = [(p_f p_v)g/\sigma]^{1/2} u \lambda P_r^{3n} (c/\lambda C_2)^3, \quad (2.25)$$

where g is the acceleration of gravity, u is the viscosity of the fluid, and c is the heat capacity of the fluid. The constant n and the value

of C_2 depend on the fluid-surface combination (18), and take the values 1.0 and 0.013 respectively for a platinum surface in water. Unless otherwise indicated, properties are those of the liquid phase. For example, for platinum-water at atmospheric pressure, $C_1 = 140 \text{ Wm}^{-2}\text{K}^{-3}$.

Stephan and Abdelsalam (31) carried out an exhaustive investigation of experimental data on pool boiling in various fluids and recommended the following correlation as being applicable to water

$$q = C_3(T_w - T_s)^{3.06} \quad (2.26)$$

in which C_3 is a function of saturation temperature. Based on data in the paper, C_3 may be expressed empirically, in S.I. units, as

$$C_3 = 229 p^{0.649} \quad (2.27)$$

where p is in units of MPa for the range 0.1 to 20. As an example, for boiling at atmospheric pressure, $C_3 = 52 \text{ Wm}^{-2}\text{K}^{-3.06}$. Thus, for a given surface superheat, this correlation predicts a much lower heat flux than that predicted by the Rohsenow correlation.

3. THEORY

3.1 Determination of Largest Potentially Active Cavity

In the absence of free gas bubbles, nucleation sites for boiling initiation will be located at surface cavities which have vapor trapped in them. The rate of boiling heat transfer is governed by the spatial distribution and the size spectrum of nucleation sites. Heat flux and superheat required to initiate boiling generally depend on the size of the largest site. The largest potential nucleation site, i.e., a cavity, idealized by a conical shape, containing vapor, can be determined by considering the pressure-temperature history of the surface along with the fluid-surface wetting characteristics.

Consider an arbitrary surface cavity, idealized by a conical shape, containing vapor with a fluid of infinite extent covering the surface (Fig. 3.1). Assume a well degassed fluid so that the partial pressure of noncondensable gas is negligible compared to vapor pressure and fluid pressure. The system is initially at pressure p_{f1} and at temperature T_1 at which the vapor pressure is p_{v1} less than p_{f1} and the surface tension is σ_1 .

When a pressure $p_{f2} \gg p_{v1}$ is applied, the fluid will enter the mouth of the cavity. Mechanical equilibrium across the meniscus requires

$$p_{f2} - p_{v1} = \frac{2\sigma_1}{R_M}, \quad (3.1)$$

where R_M is the radius of curvature of the meniscus (see Fig. 3.1).

From a geometric consideration, the cavity radius r at the meniscus line of contact is given by




FIG. 3.1. Illustration of vapor entrapment at a potential nucleation site.

$$r = R_M \cos(\pi - \theta_a + \frac{\alpha}{2}),$$

or

$$r = \frac{2\sigma_1}{P_{f2} - P_{v1}} \cos(\pi - \theta_a + \frac{\alpha}{2}) \quad (3.2)$$

where θ_a is the advancing contact angle between the fluid and the cavity wall, and α is the included angle of the cavity apex. The minimum pressure necessary for the meniscus to enter a cavity with mouth radius r_c can also be obtained from Eq. (3.2). If this requirement is not met, then the contact angle is less than θ_a and the meniscus is at the mouth or the cavity is flooded.

The argument of the cosine must fall between 0 and $\frac{1}{2}\pi$ since r must exist for vapor to be trapped in the cavity. This provides a maximum value for the apex angle of the cavity,

$$\alpha_{\max} < 2\theta_a - \pi. \quad (3.3)$$

If α is greater than this value, the cavity will flood with fluid and become deactivated. It is also apparent from Eq. (3.3) that θ_a must be greater than $\frac{1}{2}\pi$ for vapor to be trapped in the cavity.

Equations (3.1), (3.2), and (3.3) describe the potential nucleation sites available for the pressure-temperature history of the system when P_{f2} equals $P_{f,\max}$. Cavities with mouth radii greater than or equal to the critical radius $r = r_c$ when $P_{f2} = P_{\max}$ and apex angles less than α_{\max} will have the meniscus located at the position inside the cavity where the local cavity radius is equal to r_c . Cavities with apex angles greater than α_{\max} will be flooded, while cavities with mouth radii less than r_c will not be affected.

The description of the meniscus behavior as conditions leading to nucleation are imposed depends on the manner in which these conditions arise. Boiling can be initiated by decreasing the fluid pressure, increasing the vapor pressure by heating, or a combination of these two actions.

3.2 Activation of a Nucleation Site

3.2.1 Decrease in Fluid Pressure

If the fluid pressure is released to a value p_f such that $p_{vl} \leq p_f \leq p_{f2}$, the radius of the meniscus will change to a new value given by

$$R_M = \frac{2\sigma_1}{p_f - p_{vl}} . \quad (3.4)$$

The radius of the meniscus line of contact remains constant at the value given by Eq. (3.2), and the contact angle θ must satisfy

$$r = \frac{2\sigma_1}{p_f - p_{vl}} \cos(\pi - \theta + \frac{\alpha}{2}) = r_c . \quad (3.5)$$

As p_f approaches p_{vl} , the contact angle θ must decrease so that r remains constant. However, as long as p_f is greater than p_{vl} , the meniscus will be concave on the fluid side.

When p_f becomes less than p_{vl} , the meniscus radius becomes negative by Eq. (3.4), i.e., the meniscus flips from concave to convex on the fluid side. From the force balance,

$$R_M = - \frac{2\sigma_1}{p_f - p_{vl}} . \quad (3.6)$$

With no boiling, r remains constant at the value determined by Eq. (3.2). However, r can also be defined by

$$\begin{aligned} r &= R_M \cos(\theta - \frac{\alpha}{2}) \\ &= -\frac{2\sigma_1}{p_f - p_{vl}} \cos(\theta - \frac{\alpha}{2}) \end{aligned} \quad (3.7)$$

Equation (3.7) shows that r will remain constant as θ decreases to the value of the receding contact angle θ_r . When θ equals θ_r the fluid will begin to recede over the previously wetted cavity wall and the meniscus line of contact will move towards the cavity mouth. This will occur when

$$p_{vl} - p_f' = \frac{2\sigma_1}{r_c} \cos(\theta_r - \frac{\alpha}{2}). \quad (3.8)$$

When the meniscus is at the cavity mouth, boiling inception will take place when the meniscus radius of curvature is at a minimum, i.e., at the cavity mouth radius, \hat{r}_c . This will occur at a pressure p_f'' such that

$$p_{vl} - p_f'' = \frac{2\sigma_1}{\hat{r}_c} \quad (3.9)$$

The application of these equations to a range of cavity sizes will be discussed later. However, it is apparent that $p_f'' < p_f'$ when $r_c = \hat{r}_c$.

3.2.2 Increase in Vapor Pressure

If a temperature $T_2 > T_1$ is applied at pressure p_f , where $p_{vl} \leq p_f \leq p_{f2}$, the surface tension and the vapor pressure will assume new values σ_2 and p_{v2} , respectively. If T_2 is less than the saturation

temperature at p_f the meniscus radius of curvature will change, but the line of contact will not, and the radius r at the line of contact will remain constant at the value given by Eq. (3.2). Here,

$$R_M = \frac{2\sigma_2}{p_f - p_{v2}}, \quad (3.10)$$

and

$$\begin{aligned} r &= R_M \cos(\pi - \theta + \frac{\alpha}{2}) \\ &= \frac{2\sigma_2}{p_f - p_{v2}} \cos(\pi - \theta + \frac{\alpha}{2}) = r_c. \end{aligned} \quad (3.11)$$

Again, the interface is stable with the meniscus concave on the fluid side for $(p_f - p_{v2}) > 0$.

When the applied temperature T_2 becomes greater than the saturation temperature at p_f , the meniscus radius of curvature becomes negative by Eq. (3.10) and the meniscus flips from concave to convex on the fluid side. The force balance in this case requires

$$R_M = -\frac{2\sigma_2}{p_f - p_{v2}}. \quad (3.12)$$

The radius of the meniscus line of contact is given by

$$\begin{aligned} r &= R_M \cos(\theta - \frac{\alpha}{2}) \\ &= -\frac{2\sigma_2}{p_f - p_{v2}} \cos(\theta - \frac{\alpha}{2}) = r_c. \end{aligned} \quad (3.13)$$

The meniscus radius of contact remains constant as θ decreases to the value of the receding contact angle θ_r . Movement of the meniscus line of contact towards the cavity mouth will commence when

$$p'_{v2} - p_f = \frac{2\sigma'}{r_c} \cos(\theta_r - \frac{\alpha}{2}) , \quad (3.14)$$

corresponding to a temperature T'_2 . Again, boiling will initiate when the meniscus radius of curvature reaches a minimum equal to the cavity mouth radius \hat{r}_c . This will occur at a temperature T''_2 such that

$$p''_{v2} - p_f = \frac{2\sigma''}{\hat{r}_c} . \quad (3.15)$$

Although σ decreases with increasing temperature, under usual conditions $p''_{v2} > p'_{v2}$ or $T''_2 > T'_2$ when $r_c = \hat{r}_c$.

3.3 Cavity Geometry

Consider now a broad size range of active cavities present on the surface. The system has experienced conditions such that the meniscus radius of curvature is convex on the fluid side. If the meniscus line of contact is below the cavity mouth, an increase in $p_v - p_f$ can not be balanced in Eq. (3.8) or (3.14), and the line of contact will move towards the cavity mouth. First boiling will then occur from a cavity with mouth radius \tilde{r}_c such that

$$\tilde{r}_c = \hat{r}_c \sec(\theta_r - \frac{\alpha}{2}) , \quad (3.16)$$

since the threshold conditions for meniscus motion will also satisfy the requirement for nucleation from a cavity with mouth radius \tilde{r}_c .

The effect of the cavity apex angle in determining potential nucleation sites is revealed by Eq. (3.2), which shows that vapor can be trapped at lower liquid temperatures as α decreases. In other words, given two cavities with the same mouth radius, the cavity with the

smaller apex angle will boil first. Therefore, a cylindrical cavity ($\alpha = 0$) will be the largest potentially active nucleation site available, and the superheat required to achieve the receding contact angle θ_r will be less than for a conical cavity. The meniscus will rush out of the cylindrical cavity for an increase in $p_v - p_f$, and the relation of Eq. (3.9) or (3.15) must be satisfied to initiate boiling if the entrance angle to the cavity mouth is 90° . The superheat in this case may be higher than that required for a conical cavity with mouth radius \hat{r}_c if α is sufficiently small. However, Fabic (1) argued that the cavity mouth would be rounded, and appropriate rounding at the entrance would allow boiling to initiate after the meniscus flip with no additional superheat. This special rounding would also apply to conical cavities, but the only effect would be to allow the superheat necessary for boiling inception in a cavity with mouth radius \hat{r}_c to approach the value for \hat{r}_c . Since Fabic's argument provides the lower limit for boiling initiation, further discussion will consider cylindrical cavities where $r = r_c$ is the radius of the largest active cylindrical cavity according to Eq. (3.2).

3.4 Effect of Contact Angles

The contact angles used in this work are the same as those adopted by Fabic. He selected an advancing contact angle $\theta_a = 108^\circ$ for water on metal for all values of system pressures and temperatures. This value is based on reported findings that the largest contact angle water can make with a solid surface is $\theta_a = 105^\circ$ to 110° . His selection of the receding contact angle $\theta_r = 66^\circ$ was more arbitrary since it was a best fit value for his work. However, it also agreed with the observance of a 40° maximum difference between θ_a and θ_r .

Consider a horizontal surface immersed in well degassed water of infinite extent. The surface and the fluid are initially at uniform temperature T_1 when an initial pressure p_{f2} is applied. The surface is then heated to temperature $T_w = T_2$ such that no boiling occurs. Beginning at time $t = 0$, the system is subjected to a time-dependent decrease in the fluid pressure $p_f(t)$. No boiling will occur until p_f reaches the value necessary for boiling initiation.

The radius of the largest active cylindrical cavity is obtained from Eq. (3.2) for the conditions T_1 and p_{f2} ,

$$r_c = \frac{2\sigma_1}{p_{f2} - p_{v1}} \cos(\pi - \theta_a). \quad (3.17)$$

Since r_c remains constant until boiling is initiated, Eq. (3.13) also applies,

$$r_c = -\frac{2\sigma_2}{p_f - p_{v2}} \cos(\theta_r). \quad (3.18)$$

The fluid pressure necessary for boiling initiation, p_b , can be obtained by combining Eqs. (3.14) and (3.15),

$$p_b = p_{v2} - \frac{\sigma_2}{\sigma_1} \frac{\cos(\theta_r)}{\cos(\pi - \theta_a)} (p_{f2} - p_{v1}). \quad (3.19)$$

Figure 3.2 shows the effect of surface temperature on the incipient boiling pressure, where it is observed that increasing T_w causes p_b to increase. The figure also shows that for appropriate extreme conditions of initial pressure, no boiling is predicted.




FIG. 3.2. Effect of surface temperature on incipient boiling pressure with $\theta_u = 108^\circ$ and $\theta_r = 66^\circ$. Overpressure is applied at ambient temperature $T_a = 100^\circ\text{C}$.

The influence of the advancing and receding contact angles on the boiling initiation pressure can be examined using Eq. (3.19). Increasing the ratio of the cosine terms, by decreasing θ_r or increasing θ_a , requires a lower value of p_b (and hence a higher superheat) to satisfy the condition for nucleation. Decreasing the ratio of the cosine terms has the opposite effect. The effect of selected changes in contact angles on the ratio of the cosine terms is shown in the following table, and the effect on p_b for a representative case is shown in Fig. 3.3. It is apparent that the value of p_b is very sensitive to small changes in the value of either contact angle.

θ_a	θ_r	$\frac{\cos(\theta_r)}{\cos(\pi - \theta_a)}$
108°	66°	1.316
110°	63.25°	1.316
106°	68.73°	1.316
106°	66°	1.476
108°	62.86°	1.476
108°	68.45°	1.189
110°	66°	1.189




FIG. 3.3. Effect of selected changes in contact angle on incipient boiling pressure. Overpressure is applied at $T_a = 100^\circ C$ before the surface temperature is raised to $T_w = 160^\circ C$.

4. APPARATUS AND EXPERIMENTAL PROCEDURE

4.1 Pressure System

4.1.1 Pressure Vessel

The test vessel, shown in Fig. 4.1, is made of type 316 stainless steel. The vessel is 40.64 cm in length with an outer diameter of 12.065 cm and an inner diameter of 9.8425 cm. The end flanges are sealed with Ultek oxygen free hardened copper O-rings Model 2 68-4000, from Perkin-Elmer Corp. One end flange is penetrated by a 2 kW Firerod electrical heater, Model N6A22, from Watlow, Inc. This heater is used to maintain the ambient temperature of the test fluid. The other end flange is penetrated by the electrode assembly. A stainless steel-sheathed copper-constantan thermocouple from Watlow, Inc. penetrates the cylinder wall to provide constant monitoring of the bulk fluid temperature.

The two optical ports are essential to the observation of bubble growth behavior on the electrically heated test element. The design of the window housing is shown in Fig. 4.2. The windows are of T08 commercial grade clear fused quartz obtained from Amersil, Inc. The discs are 4.445 cm in diameter and 1.5 cm thick and, as estimated by Amersil, a pressure of 13.6 MPa may be used with an approximate safety factor of 3.5. The cushions and seals for the windows are fabricated of teflon.

4.1.2 Pressure Measurement System

A Kistler Quartz Miniature Pressure Transducer Model 603A penetrates the cylinder wall to provide the means to measure the pressure history during a transient. The point of penetration is between one of the optical ports and the end flange containing the electrode assembly, and




FIG. 4.1. Schematic diagram of the pressure vessel.




FIG. 4.2. Pressure vessel window housing.

on the horizontal plane through the test element. This location places the pressure transducer in closest proximity to the test element so that recorded information represents the actual pressure history of the test element during the experiment. Although the transducer will withstand sustained temperatures of up to 260°C without damage, its temperature must be limited to about 120°C to minimize drift and ensure good low frequency response. A water cooling adapter designed by Kistler provides this cooling capability, as well as being a most convenient means of attachment to the pressure vessel. Figure 4.3 shows details of the cylinder wall where the adaptor is mounted, and Fig. 4.4 shows the cooling adaptor design from Kistler. Since this design is for a physically larger transducer, an adaptor was designed to mount the Model 603A pressure transducer in the cooling jacket. The design of the second adaptor is shown in Fig. 4.5. Both adaptors were fabricated by machine shop personnel in the Department of Physics.

The quartz sensing element in the pressure transducer is oriented such that increasing applied pressure results in a negative-going charge signal that is inverted to a positive-going voltage signal by Kistler charge amplifiers. The Kistler Model 504E Dual Mode Amplifier is designed to develop the full capabilities of the quartz transducer while eliminating the attenuating effects of the cable and transducer capacitance.

Three factors must be considered when setting up the pressure measurement system for optimum performance: the system transfer function (i.e., volts output per measurand unit input), the correct time constant for the event, and the amplifier drift. All are directly affected by the settings on the dual mode amplifier.




FIG. 4.3. Pressure transducer cooling adaptor
mounting to the pressure vessel.




FIG. 4.4. Pressure transducer cooling adaptor, designed by Kistler.




FIG. 4.5. Pressure transducer adaptor for mounting the Model 603A to the cooling adaptor.

The system transfer function is inversely proportional to the transducer sensitivity, which is set on the dual mode amplifier as a value between 1.00 and 11.00. Since the pressure transducer used in this study has a sensitivity less than 1.00 pC/psi, a range multiplier of 10 is automatically required in determining the transfer function. The transfer function is also dependent on the amplifier gain, which varies directly with the range switch position.

The time constant is selected according to the temporal behavior of the input signal. Since the depressurization rates used in this study were small, the long time constant setting was chosen to avoid signal decay before the end of the transient. Unfortunately, the improvement in low frequency response allowed by the long time constant setting is at the expense of amplifier drift as a function of time.

Amplifier drift is inversely proportional to the range setting. For the long time constant the drift is measured in millivolts per second. Thus the need to minimize drift must be balanced against the desire to establish a system transfer function that provides maximum deflection of the output signal for a given pressure change.

4.1.3 Pressurizer

The pressurization system, as shown in Fig. 4.6, consists of a bottle of commercial nitrogen, the pressurizer, Model 30A-10WS, from Greer Hydraulics, Inc. and the pressure vessel. Seamless stainless steel tubing (0.635 cm) with 0.635-cm taper-seal valves from High Pressure Equipment Company is used for gas delivery. The high pressure nitrogen enters one side of the pressurizer and inflates a neoprene rubber bag. This bag presses against the water in the other half of the pressurizer. Thus, pressure can be applied to the test fluid without having the




FIG. 4.6. Pressurization system.

pressurizing gas dissolve in the test fluid. The pressure vessel is also connected to the water side of the pressurizer using seamless stainless steel tubing. On the gas side, there are two Asco Red Hat solenoid valves, Model 8262A214 from Automatic Switch Co., one to control inflow of gas and another solenoid valve to control the flow of gas to the atmosphere. On the fluid side of the system, there is another solenoid valve. Once the system is pressurized, this valve can be closed so that the pressure in the pressure vessel remains constant while the pressure on the gas side of the bladder is raised or lowered. Then the valve can be opened causing an instantaneous compression or decompression. There are also two Model 63-5622 pressure gauges from Matheson Corp. and one Model 7108P-200 pressure gauge from Transcat associated with the system. One Matheson gauge is on the pressure vessel itself and the other is on the supply line of the nitrogen gas, while the Transcat gauge is on the gas side of the pressurizer.

4.2 Heating Element

The test element, shown in Fig. 4.7, consists of two brass rods each 0.6350 cm in diameter and a teflon block. The teflon block is used to prevent the rods from sagging. The vertical support assembly can be adjusted to provide for different lengths of platinum wire. The teflon seals at the penetration points of the electrodes served a double purpose of providing a water tight seal and also providing insulation between the electrodes and the pressure vessel.

The heating element is of pure platinum wire (SPPL-010 from Omega Engineering, Inc.) of diameter 2.50×10^{-4} m and is mounted horizontally. The maximum length of the heating element is 9.6 cm. The spring attachment provides tension across the wire. The platinum wire not only




FIG. 4.7. Heating element construction.

acts as the test element but also as a temperature sensor. The resistance, $R(\theta)$, of pure platinum has a well characterized temperature dependence, (32)

$$R(\theta) = R_0 (1 + \alpha\theta + \beta\theta^2),$$

where

$$\alpha = 3.92 \times 10^{-3}$$

$$\beta = -5.5 \times 10^{-7}$$

θ = the temperature of the platinum wire in °C,

$R(\theta)$ = the resistance of the wire at temperature θ in ohms,

R_0 = the resistance of the platinum wire at 0°C.

Once the resistance is measured, the average temperature of the platinum wire can be calculated.

4.3 Electrical System

The electrical system consists of two twelve volt storage batteries, a control system, and a voltage bias system. The two storage batteries are wired in parallel and provide the dc current to the test element. The control system regulates current to the test element such that the power delivered remains constant with time. Figure 4.8 is a schematic diagram of the control system circuit. The voltage bias system is an EAI Analog Computer, Model TR-10. Simple linear summing circuits apply bucking voltages to the test voltages across the standard resistor and the test element so that only the variations in these voltages are recorded by the oscilloscope.

4.4 Data Measurement System

Data for the experimental runs are taken on a Nicolet Explorer III Digital Oscilloscope equipped with a floppy disc storage system and a





FIG. 4.8. Control system and power amplifier schematic diagrams.

RS-232C serial interface port for transmission of the stored data to other devices. The oscilloscope has two inputs, each with separate amplifying circuits. The oscilloscope is set in Cursor mode for triggering. In this mode the trigger source signal is continuously monitored until the triggering conditions are met or exceeded. At this instant the designated storage channel is assigned trigger time zero, and input signal regions both preceding and following the trigger time are stored for observation. Thus, although the event time zero may not correspond to the trigger time zero, the entire transient can be captured by judicious choice of the storage channel for trigger time zero. Any difference between trigger and event time zero can be accounted for in analysis.

Three voltage signals are available during a transient: one relating to pressure vessel pressure, and two relating to test element temperature. Experimental runs to determine the pressure history during decompression are performed by recording the voltage signal from the pressure transducer amplifier, with the oscilloscope triggered by this signal. The unused input channel is turned off so that the total recording capacity of the oscilloscope is utilized for recording the single input voltage. This signal provides the information necessary for determining the pressure history of the test element during the transient. Experimental runs to determine the test element temperature history during decompression are performed by recording the variations in both the voltage across the test element and the voltage across a standard resistor, Model 79 21 from Ohmite, with the oscilloscope triggered by the latter signal. The two source signals are fed to the voltage bias system, where the voltages induced by the application of

power at initial conditions are cancelled by applying bucking voltages. The two recorded signals, together with their respective bucking voltages, provide the information necessary for determining the resistance of the test element and thus its temperature, as well as the power delivered to the test element. The computer code used in the analysis of temperature data is provided in Appendix A, and the computer code used in the analysis of pressure data is provided in Appendix B.

4.5 Test Element Installation

The test vessel is cleaned using acetone and then rinsed with the test fluid. The optical ports require special attention during cleaning to keep the windows clear of spots and also free from scratches.

The test element is soldered to the brass electrodes of the test section. The entire test section is then cleaned with acetone to remove excess flux or other contamination arising from the soldering process. The test section is then installed in the pressure vessel and the mounting bolts torqued to 80 to 110 Nm. A small voltage is applied across the test element in such a way that the wire glows cherry red. The air heating is done for approximately ten minutes. The heating of the wire tends to anneal the surface of the wire thus leading to consistent surface properties.

After the initial preparation of the test element, the test fluid is poured into the pressure vessel. The wire is then conditioned by applying a small voltage across it until boiling initiated. The wire is operated at this voltage for approximately ten minutes, then the voltage is increased slightly. This is repeated until the voltage across the wire reaches a maximum of 10 V. The purpose of this conditioning is to activate the cavities on the wire by driving out any trapped gas.

Each time a new test element is installed, the power supply must be calibrated. The following steps are used:

1. Set V_a and V_b equal to zero by grounding.
2. Adjust R_2 until the output of V_x is equal to zero.
3. Adjust R_3 until the output of V_y is equal to zero.
4. Adjust R_6 until the output of V_o is equal to zero.
5. Set V_a and V_b equal to each other and adjust R_4 so that the output of V_o is equal to zero.
6. Set V_b to zero (leaving V_a alone), then adjust R_5 so that the output of V_o is equal to zero.
7. Set V_a equal to zero and re-adjust R_6 so that the output of V_o is again equal to zero.
8. Set V_a equal to 8.245 V and V_b equal to 4.588 V.
9. Adjust R_1 until V_x is equal to 10.00 V.
10. Adjust R_7 until V_y is equal to 10.00 V.

4.6 Procedures

4.6.1 Preliminary Procedures

These steps are followed before each experimental session:

1. The test fluid is heated to boiling and boiled for one hour to remove dissolved gases.
2. A voltage is applied to the test element until vigorous boiling has commenced. The boiling from the element is continued for ten minutes.
3. The pressure vessel is refilled with de-gassed, near-boiling test fluid, and all valves to atmosphere are closed.
4. All associated electronic equipment is allowed to warm up for the hour required for de-gassing.

5. The oscilloscope Channel B trigger level is adjusted using a Wavetek Digital VCG Model 113.

4.6.2 Experimental Procedures

Since the oscilloscope has only two input channels for recording data, pressure data and temperature data must be recorded in separate experimental runs. However, most procedural steps are the same.

These steps are followed to set up each experimental run:

1. Vigorous boiling from the test element is achieved and continued for ten minutes at atmospheric pressure and the desired bulk fluid subcooling. This allows activation of the full size range of bubble nucleation sites.
2. The test element is allowed to cool to test fluid bulk temperature.
3. The system is slowly pressurized to the desired pressure while holding the bulk temperature constant. The system is maintained at this condition for ten minutes to allow it to stabilize.
4. Power is applied to the test element until the desired test element temperature is achieved.
5. The zero settings on the active input amplifiers of the oscilloscope are adjusted and the trigger time zero is checked. These settings are important for proper triggering of the oscilloscope and for use in the computer analysis of the run.
6. Voltage signals from the standard resistor and the test element are fed to the voltage bias system. Bucking voltages are applied such that the signals from the voltage bias system to

the oscilloscope are nominally zero. (This step is performed only if recording temperature data.)

If the boiling initiation time is not desired when performing a run to record pressure data, steps 1, 2, and 4 may be disregarded.

After the run has been set up, these steps are followed to continue the experiment:

7. Equipment settings are checked and recorded as necessary, and test fluid pressure and temperature are recorded. The gas supply solenoid valve is then closed.
8. The decompression is initiated and the oscilloscope is triggered by the appropriate input signal.
9. The recorded data are stored on floppy disc for later transmission to the computer.
10. Manually observed boiling initiation time is recorded (if measured).
11. Steps 1 through 10 are repeated until all data for this combination of test parameters are acquired.

The above steps are repeated for other test parameter combinations of interest.

5. RESULTS

5.1 Boiling Initiation

The initiation of boiling at a surface is governed by the size distribution of potential nucleation sites and the fluid temperature profile adjacent to the surface. The largest site will be the first to become active since it requires the least superheat for boiling. The mouth diameter of the largest potentially active site is estimated to be 0.35 μm . This value was obtained from photo-micrographs of the surfaces of similar heating elements used in the concurrent study of pressure effects on boiling initiation during transient heating (22). As discussed in Chapter 3, the activation of a cavity occurs when the superheat has reached a prescribed magnitude at a distance from the surface comparable to the radius of the cavity mouth.

Natural convection determines the temperature gradient in the fluid adjacent to the surface before decompression. After natural convection is fully established, the thermal boundary layer and the temperature profile do not change significantly until the fluid is agitated, either by boiling or by bulk fluid movement. The increase in superheat necessary to initiate boiling arises from the decrease in the bulk fluid saturation temperature associated with the decrease in system pressure.

The temperature of the test element should behave in a simple manner when a constant power is applied and natural convection from the surface to the fluid is fully established. The temperature would be constant before a pressure transient is initiated, and would remain so during the transient until the inception of boiling. At this point the test element temperature would begin to decrease. Thus, finding this

point of time in the temperature history and the pressure at this time from the pressure history of a test would establish the conditions for boiling inception.

In this study of boiling initiation during pressure transients, three voltage signals, one for pressure and two for temperature, were available for each test. However, the digital oscilloscope could only record two of these simultaneously. Since both temperature signals had to be recorded for quantitative results, the nature and reproducibility of the decompression event had to be investigated.

The system was prepared for experimental runs by bulk boiling of the water in the pressure vessel for one hour at atmospheric pressure, after which the fluid lost through evaporation was replaced with degassed water at near-boiling temperature. The pressure vessel vent to the atmosphere was closed after bulk boiling, and subsequent system venting to the atmosphere was accomplished by opening the gas side of the pressurizer to atmospheric pressure. This was followed by vigorous boiling from the platinum test element for ten minutes. Pressure and temperature runs were then conducted to examine the effect of the pressure-temperature history on boiling initiation.

5.2 Pressure Runs

The program used to analyze the pressure runs is provided in Appendix B. The choice of amplifier time constant and the effect of system temperature on the pressure signal is discussed in Appendix C. Representative results from the program are provided in Appendix D. All pressure runs are described in Table 5.1.

The reproducibility of the decompression was of primary importance. In all runs the ambient temperature was 100°C, and the decompression

Table 5.1. Results of measurements made to determine the behavior of the pressure transients.

Run	p_a (MPa)	Drift (V/s)	Transfer Function (MPa/V)
AP2-2	0.377	-0.005246	0.7942
AP2-6	0.377	-0.005246	0.8654
AP2-7	0.515	-0.0096	0.7798
AP2-8	0.515	-0.0096	0.7908
AP3-4	0.515	-0.0096	0.8131
AP3-5	0.446	-0.007801	0.7631
AP3-6	0.446	-0.007632	0.7705
AP4-2	0.446	-0.005812	0.7748
AP4-3	0.584	-0.006913	0.7631
AP4-7	0.584	-0.005800	0.7771
AP4-8	0.584	-0.005295	0.7690
AP7-5	0.377	-0.003981	0.9952
AP7-8	0.377	-0.003926	1.0297
AP8-6	0.377	-0.002703	0.8536
AP9-2	0.377	-0.004091	0.9432
AP9-8	0.377	-0.002093	0.8248

ended at atmospheric pressure. The pressure histories for decompressions from initial pressures of 0.377-0.584 MPa are illustrated in Figs. 5.1 - 5.4, where it is seen that the decompression event is reproducible over most of the initial pressure drop.

The results of runs AP2-7, AP2-8, and AP3-4 require special comment. For unknown reasons, analysis of the raw data indicated negligible drift and a pressure transducer sensitivity greater than the manufacturer's specification. Since this was not characteristic of previous experience, a drift value was arbitrarily specified to give a transfer function reasonable with expectations. However, results with this data should be viewed with caution.

The pressurizer tended to back-fill with water from the pressure vessel in the course of the repeated fluid temperature cyclings experienced. This process was slow enough that little effect on depressurization was observed until the pressurizer was almost completely full of water. When this occurred the decompression event became erratic and unreliable. When approximately two liters of water were removed from the pressurizer, allowing a larger gas volume for pressurization, the rate of decompression changed significantly (Fig. 5.5). However, the partial removal of water did not affect the reproducibility of subsequent pressure runs, as shown in Figs. 5.6 and 5.7.

The decompressions displayed near-exponential behaviors over the reproducible portions of the transients. Figures 5.8 and 5.9 illustrate this behavior for representative pressure runs, and Table 5.2 lists their approximate reduction periods. These periods were on the order of 4 s before the pressurizer was partially drained and on the order of 6.6 s afterward.




FIG. 5.1. Experimental pressure results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$. The solid line represents results from run AP2-2. The dashed line represents results from run AP2-6.




FIG. 5.2. Experimental pressure results for decompression from 0.515 to 0.101 MPa at $T_a = 100^{\circ}\text{C}$. The dashed line represents results from run AP2-7, the solid line represents results from run AP2-8, and the dot-dashed line represents results from run AP3-4.




FIG. 5.3. Experimental pressure results for decompression from 0.446 to 0.101 MPa at $T_a = 100^\circ\text{C}$. The solid line represents results from run AP3-5, the dashed line represents results from run AP3-6, and the dot-dashed line represents results from run AP4-2.




FIG. 5.4. Experimental pressure results for decompression from 0.584 to 0.101 MPa at $T_s = 100^\circ\text{C}$. The solid line represents results from run AP4-3, the dashed line represents results from run AP4-7, and the dot-dashed line represents results from run AP4-8.




FIG. 5.5. Comparison of experimental pressure results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$ before and after partial draining of the pressurizer. The solid line represents run AP2-2, performed before approximately 2 liters of water were removed from the pressurizer. The dashed line represents run AP8-8, performed after the quantity of water was removed.




FIG. 5.6. Experimental pressure results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$. The maximum system pressure was 0.377 MPa. The solid line represents results from run AP7-5. The dashed line represents results from run AP7-8.




FIG. 5.7. Experimental pressure results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$, after application of a maximum pressure greater than 0.377 MPa. The solid line represents results from run AP8-6, the dashed line represents results from run AP9-2, and the dot-dashed line represents results from run AP9-B.




FIG. 5.8. Experimental pressure results for decompressions to 0.101 MPa at $T_a = 100^\circ\text{C}$. Initial pressures were 0.377 to 0.584 MPa. Results are from representative runs performed before removal of a quantity of water from the pressurizer.




FIG. 5.9. Experimental pressure results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$ after application of a maximum pressure $P_{a,\text{max}} > 0.377 \text{ MPa}$. Results are from representative runs performed after removal of a quantity of water from the pressurizer.

Table 5.2. Approximate reduction periods for representative pressure runs.

Series	Run	t_1 (s)	t_2 (s)	$p(t_1)$ (MPa)	$p(t_2)$ (MPa)	τ (s)
1	AP2-2	0.56	3.60	0.3153	0.1496	4.078
2	AP2-8	0.56	3.60	0.4300	0.1921	3.773
3	AP3-5	0.56	3.60	0.3764	0.1733	3.920
4	AP4-3	0.56	3.60	0.4822	0.2089	3.634
5	AP7-5	0.56	5.52	0.3449	0.1736	7.225
6	AP8-6	0.48	10.08	0.3409	0.1612	6.622
7	AP9-2	0.56	5.52	0.3396	0.1587	6.519
8	AP9-8	0.56	5.52	0.3394	0.1615	6.680

5.3 Temperature Runs

The preparation of the system for a series of runs was described earlier. Additionally, each temperature run was preceded by vigorous boiling from the platinum test element for ten minutes at atmospheric pressure to ensure a consistent range of cavity sizes before pressurization.

In the series of tests presented, the system was pressurized to a maximum ambient pressure, $p_{a,\max}$, while the bulk water temperature was held steady at 100°C. Power was then applied to the test element to elevate its temperature to 160°C. The decompression event was then initiated and a manual measurement of boiling initiation time t_b was obtained. The program used to analyze the temperature runs is provided in Appendix A. Representative results from the program are provided in Appendix E. All series are described in Table 5.3.

In series 1 the system was pressurized to a maximum pressure of 0.377 MPa. Figure 5.10 illustrates series 1, where it is observed that the temperature of the test element began to decrease almost immediately, while the measured boiling initiation time occurred after the temperature had dropped an appreciable amount.

In series 2 the system was pressurized to 0.515 MPa. The results of this series are shown in Fig. 5.11. The temperature of the test element remained constant for approximately two seconds, and the measured boiling times were close to the times at which the temperatures begin to decrease. Also apparent is the variability of the heater temperature recovery to a steady-state value.

Figures 5.12 and 5.13 illustrate series 3 and series 4, in which the system was pressurized to 0.446 and 0.584 MPa, respectively. Again, the heater temperature remained constant for a period of time after

Table 5.3. Experimental conditions for measurements to determine the effects of pressure-temperature history on boiling initiation. Initial conditions: wire temperature $T_w = 160^\circ\text{C}$, ambient temperature $T_a = 100^\circ\text{C}$.

Series	Run	Duration (s)	$p_{a,\max}$ (MPa)	$p_a(t=0)$ (MPa)	q (MW/m ²)
1	AP2-3	20	0.377	0.377	0.427
	AP2-4	20	0.377	0.377	0.430
	AP2-5	20	0.377	0.377	0.432
2	AP3-1	20	0.515	0.515	0.424
	AP3-2	20	0.515	0.515	0.424
	AP3-3	20	0.515	0.515	0.437
3	AP3-7	20	0.446	0.446	0.419
	AP3-8	20	0.446	0.446	0.419
	AP4-1	20	0.446	0.446	0.419
4	AP4-4	20	0.584	0.584	0.408
	AP4-5	20	0.584	0.584	0.416
	AP4-6	20	0.584	0.584	0.416
5	AP7-2	20	0.377	0.377	0.407
	AP7-3	20	0.377	0.377	0.419
	AP7-4	20	0.377	0.377	0.419
	AP7-6	20	0.377	0.377	0.419
	AP7-7	20	0.377	0.377	0.419
6	AP8-4	20	1.480	0.377	0.419
	AP8-5	20	>1.480	0.377	0.414
7	AP8-7	20	1.480	0.377	0.418
	AP8-8	100	1.480	0.377	0.424
8	AP9-4	200	0.791	0.377	0.418
	AP9-6	200	0.791	0.377	0.418




FIG. 5.10. Experimental temperature results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$ and initial heater temperature $T_w = 160^\circ\text{C}$. The reduction period of the pressure transient was on the order of 4 s. The circles mark the measured boiling initiation times.




FIG. 5.11. Experimental temperature results for decompression from 0.515 to 0.101 MPa at $T_a = 100^\circ\text{C}$ and initial heater temperature $T_u = 160^\circ\text{C}$. The reduction period of the pressure transient was on the order of 4 s. The circles mark the measured boiling initiation times.




FIG. 5.12. Experimental temperature results for decompression from 0.446 to 0.101 MPa at $T_A = 100^\circ\text{C}$ and initial heater temperature $T_w = 160^\circ\text{C}$. The reduction period of the pressure transient was on the order of 4 s. The circles mark the measured boiling initiation times.




FIG. 5.13. Experimental temperature results for decompression from 0.584 to 0.101 MPa at $T_a = 100^\circ\text{C}$ and initial heater temperature $T_h = 160^\circ\text{C}$. The reduction period of the pressure transient was on the order of 4 s. The circles mark the measured boiling initiation times.

initiation of the pressure transient, and measured boiling times were close to the points where the temperatures began to decrease. Figure 5.13 also shows particularly well the variable nature of the heater temperature recovery after boiling had begun.

Series 5-8 were performed after removal of a quantity of water from the pressurizer. The rates of decompression in these runs were less than those for series 1-4 as discussed earlier. Additionally, the procedure was varied such that the system was subjected to a maximum pressure $p_{a,\max}$, then slowly returned to a starting pressure $p_a(t=0)$, the pressure at the initiation of the pressure transient.

In series 5 the maximum pressure was 0.377 MPa. Measured boiling initiation times for all runs in this series except for run AP7-6 were well after the heater temperature had begun to decrease. As in series 1, the heater temperature began to decrease almost immediately after initiation of the pressure transient. Figure 5.14 illustrates this series.

In series 6 and series 7 the maximum pressure applied was 1.480 MPa. The exception was run AP8-5, which experienced an unknown maximum pressure greater than 1.480 MPa. In these runs the measured boiling time corresponds to the time of the first audible bubble collapse. Bubbles did not appear on the visible part of the test element until after the system had returned to atmospheric pressure. In series 6 (Fig. 5.15), the heater temperature began to decrease shortly after initiation of the pressure transient, but the decrease was very gradual until the end of the pressure transient. Heater temperature fluctuations indicative of substantial nucleate boiling then appeared, but the temperature decreased minimally compared to runs with less extreme overpressures.




FIG. 5.16. Experimental temperature results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$ and initial heat temperature $T_h = 160^\circ\text{C}$. The maximum pressure applied was 0.377 MPa and the pressure reduction period was on the order of 6.6 s. The circles mark the measured boiling initiation times.




FIG. 5.15. Experimental temperature results for decompression from 0.377 to 0.101 MPa at $T_a = 100^\circ\text{C}$ and initial heater temperature $T_w = 160^\circ\text{C}$. The maximum pressure applied was 1.48 MPa and the pressure reduction period was on the order of 6.6 s. The circles mark the measured boiling initiation times.

This behavior was also observed in series 7, in which runs of 20 s and 100 s duration were performed. The temperature behavior during the first 20 s of the event is shown in Fig. 5.16(a). Even 100 s after the initiation of the pressure transient [Run AP8-8 and Fig. 5.16(b)] the heater temperature had only decreased about 7 K, as opposed to 10-12 K drops in 20 s seen in series 5, for example.

The long-term behavior of the heater temperature was of specific interest in series 8. The maximum pressure in this series was 0.791 MPa, and the duration of the runs was 200 s. Again, no bubbles were seen until after the system had returned to atmospheric pressure. Measured boiling initiation times were before substantial nucleate boiling was indicated by the temperature analysis. The minimal decrease in the heater temperature during the first 20 s of the event is illustrated in Fig. 5.17(a). After the initial drop, the temperature reached a plateau before experiencing a more sustained decrease. The heater temperature approached the steady-state boiling temperature at the same superficial heat flux by approximately 200 s. Series 8 and the corresponding steady-state boiling temperature traces are shown in Fig. 5.17(b).

If the point at which the heater temperature starts to decrease is taken as the incipient boiling point, conditions at boiling initiation can be determined from pressure and temperature values at this time. Normally, this estimated time should be equivalent to the measured boiling initiation time, with any difference accounted for by resolution of the data analysis, human error, and reaction time in operating the chronograph. However, a significant discrepancy could exist between these two times. If the resolution limit of the analyzed data is




FIG. 5.16(a). Experimental temperature results showing the initial behavior of the heater temperature for $T_a = 100^\circ\text{C}$ and initial heater temperature $T_w = 160^\circ\text{C}$. The decompression was from 0.377 to 0.101 MPa after a maximum pressure of 1.48 MPa had been applied. The reduction period of the pressure transient was on the order of 6.6 s. The circles mark the measured boiling initiation times.




FIG. 5.16(b). Experimental temperature results showing the long-term behavior of the heater temperature for $T_a = 100^\circ\text{C}$ and initial heater temperature $T_u = 160^\circ\text{C}$. The decompression was from 0.377 to 0.101 MPa after a maximum pressure of 1.48 MPa had been applied. The reduction period of the pressure transient was on the order of 6.6 s.




FIG. 5.17(a). Experimental temperature results showing the initial behavior of the heater temperature for $T_a = 100^\circ\text{C}$ and initial heater temperature $T_w = 160^\circ\text{C}$. The decompression was from 0.377 to 0.101 MPa after a maximum pressure of 0.791 MPa had been applied. The reduction period of the pressure transient was on the order of 6.6 s. The circles mark the measured boiling initiation times.




FIG. 5.17(b). Experimental temperature results showing the long-term recovery of the heater temperature to the steady-state nucleate boiling value at $T_e = 100^\circ\text{C}$. The decompression was from 0.377 to 0.101 MPe after a maximum pressure of 0.791 MPe had been applied. The initial heater temperature was $T_w = 160^\circ\text{C}$, and the reduction period of the pressure transient was on the order of 6-6 s. The superficial heat fluxes were the same for the transient and the steady-state run. The time scale of the steady-state results as shown is multiplied by a factor of 10.

approached, the measured value should be selected as the true boiling initiation time. If boiling initiates on a part of the test element outside the visual range and the ambient noise level precludes audio detection, the measured time would be late and the estimated value should be selected as the true boiling initiation time. Additionally, although the partial pressure of noncondensable gas is assumed to be negligible, an isolated cavity could contain a bubble of noncondensable gas. Premature non-boiling bubble formation could occur at this site. The frequency of bubble formation would not display the periodicity of true nucleate boiling. Although conditions for boiling initiation would not have been achieved according to the criteria of this work, the chronograph would have been stopped at the appearance of the first bubble. Again, the estimated boiling initiation time should be selected. Following this prescription for determining true boiling initiation times, the measured and true boiling initiation times and conditions at boiling initiation are given in Table 5.4 for all series.

Table 5-6. Results of measurements made to determine the effects of pressure-temperature history on boiling initiation. In all cases, the heater is a platinum wire of 0.25 mm diameter and 9.6 cm length. Demulsions was carried out at atmospheric pressure. True boiling initiation times are at the point the heater temperature began to show a substantial decrease. Initial conditions: wire temperature $T_w = 160^\circ\text{C}$, ambient temperature $T_a = 100^\circ\text{C}$.

Series	Run	Measured t_b (s)	P_b (MPa)	$T_b - T_a$ (K)	True t_b (s)	P_b (MPa)	$T_b - T_a$ (K)	$T_b - T_g$ (K)
1	AP2-3	2.17	0.208	57.9	36.4	0.08 ^a	0.365	59.4
	AP2-4	2.95	0.173	57.4	41.7	0.08	0.365	60.8
	AP2-5	2.26	0.204	58.1	37.3	0.08	0.365	59.8
2	AP3-1	2.93	0.228	59.3	34.9	2.16	0.279	59.8
	AP3-2	2.99	0.225	59.1	35.1	2.16	0.279	59.7
	AP3-3	2.78	0.238	59.0	33.2	2.16	0.279	59.6
3	AP3-7	2.67	0.218	59.1	36.1	1.84	0.269	59.8
	AP3-8	2.75	0.214	59.0	36.6	1.84	0.269	59.8
	AP4-1	2.74	0.215	59.2	36.7	2.00	0.259	59.9
4	AP4-4	3.78	0.291	59.8	39.4	3.92	0.194	59.8
	AP4-5	3.76	0.202	59.7	39.1	3.76	0.202	59.7
	AP4-6	3.69	0.205	59.9	38.9	3.12	0.236	60.2
5	AP7-2	4.28	0.202	58.7	38.2	1.46 ^b	0.299	39.3
	AP7-3	5.14	0.181	59.3	42.2	1.46	0.299	60.2
	AP7-4	4.39	0.199	59.1	39.0	1.46	0.299	60.0
6	AP7-6	1.46	0.299	59.9	26.5	1.46	0.299	59.9
	AP7-7	5.7	0.170	58.8	43.6	1.46	0.299	60.2
	AP8-4	5.52	0.161	59.2	45.7	8.88	0.110	58.4
7	AP8-5	6.08	0.149	58.6	47.4	11.76 ± 0.48	0.101	57.7
	AP8-7	5.35	0.162	59.5	45.8	8.08	0.123	59.0
	AP8-8	5.90	0.152	59.1	47.4	8.4 ± 0.8	0.120	58.6
8	AP9-4	5.05	0.174	59.2	43.3	7.2 ± 0.8	0.131	58.2
	AP9-6	3.88	0.203	59.8	39.1	7.2 ± 0.8	0.131	58.7

^aListed times are first times for which temperature data were calculated. The estimated time range is 0.08 to 0.40 s.

^bListed times are from the measured time of Run AP7-6. The estimated time range is 1.0 to 2.5 s.

6. DISCUSSION OF RESULTS

6.1 Pressure Measurement

After the initiation of decompression the pressure vessel experienced a near-exponential reduction in pressure. Pressure transients were generally reproducible to times well beyond measured boiling initiation times. The spikes that occasionally appeared in the measurements are believed to be due to spurious electronic noise. The pressure measurement system sensitivity was less than expected due to installation constraints (see Appendix C). However, the system performed consistently except in the decompressions from 0.515 MPa (series 2). The reasons for the unusual behavior in those runs are unknown; therefore the results of series 2 are not considered in the following discussion.

6.2 Estimation of Boiling Initiation Times

Consider a heater experiencing a constant power application. In the case where heat transfer from the heater to a surrounding fluid is by natural convection, the inception of nucleate boiling will enhance the heat transfer and cause the heater surface temperature to decrease. Estimated boiling initiation times were obtained by determining the times at which the test heater temperature began to show a substantial decrease. These times provided an independent means of confirming measured boiling initiation times. The accuracy of the estimated times was dependent on the techniques used to obtain and analyze the raw voltage data. Since the variations in the voltages were expected to be small compared to the initial applied voltages, the measurement system was set up to measure only the variations. The analysis of the data required averaging the data over several points to minimize masking of

changes in true voltage by electrical noise. However, the data reduction resulted in coarse time steps and thus crude estimations of the time at which the heater temperature began to decrease. Although the two methods of determining boiling initiation times should have produced the same values, this was observed only in series 3 and series 4, where the inception of boiling was accompanied by a marked change in heater temperature. In these two series, the true boiling initiation times were the measured times adjusted according to the temperature histories. These adjustments were reasonable considering reaction times and human error. In the other series, however, experimental runs generally lacked a sharp change in heater temperature at boiling initiation, and the combination of test conditions helped to produce major differences in estimated and measured times. In series 1 the temperature began to decrease almost immediately, so true boiling initiation times were the first times for which temperature data were calculated. In series 5-8 poor data resolution combined with relatively slow pressure transients required specification of a range of boiling initiation times. Table 6.1 summarizes the conditions at boiling initiation for the series considered.

6.3 Effects of Pressure-Temperature History on Boiling Initiation

Runs in each series had been preceded by vigorous boiling from the test element for 10 minutes at atmospheric pressure and bulk fluid temperature $T_a = 100^\circ\text{C}$. The pressure was raised to the maximum value for each run before power was applied to the test heater to elevate its temperature.

In series 1, 3, and 4 the decompression began at the maximum pressure, and reduction periods were on the order of 4 s. The boiling

Table 6.1 Summary of results of measurements made to determine the effects of pressure-temperature history on boiling initiation. In all cases, the heater is a platinum wire of 0.25 mm diameter and 9.6 cm length. Degassing was carried out at atmospheric pressure. Initial conditions: $T_w = 160^\circ\text{C}$, $T_a = 100^\circ\text{C}$.

Series	$p_{a,\max}$ (MPa)	$p_a(t=0)$ (MPa)	t_b (s)	p_b (MPa)	$T_b - T_s$ (K)
1	0.377	0.377	0.08 - 0.40	0.365 - 0.330	19.7 - 23.2
3	0.446	0.446	1.84 - 2.00	0.269 - 0.259	30.2 - 31.4
4	0.584	0.584	3.12 - 3.92	0.236 - 0.194	34.4 - 40.7
5	0.377	0.377	1.0 - 2.5	0.321 - 0.260	24.1 - 31.3
6	1.48	0.377	8.88 - 12.24	0.110 - 0.101	57.7 - 60.0
7	1.48	0.377	7.6 - 9.2	0.127 - 0.114	53.6 - 56.7
8	0.791	0.377	6.4 - 8.0	0.144 - 0.121	49.9 - 55.0

initiation times increased with increasing initial pressure, and no overlapping of times was observed for the different series. Increasing initial pressure also resulted in decreasing boiling initiation pressures and increasing superheats at boiling inception.

In series 1, Fabic's hypothesis gives the largest available nucleation sites radii of $r_c = 0.132 \mu\text{m}$. This would lead to a boiling initiation pressure of 0.330 MPa and a boiling initiation superheat of 23.2 K. In series 3, $r_c = 0.106 \mu\text{m}$, leading to a boiling initiation pressure of 0.258 MPa and a boiling initiation superheat of 31.5 K. Both of these series are in excellent agreement with the Fabic model if the estimated boiling inception times are used. However, the model predicts a boiling initiation pressure of 0.114 MPa for the cavity size $r_c = 0.075 \mu\text{m}$ of series 4. This pressure is substantially below that observed in this series.

In series 5-8 the pressure transient was initiated from 0.377 MPa after the initial maximum pressure was applied. Reduction periods were on the order of 6.6 s. Boiling initiation times increased with increasing initial pressure, but the range of times tended to overlap for maximum pressures of 0.791 and 1.48 MPa.

Series 5 repeated the conditions of series 1 at a slower decompression rate. Although superheats were higher and pressures were lower at the inception of boiling in series 5, the results also support Fabic's model. Series 6-8 experienced such extremes in pressure that Fabic's model predicted no boiling for the given heater temperature. The model predicted a maximum cavity radius of 0.026 μm for series 6 and series 7, which would require a heater temperature of 192.3°C to initiate boiling. Series 8 would require a heater temperature of

169.7°C to initiate boiling from a predicted maximum cavity radius of 0.053 μm. However, the heater temperature history indicated that boiling began near the end of decompression, and after an additional period of time sites were seen to commence nucleating on the visible part of the test element.

6.4 Approach to Steady-State Boiling

Even though Fabic's model greatly underpredicted boiling initiation pressures (and overpredicted boiling initiation superheats) in series 4 and series 6-8, the pressure-temperature history did affect the reactivation of nucleation sites as the runs progressed.

The models used to predict boiling conditions based on cavity size can also explain the behavior of the heater temperature as steady-state nucleate boiling is approached. Consider Eq. (2.7),

$$p_v(T_w) - p_v(T_s) = 2\sigma(T_w)/r_c. \quad (2.7)$$

Although surface tension decreases with increasing temperature, vapor pressure is more sensitive to temperature variations and hence dominates the temperature dependence of Eq. (2.7). It is apparent that test element temperature results would be very sensitive to whether or not one or two cavities activate consistently in separate runs.

Since T_w remains constant until the inception of boiling, superheat increases with decreasing pressure until conditions for boiling are achieved. Once boiling begins, the heater cools, with the amount of cooling determined by the size and density of active sites. During the pressure transient, the cooling tends to offset the decrease in $p_v(T_s)$, thus restricting the activation of other nucleation sites.

After the decompression ends, a larger site rendered inactive by the pressure-temperature history experienced prior to the pressure transient could be activated in two ways. Vapor microbubbles created in the collapse of macroscopic bubbles in subcooled liquid could migrate from an adjacent active site and seed the cavity (33-36). If the cavity has vapor trapped at its base, activation could be accomplished either by vapor migration or by achievement of a sufficiently large local superheat to overcome the effects of pre-pressurization. Once the barrier to nucleation were breached, the cavity would remain active.

The temperature of the platinum wire test element was calculated using its resistance at 0°C (see Section 4.2). Based on measurements of the resistance at 100°C, the wire resistance at 0°C was $R_0 = 0.1961 \pm 0.0021$. This led to an uncertainty of ± 2.9 K in the value of the calculated wire temperature T_w . This was a systematic error that adds to the uncertainty in boiling initiation conditions beyond that reported in Table 6.1.

The system pressure during the decompression was calculated using the recorded value of the pressure at the initiation of the event. The error in this measurement, including the $\pm 0.25\%$ accuracy of the pressure gauge, was estimated to be ± 3.4 kPa. In addition, the pressure transducer had a linearity of $\pm 1.0\%$ (based on the manufacturer's performance data), and the dual mode amplifier had a range accuracy of $\pm 1\%$. The combination of these sources of error led to an uncertainty in the pressure measurement of approximately $\pm 8-9$ kPa, dependent upon the magnitude of the pressure drop recorded. This error also adds to the uncertainty in boiling conditions beyond that reported in Table 6.1.

6.5 Conclusions

Although this study did not allow a quantitative comparison of results to prediction based on Fabic's theory, the results did show a clear effect of the pressure-temperature history on the initiation of boiling during pressure transients. Increasing the initial pressure tended to delay the inception of boiling, showing that lower pressures and higher superheats were necessary to initiate boiling. Since smaller cavities require greater superheat to nucleate, this is consistent with predictions that the size of the largest potential nucleation site becomes progressively smaller as greater overpressures are applied. That boiling occurred in cases where none was predicted indicates that a simple time-independent theory using constant contact angles is inadequate.

7. SUGGESTIONS FOR FURTHER STUDY

A more comprehensive study of the pressure and temperature effects on boiling initiation during pressure transients needs to be performed, with a wide range of conditions and different heater geometries. Certain changes are recommended to improve the validity and efficiency of such a study.

The test heater power supply should be upgraded with additional deep-cycle storage batteries. This would improve stability and allow application of greater power levels. More stable power supplies to provide biasing voltages are also necessary to enhance the resolution of the small voltage variations associated with this study.

An electro-acoustical device should be used in an independent method for detecting the onset of nucleate boiling. The visual technique employed in this study was hampered by a limited field of vision and reaction times. Visual detection also becomes increasingly unreliable as pressure reduction periods decrease.

A much more sensitive pressure transducer should be installed. This would greatly improve the response of the pressure measurement system and minimize amplifier drift problems.

A four-channel recording digital oscilloscope and a captive computer system are also recommended. With a four-channel oscilloscope, all pertinent data for each experimental run could be recorded, and the reproducibility of the pressure transient would not be a major concern. A captive computer system would greatly improve the efficiency of the study, allowing each test to be analyzed during preparation for a subsequent experiment. Additionally, near immediate feedback of the effects of changes in test conditions would be available.

Finally, a study of decompression with heater temperature held constant needs to be performed, as well as an investigation of the effect of temperature on advancing and receding contact angles. These two subjects need to be addressed in order to develop a general model for boiling behavior during transient condition.

8. REFERENCES

1. Fabic, S., "Vapor nucleation on surfaces subjected to transient heating," Ph.D. Dissertation, Nuclear Engineering Department, University of California, Berkeley, 1964.
2. Winterton, R. H. S., "Nucleation of boiling and cavitation," *J. Phys. D: Appl. Phys.*, 10, 2041-2056 (1977).
3. Weisman, J., G. Bussell, and T. Hsieh, "The initiation of boiling during pressure transients," *J. Heat Transfer*, Nov. 1974, pp. 535-555.
4. Gallagher, J. P. and R. H. S. Winterton, "Effect of pressure on boiling nucleation," *J. Phys. D: Appl. Phys.*, 16 L57-L61 (1983).
5. Sakurai, A., M. Shiotsu, and K. Hata, "Transient boiling caused by rapid depressurization from initial nonboiling state," 2d Multi-Phase Flow and Heat Transfer Symposium-Workshop, Miami Beach, Florida, 16-18 April 1979.
6. Churchill, S. W. and H. H. Chu, "Correlating equations for laminar and turbulent free convection from a horizontal cylinder," *Int. J. Heat Mass Transfer*, 18, 1049-1053 (1975).
7. Morgan, Vincent T., "The overall convective heat transfer from smooth circular cylinders," in *Advances in Heat Transfer*, Vol. 11, T. F. Irvine, Jr., & J. P. Hartnett (eds.), Academic Press, New York, 1975.
8. Fujii, T., M. Fujii, and T. Honda, "Theoretical and experimental studies of the free convection around a long horizontal thin wire in air," *Heat Transfer 1982*, Vol II, Seventh International Heat Transfer Conference, Munich, 1982, Paper NC32, pp. 311-316.
9. Griffith, Peter, and John D. Wallis, "The role of surface conditions in nucleate boiling," *Chemical Engineering Progress Symposium Series*, vol. 55, No. 30, 49-63 (1960).
10. Hsu, Y. Y., "On the size range of active nucleation cavities on a heating surface," *J. Heat Trans.*, 84, 207-216 (1962).
11. Bergles, A. E., and W. M. Rohsenow, "The determination of forced-convection surface boiling heat transfer," *J. Heat Transfer*, 86, 365-372 (1964).
12. Han, C-Y, and Peter Griffith, "The mechanism of heat transfer in nucleate pool boiling - Part I, bubble initiation, growth, and departure," *Int. J. Heat Mass Transfer*, 8, 887-904 (1965).
13. Madejski, J., "Activation of nucleation cavities on a heating surface with temperature gradient in a superheated liquid," *Int. J. Heat Mass Transfer*, 9, 295-300 (1966).

14. Schmidt, R. J., and R. Cole, "Comments on activation of nucleation cavities on a heating surface with temperature gradient in a superheated liquid," *Int. J. Heat Mass Transfer*, 13, 443-445 (1970).
15. Schultz, R. R., S. Kasturirangan, and R. Cole, "Experimental studies of incipient vapor nucleation," *Can. J. Chem. Eng.*, 53, 408-413 (1975).
16. Schultz, R. R., and Robert Cole, "Initial bubble growth in slightly subcooled transient boiling," *AICHE Symposium Series, Heat Transfer - Orlando 1980*, vol. 76, Paper 199, pp. 310-317.
17. Sakurai, A, and M. Shiotsu, "Transient pool boiling heat transfer. Part 1: Incipient boiling superheat," *J. Heat Transfer*, 99, 547-553 (1977).
18. Cole, Robert, "Nucleate boiling heat transfer, a general survey," in *Boiling Phenomena*, Vol I, S. van Stralen and R. Cole (eds.), Hemisphere, New York, 1979, pp. 155-193.
19. Tolubinskiy, V. I., A. M. Kichigin, and S. G. Povsten, "Generalized equation for critical heat fluxes in free-convection boiling of liquids," *Heat Transfer - Soviet Research*, 8, No. 3, 23-31 (1976).
20. Tolubinskiy, V. I., Y. N. Ostrovskiy, and V. Y. Pisarev, "Transient heat transfer with phase transitions," *Heat Transfer - Soviet Research*, 11, No. 1, 18-23 (1979).
21. Johnson, H. A., "Transient boiling heat transfer to water," *Int. J. Heat Mass Trans.*, 14, 67-82 (1971).
22. Faw, R. E. and R. J. VanVleet, "Initiation of subcooled pool boiling during pressure and power transients," Report 161, Kansas Engineering Experiment Station, Manhattan, Kansas, 1984.
23. Howell, John R. and Kenneth J. Bell, "An experimental investigation of the effect of pressure transients on pool boiling burnout," *Heat Transfer - Houston, Chem. Eng. Progr., Symp. Ser.*, 59, 88-95.
24. Aoki, S., A. Inoue, and Y. Kozawa, "Transient boiling crisis during rapid depressurization," Proc. 5th International Heat Transfer Conference, 1974, Paper B6.3.
25. Kung, S., "Boiling heat transfer and bubble growth dynamics during rapid decompression," Ph.D. Dissertation, Nuclear Engineering Department, Kansas State University, Manhattan, Kansas, 1980.
26. Hooper, F. C. and A. H. Abdelmessih, "The flashing of liquids at higher superheats," *Heat Transfer 1966*, Proc. 3rd Int. Heat Transfer Conf., Chicago, 1966, Vol. 4, pp. 44-50.

27. Kenning, D. B. R. and K. Thirunavukkarasu, "Bubble nucleation following a sudden pressure reduction in water," Heat Transfer 1970, Proc. 4th Int. Heat Transfer Conf., Paris-Versailles, 1970, Vol. V, Paper B2.9.
28. Lienhard, J. H., Md. Alamgir, and M. Trela, "Early response of hot water to sudden release from high pressure," J. Heat Transfer, Trans. ASME, 100, 473-479 (1978).
29. Alamgir, Md., C. Y. Kan, and J. H. Leinhard, "An experimental study of the rapid depressurization of hot water," J. Heat Transfer 102, 433-438 (1980).
30. Rohsenow, W. M., "A method of correlating heat-transfer data for surface boiling," ASME Trans., 74, 969-976 (1952).
31. Stephan, K., and M. Abdelsalam, "Heat-transfer correlations for natural convection boiling," Int. J. Heat Mass Transfer, 23, 73-87 (1980).
32. Vines, R. F., The platinum metals and their alloys, International Nickel Co., New York, 1941.
33. Mesler, Russel, "Bubble nucleation," in Encyclopedia of Fluid Mechanics, N. P. Cheremisinoff (ed.), Gulf Publishing (in press).
34. Mesler, Russell and Gregory Mailen, "Nucleate boiling in thin films," AIChE Journal, 23, 954-957 (1977).
35. Bergman, Theodore, and Russell Mesler, "Bubble nucleation studies, Part I: Formation of bubble nuclei in superheated water by bursting bubbles," AIChE Journal, 27, 851-853 (1981).
36. Carroll, Kenneth, and Russell Mesler, "Splashing liquid drops form vortex rings and not jets at low Froude numbers," J. Appl. Phys., 52(1), 507 (1981).

APPENDIX A

Program BOIL: Temperature Data Analysis

This program was written in Hewlett-Packard BASIC, Version 2.0, and run on the HP 9816 microcomputer. The program was originally written for analysis of power transient data from a concurrent study (22), and this capability is retained in the current version. In fact, the program parameters default to the power transient values, and changes in these values arising from choosing the pressure transient option are contained in the voltage input data set.

The voltage data for an experimental run are measured by a Nicolet Explorer III digital oscilloscope. The voltage input is converted to a corresponding channel number and stored. The channel number is obtained by dividing the sampled voltage by the conversion factor

$$V_{\text{norm}} = \{\text{Voltage Range}\}/2000 \quad \text{Volts/channel.}$$

There are 4096 voltage channels (-2048 to +2047), which allows a full scale voltage interval greater than -VR to +VR, where VR is the oscilloscope voltage range setting. There are also 4096 memory addresses available. Channel numbers are stored sequentially at a time interval determined by the Time Per Point switch. If both input channels A and B are active, the signals are stored in the sequence ABABAB, and the time interval defines the time between each sampling of the pair AB. Thus, the channel number defines the voltage and the memory address defines the time at which the voltage was sampled.

Voltage data is originally input to the program from the oscilloscope. The data is also saved on a disk for reference. The information required from each run depends on the case considered, i.e.,

transient power or transient pressure. The former is always performed in Normal Trigger mode on the oscilloscope, so the first datum is at time zero, while the latter is always performed in the Cursor Trigger mode. In this configuration the first datum time and the event initiation time must be recorded, as well as certain equipment settings. These values are stored as the first nine points in the data file when it is saved on the disk.

The program separates the raw voltage data into the two input signals, converts the data to true voltages, and then averages the data. The voltage is found from the expression

$$V = \{\text{Channel number}\} \frac{V_{\text{norm}}}{\text{Amp}} - V_{cz} + V_o,$$

where Amp is the signal amplification, V_{cz} is the zero input voltage level for the oscilloscope, and V_o is the biasing voltage. The biasing voltage is subtracted from the signal before it is amplified and sent to the oscilloscope to permit greater precision in the measurement of the small voltage changes associated with this case. The voltages are smoothed over n points, and the averaged voltage is assigned the averaged time value. Smoothing intervals are exclusive, i.e., no datum is used more than once in the averaging process.

Program output is available in an ASCII file for hardcopy printout or in binary data files for plotting the results.

```

1      ***** SOIL *****
2
3      ** PROGRAM CONVERTS VOLTAGE DATA MEASURED ACROSS A PLATINUM WIRE   **
4      ** AND A STANDARD RESISTOR TO A TEMPERATURE HISTORY OF THE WIRE.    **
5      ** VOLTAGE DATA IS ORIGINALLY INPUT FROM THE NICOLET DIGITAL        **
6      ** OSCILLOSCOPE, BUT THESE DATA ARE ALSO STORED ON A DISC FOR        **
7      ** FUTURE REFERENCE. FROM THE TEMPERATURE DATA THE WIRE             **
8      ** SUPERHEAT, THE SUPERFICIAL HEAT FLUX AND THE MODIFIED             **
9      ** NUSSELT NUMBER HISTORIES ARE DETERMINED.                         **
10
11      ** PROGRAM WILL ANALYZE FOR TWO CASES: a) POWER TRANSIENTS AT      **
12      ** CONSTANT PRESSURE, and b) PRESSURE TRANSIENTS AT CONSTANT        **
13      ** POWER. THE DISTINCTION IS: a) NORMAL TRIGGER OF D-SCOPE,          **
14      ** and b) CURSOR TRIGGER OF D-SCOPE.                                **
15
16
17      ** R.VANVLEET                               KSU NOV 1983  **
18
19      ** revised for Case b and improved efficiency by                   **
20
21      ** O.SCHMIDT                                KSU SEP 1984  **
22
23      ** update: "quick & dirty" plot (O.SCHMIDT)  KSU JAN 1985  **
24
25
26
270 OPTION BASE 1
280 COM /Array/ Raw#4096!,A1S12!,B1S12!,E(S12),Z(S12,4)
290 COM /Const/ Alpha,Beta,Ubeg,Tcnd
300 COM /Datum/ Di,Len,Ra,Ps,Ta,Tau,T0,Va0,Vb0,Vcz1,Vcz2,Vnorm,P$(35)
310 COM /Stat/ Amp,Mode,Nav,Nblock,Sigma
320 DIM Title#(80)
330
340 PRINT CHR$(12)
350 INPUT "RESET GRAPHICS (Y/N) ? ",Reset$
360 INPUT "WHAT IS THE RUN NUMBER, e.g., RUN ???? ",Title$
370 Titles$="RUN NUMBER "+Title$
380 PRINT Title$
390
400      ! MAIN PROGRAM
410
420      CALL Param
430      CALL Inpt(N$)
440      Tscale=Tau42#90
450      IF Reset$="Y" THEN CALL Graf_set(Tscale)
460      PRINT Title$, " ", " ", "SOURCE DATA FILE: ",N$,
470      PRINT
480      PRINT "AVERAGING DATA --> ";Nav; " PBINT AVERAGING"
490      CALL Avg
500      PRINT "CALCULATING INITIAL WIRE RESISTANCE"
510      CALL Resis
520      PRINT "CALCULATING PROPERTIES"
530      CALL Prop
540      CALL Outp(N$,Title$)
550
560 END
570
580
590 SUB Param
600   COM /Const/ Alpha,Beta,Ubeg,Tcnd
610   COM /Datum/ Di,Len,Ra,Ps,Ta,Tau,T0,Va0,Vb0,Vcz1,Vcz2,Vnorm,P$,
620   COM /Stat/ Amp,Mode,Nav,Nblock,Sigma
630
640      ! DATA FOR THE WIRE, THE FLUID, AND THE SETTINGS ON THE SCOPE
650      ! DEFAULT FOR CONSTANT PRESSURE RUNS
660
670      Ra=.2394+.00293           ! STANDARD RESISTANCE
680      Di=.25E-4                 ! WIRE DIAMETER
690      Len=9.6E-2                ! WIRE LENGTH
700
710      Alpha=.09392
720      Beta=.5,3E-7
730      Tcnd=.674                  ! MEAN VALUE 70 TO 200 C IS .674 IN WATER COND
740

```

```

590 Vnora=.002           : 4V RANGE ON O-SCOPE
600 Vcz1=-4,             : ZERO INPUT VOLTAGE LEVEL
610 Vcz2=4,
620 Va0=0,               : BUCKING VOLTAGE
630 Vb0=0,
640 :
650 Obeg=0,
660 Mode=1
670 Aap=.1,
680 Nav=16
690 SUBEND
700 :
710 :
720 :
730 SUB Inpt(N$)
740 OPTION BASE 1
750 COM /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
760 COM /Const/ Alph,Beta,Obeg,Icnd
770 COM /Oatum/ Di,Len,Ra,Rs,Ta,Tau,T0,Va0,Vb0,Vcz1,Vcz2,Vnora,P$
780 COM /Stat/ Aap,Mode,Nav,Mblock,Sigma
790 DIM Raw$(4096){5}
800 :
810 INPUT "DATA SOURCE --- SCOPE = 1, BOAT FILE = 2",Tt
820 IF Tt=1 THEN
830   PRINT
840   PRINT "TRIGGER MODE --- NORMAL = 1, CURSOR = 2"
850   INPUT "(NORMAL if constant pressure run)      ",Mode
860 END IF
870   CALL Reader(Tt,N$,Raw$(1))
880 IF Raw$(1)="CURSR" THEN Mode=2
890 IF Mode<2 THEN Raw$(1)=VAL(Raw$(1))
900 FOR I=2 TO 4096
910   Raw$(I)=VAL(Raw$(I))
920 NEXT I
930 IF Mode=1 THEN I040
940   Vnor=Raw(2)
950   Ch0=Raw(3)
960   Tau=Raw(4)
970   Vcz1=Raw(5)/1000
980   Vcz2=Raw(6)/1000
990   Aap=Raw(7)
1000  Va0=Raw(8)
1010  Vb0=Raw(9)
1020  Reserv=16
1030  Pg=""
1040 BEEP 2[97.26,.3
1050 INPUT "ENTER AMBIENT TEMPERATURE (C)",Ta
1060 INPUT "ENTER INITIAL WIRE TEMPERATURE (C)",T0
1070 IF Mode=2 THEN GOTO I110
1080   INPUT "ENTER AMBIENT PRESSURE, e.g. 101.4,475.8,[397.8 (kPa)],P$"
1090   INPUT "ENTER INITIAL HEAT FLUX ON THE WIRE (W/m^2)",Obeg
1100   INPUT "ENTER SAMPLING TIME INCREMENT, E.G. 1E-2 FOR 20 SEC RUN",Tau
1110   INPUT "ENTER [4,8,16] POINT RUNNING AVERAGE (DEFAULT = 16)",Nav
1120 IF Mode<1 THEN I250
1130 INPUT "ENTER MAXIMUM PRESSURE",Pmax
1140 INPUT "ENTER STARTING PRESSURE FOR DECOMPRESSION",Pstart
1150 INPUT "UNITS OF VALUES JUST ENTERED --- K = kPa, P = psig",Unit#
1160 IF Unit#="" THEN I210
1170   Conv=((Pstart/14.696)+1)*101.325
1180   Pmax=ROUND(Conv,5)
1190   Conv=((Pstart/14.696)+1)*101.325
1200   Pstart=ROUND(Conv,5)
1210   IF Pstart>Pmax THEN Pg="Max "&VAL$(Pmax)&" , "
1220   Pg=Pg;"Decompress from "&VAL$(Pstart)
1230   Neg=INT((Ch0-1-Reserv)/Nav/2)      ! ALLOWS CALCULATIONS FOR TIME<0
1240   Raw$(1)=Ch0-Nav*Neg                ! START CHANNEL
1250   Nch=(4096-(Raw$(1)-1))/2
1260   Mblock=INT(Nch/Nav)
1270   PRINT CHR$(12)
1280   PRINT Raw$(1),Raw(2),Raw(3),Raw(4),Raw(5),Raw(6),Raw(7),Raw(8)
1290   PRINT
1300 SUBEND

```

```

1310 :
1320 :
1330 :
1340 SUB Reader(Tt,Name$,Raw$(#))
1350   OPTION BASE 1
1360   COM /Stat/ Acp,Mode,Nev,Nblock,Sigma
1370 :
1380   PRINT
1390   PRINT "PLEASE INSERT DATA DISC INTO DISC DRIVE 0"
1400   INPUT "PLEASE ENTER A UNIQUE NAME FOR THE BOAT FILE.",Name$
1410   DISP "WORKING, PLEASE WAIT."
1420   MASS STORAGE IS "HPB2901,700,0"
1430   IF Tt=2 THEN 1650
1440 :
1450   ASSIGN PScope TO 9
1460   CONTROL 9,3;9600
1470   ASSIGN PScope;FORMAT ON
1480   CONTROL 9,5;3
1490   CONTROL 9,4;2
1500   OUTPUT PScope;CHR$(1);
1510   OUTPUT PScope;CHR$(69);CHR$(48);CHR$(68);CHR$(49);CHR$(68);CHR$(48);
1520   OUTPUT PScope;CHR$(79);CHR$(52);CHR$(48);CHR$(57);CHR$(54)
1530   OUTPUT PScope;CHR$(2);
1540   ENTER PScope USING "5A,X,I";Raw$(#)
1550   CONTROL 9,3;0
1560   ASSIGN PScope TO 9
1570     IF Mode2 THEN CALL Scope_Set(Raw$(#))
1580   0ISP "WORKING, PLEASE WAIT."
1590   CREATE BOAT Name$,40%;5
1600   ASSIGN #Path TO Name$
1610   OUTPUT #Path USING "5A";Raw$(#)
1620   ASSIGN #Path TO #
1630   SUBEXIT
1640 :
1650   ASSIGN #Path TO Name$
1660   ENTER #Path USING "5A";Raw$(#)
1670   ASSIGN #Path TO #
1680   SUBEND
1690 :
1700 :
1710 :
1720 SUB Scope_Set(Raw$(#))
1730   OPTION BASE 1
1740   BEEP 1627.60,.3
1750   INPUT "ENTER TIME FOR FIRST DATA POINT (sec)",Chito
1760   INPUT "ENTER TIME OF EVENT INITIATION (sec)",Event0
1770   INPUT "ENTER TIME INCREMENT, e.g. 1E-2 FOR A 20 s RUN ",Tau
1780   INPUT "ENTER VOLTAGE RANGE (V)",Range
1790   INPUT "ENTER DC LEVEL ZERO FOR CHANNEL A (V)",Vca
1800   INPUT "ENTER DC LEVEL ZERO FOR CHANNEL B (V)",Vcb
1810   INPUT "ENTER BUCKING VOLTAGE FOR CHANNEL A (V)",Va0
1820   INPUT "ENTER BUCKING VOLTAGE FOR CHANNEL B (V)",Vb0
1830   INPUT "ENTER SIGNAL AMPLIFICATION OF ANALOG COMPUTER",Acp
1840 :
1850   Raw$(1) = "CURSR"
1860   Raw$(2) = VAL$(Range/2000)           : Vnorm
1870   Ch0 = (ABS(Ch1$0)-ABS(Event0))/2/Tau+1
1880   Raw$(3) = VAL$(Ch0)
1890   Raw$(4) = VAL$(Tau)
1900   Raw$(5) = VAL$(Vca#1000)           : Vcz1
1910   Raw$(6) = VAL$(Vcb#1000)           : Vcz2
1920   Raw$(7) = VAL$(Acp)
1930   Raw$(8) = VAL$(Va0)
1940   Raw$(9) = VAL$(ABS(Vb0))
1950   SUBEND
1960 :
1970 :
1980 :

```

```

1990 SUB Avg
2000   OPTION BASE 1
2010   COM /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
2020   COM /Datum/ D1,Lem,Ra,Rs,Ta,T0,Va0,Vb0,Vcz1,Vcz2,Vnora,Pb
2030   COM /Stat/ Amp,Node,Nav,Mblock,Sigma
2040 !
2050 ! THIS SUBROUTINE SEPARATES THE DATA FOR THE STANDARD RESISTOR
2060 ! PLUS THE WIRE (A(1)) AND THE WIRE (B(1)) AND CALCULATES
2070 ! THEIR RUNNING AVERAGES
2080 !
2090 IF Mode=2 THEN Cstart=Raw(10)-1
2100 Jstart=Cstart+1
2110 FOR I=1 TO Nbblock
2120   Sumx=0
2130   Sumy=0
2140   Jend=Jstart+2#Nav-1
2150   FOR J=Jstart TO Jend-1 STEP 2
2160     Sumx=Sumx+Raw(J)*Vnora/Amp ! CONVERT TO TRUE VOLTAGE
2170     Sumy=Sumy+Raw(J+1)*Vnora/Amp ! AND AVERAGE
2180   NEXT J
2190   A(1)=Sumx/Nav-Vcz1/Amp+Va0 ! SUBTRACT ZERO LEVEL AND
2200   B(1)=Sumy/Nav-Vcz2/Amp+Vb0 ! ADD BUCKING VOLTAGES
2210   Jstart=Jend+1
2220   MEET 1
2230 SUBEND
2240 !
2250 !
2260 !
2270 SUB Resist
2280   OPTION BASE 1
2290   COM /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
2300   COM /Datum/ D1,Lem,Ra,Rs,Ta,T0,Va0,Vb0,Vcz1,Vcz2,Vnora,Pb
2310   COM /Stat/ Amp,Mode,Nav,Mblock,Sigma
2320 !
2330 ! THIS SUBROUTINE CALCULATES THE INITIAL RESISTANCE OF THE WIRE
2340 !
2350 IF Mode<2 THEN GOTO 2390
2360 Ra=Vb0/Va0*Rs-.00277 ! FOR INITIAL FLUX ON WIRE
2370 SUBEIT
2380 !
2390   Sumx=0 ! NO INITIAL FLUX, USE LEAST SQUARES FIT
2400   Sumx2=0
2410   Sumy=0
2420   Sumy2=0
2430   Sumxy=0
2440   Zz=10
2450 FOR I=3 TO 12
2460   J1=(I-.5)*Nav ! TIME
2470   Ra=.5(I)*Rs/A(1)-.00277
2480   Time=J1*.25 ! EMPIRICAL ADJUSTMENT FOR BETTER FIT
2490   Sumx=Sumx+Time
2500   Sumx2=Sumx2+Time^2
2510   Sumy=Sumy+R
2520   Sumy2=Sumy2+R^2
2530   Sumxy=Sumxy+Time*R
2540 MEET 1
2550   Beta0=(Sumy-(Sumx*Sumy)/Zz)/(Sumx2-(Sumx^2)/Zz)
2560   Beta0=(Sumy/Zz)-Beta0*(Sumx/Zz)
2570   S=Sumx2-(Sumx^2)/Zz
2580   T=Sumy2-(Sumy^2)/Zz
2590   U=1./((Zz-1.)
2600   V=Beta0*Zz
2610   W=U*(S-VT) ! VARIANCE ABOUT REGRESSION
2620   Sigma=SQR(W#Sumx2/Zz/T) ! EST OF STD DEV OF INTERCEPT
2630   Ra=Beta0
2640 !
2650 BEEP 2197.26,.3
2660 PRINT " ;RA = ";Ra;" AT ";T0;" C"
2670 NewRa
2680 INPUT "Enter new value for RA or accept default",New
2690 IF NewRa THEN 2720
2700 PRINT "!!! NEW VALUE !!!";RA = " ;New;"AT ";T0;" C"
2710 Ra=New
2720 SUBEND

```

```

2730 !
2740 !
2750 !
2760 SUB Preps
2770   OPTION BASE 1
2780   CON /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
2790   CON /Const/ Alph,Beta,Qbeg,Tcnd
2800   CON /Datum/ 0t,Len,Ra,Rs,Ta,Tb,Vb0,Vc1,Vc2,Vmrc,P
2810   CON /Stat/ Aep,Mode,Nav,Mblock,Sigmas
2820 !
2830   THIS SUBROUTINE CALCULATES THE PROPERTIES OF THE WIRE:
2840 !
2850   Z(1,1) = TIME
2860   Z(1,2) = SUPERFICIAL HEAT FLUX
2870   Z(1,3) = THETA [ T(wire) - T(ambient) ]
2880   Z(1,4) = MODIFIED NUSSELT NUMBER
2890 !
2900   Const=Rai/(E+Alph*T0+Beta*T0^2) ! R(wire) AT T=0 C
2910   IF Mode=1 THEN 2990
2920     Neg=INT((Raw(5)-Raw(10))/Max/2)
2930     PRINT " ", "WIRE PROPERTY : ", "R(wire) [ AT T=0 C ] = ";Const
2940     New=Const
2950     INPUT "Enter new value for R(wire) or accept default",New
2960     IF New>Const THEN 2990
2970     PRINT " ## NEW VALUE ####", "R(wire) [ AT T=0 C ] = ";New
2980     Const=New
2990   End=Alph/Beta
3000   Ra=-.5*End
3010   Ra=.5*End
3020   FOR I=1 TO Mblock
3030     Z(1,1)=TauNavav(I-Neg-.5)
3040     Z(1,2)=A(I)*B(I)/(I-B(I)/(I-.00277/Rs)/(Rs*.14159161*Len)-Qbeg
3050     Ra=B(I)/(Ra*(I-.00277
3060     F=Ra^2*(A/.Beta)/(R/Const-1.)
3070     Z(1,3)=Ra-.5*QR(F)-Fa
3080     Z(1,4)=Z(1,2)*Ra/(Tcnd#Z(1,3))
3090   !
3100   Er1=(Vmrc^2)/(A11)^2
3110   Er2=(Vmrc^2)/(B11)^2
3120   Er3=(Sigmas^2)/(Ra^2)
3130   E11=(Er1+Er2*Er3)/((1-(Ra/R))^2)
3140   NEXT I
3150 SUBEND
3160 !
3170 !
3180 !
3190 SUB Outa(N$,Title$)
3200   OPTION BASE 1
3210   CON /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
3220   CON /Datum/ 0t,Len,Ra,Rs,Ta,Tb,Vb0,Vc1,Vc2,Vmrc,P
3230   CON /Stat/ Aep,Mode,Nav,Mblock,Sigmas
3240   DIM Add#16$,He1#16$,He2#16$,He3#16$,Inb#17$,Pre#16$,Pi#16$,R1#16$
3250   DIM St#16$,St#16$,T1#16$,W1#16$,W2#16$,Out#13$,Out#13$,Z#14$,I10$
3260 !
3270   Nbg=INT(Mblock/47) ! INFORMATION ABOUT FILE SIZE
3280   Nx=Mblock-Nbg#47
3290   IF Nx#42 THEN Mblock=Mblock-(Nx-42)
3300   IF Nx#0 THEN Nbg=Nbg-1
3310   Nbg=Mbg+1
3320   Size=19#Nbg
3330   ALLOCATE G(Mblock,2) ! "QUICK & DIRTY" PLOT
3340   Abs=3
3350   Ord=2 ! - HEAT FLUX v THETA if PRESSURE = const
3360   IF Mode=2 THEN Abs=1 ! - THETA v TIME if HEAT FLUX = const
3370   IF Mode=2 THEN Ord=3
3380   FOR I=1 TO Mblock
3390     G(I,1)=Z(I,Abs)
3400     G(I,2)=Z(I,Ord)
3410   NEXT I
3420 !
3430   BEEP 1627.60,.3
3440   PRIMF CHR$(12)
3450   CALL Scr_Plot(B(1))
3460   DEALLOCATE G(I)

```

```

3470
3480 INPUT "Do you wish to have a HARD COPY of the numbers ? ( Y/N )?",Ans$
3490 IF Ans$("Y") THEN 460
3500 PRINT Title$, " ", " ", "SOURCE DATA FILE: ";N$
3510 PRINT
3520 PRINT "***** PLEASE INSERT A DISC INTO DISC DRIVE 1"
3530 PRINT
3540 PRINT "AN ASCII FILE WILL BE CREATED ON THE DISC. THIS FILE CAN THEN"
3550 PRINT "BE TRANSFERRED TO THE MAIN COMPUTER FOR PRINT OUT."
3560 INPUT "PLEASE ENTER A UNIQUE NAME FOR THE ASCII FILE.",Ans$
3570
3580 PreS=*
3590 Add$=*
3600 Inb$=*
3600 Sts=*
3610 He1$=*
3610 He1$ TIME HEAT FLUX THETA MUSSETT*
3620 He2$=*
3620 He2$ (s) (W/m²) (C) NUMBER*
3630 He3$=*
3630 He3$ PAGE *
3640
3650 Ra$=VAL$(Ra$)
3650 Ra$=Ra$(1,7)
3660 P1$=Add$;"PRESSURE" = "MPa" kPa"
3670 R1$=Add$;"INITIAL RESIS. = "R$" OHMS AT "VAL$(T0)$" C"
3680 Sigma$=VAL$(Sigma)
3690 Sigma$=Sigma$(1,7)
3700 S1$=Add$;"SIGMA" = "%Sigma"
3710 T1$=Add$;"AMBIENT TEMP. = "VAL$(Ta)$" C"
3720 W1$=Add$;"WIRE LENGTH = "VAL$(Len1)$" m"
3730 N2$=Add$;"WIRE DIAMETER = "VAL$(D1)$" m"
3740 Np$=I
3750 Lin=1
3760 MASS STORAGE IS ":HPB2901,700,1"
3770 CREATE ASCII As$,Size
3780 ASSIGN #Path TO As$
3790 OUTPUT #Path;Add$;Title$,Inb$,W1$,N2$
3800 OUTPUT #Path;T1$,Inb$,St$,Inb$,He1$
3810 OUTPUT #Path;S1$,Inb$,St$,Inb$,He1$
3820 OUTPUT #Path;He2$,Inb$,St$,Inb$
3830 FOR I=1 TO Nblock STEP 3
3840 CALL Dec(I,2$(4))
3850 Out$(1)=Pre$2$(1)&Inb$&Z$(2)&Inb$&Z$(3)&Inb$&Z$(4)
3860 IF I<(Nblock THEN CALL Dec(I+2,2$(4))
3870 Out$(2)=Pre$2$(1)&Inb$&Z$(2)&Inb$&Z$(3)&Inb$&Z$(4)
3880 IF I+2=>Nblock THEN Call Dec(1,2$(4))
3890 Out$(3)=Pre$2$(1)&Inb$&Z$(2)&Inb$&Z$(3)&Inb$&Z$(4)
3900 IF (I+1)>Nblock THEN Out$(2)=Add$;
3910 IF (I+2)>Nblock THEN Out$(3)=Add$;
3920 OUTPUT #Path;Out$(1),Out$(2),Out$(3)
3930 Lin=Lin+1
3940 IF Np$=I AND Lin=15 THEN GOTO 3960
3950 IF Lin=17 THEN
3960   OUTPUT #Path;Inb$,Inb$,Inb$,Inb$,Inb$,Inb$,Inb$,Inb$;
3970   T1$=Add$;Title$&He3$&VAL$(Np$+1)
3980   OUTPUT #Path;T1$,Inb$,St$,Inb$
3990   OUTPUT #Path;He1$,He2$,Inb$,St$,Inb$,Inb$
4000 Lin=1
4010 Np$=Np$+1
4020 END IF
4030 NETT 1
4040 MASS STORAGE IS ":HPB2901,700,0"
4050 DEEP 1302.08,.3
4060
4070 INPUT "Do you wish to have a PLOT of the numbers (Y/N) ?",Ans$
4080 IF Ans$("Y") THEN 4610
4090 PRINT CHR$(12)
4100 PRINT Title$, " ", " ", "SOURCE DATA FILE: ";N$
4110 PRINT
4120 PRINT "***** PLEASE INSERT A DISC INTO DISC DRIVE 1"
4130 PRINT
4140 PRINT "BOAT FILES WILL BE CREATED ON THE DISC. THESE FILES CAN THEN"
4150 PRINT "BE PLOTTED USING THE GENERAL PLOTTING PROGRAM"
4160 PRINT

```

```

4170 PRINT "THE TYPE OF PLOTS POSSIBLE ARE:"
4180 PRINT
4190 PRINT "      1 = NUSSELT NUMBER vs TIME"
4200 PRINT "      2 = HEAT FLUX vs THETA"
4210 PRINT "      3 = BOTH PLOTS 1 AND 2 (plot 1 recorded first)"
4220 PRINT "      4 = HEAT FLUX vs TIME"
4230 PRINT "      5 = THETA vs TIME"
4240 PRINT "      6 = BOTH PLOTS 4 AND 5 (plot 4 recorded first)"
4250 INPUT "CHOOSE THE TYPE OF PLOT YOU WISH.",Bq
4260 IF Mode=1 THEN CALL Man1
4270 FOR #1$="M1.000E,1"
4280 ALLOCATE G1#block,2)
4290 MASS STORAGE IS ":HPB2901,700,1"
4300 IF Bq=1 OR Bq=3 THEN 4340
4310 IF Bq=2 THEN 4370
4320 IF Bq=4 OR Bq=6 THEN 4400
4330 IF Bq=5 THEN 4430
4340 Abs=1
4350 Ord=4
4360 GOTO 4460
4370 Abs=3
4380 Ord=2
4390 GOTO 4460
4400 Abs=1
4410 Ord=2
4420 GOTO 4460
4430 Abs=1
4440 Ord=3
4450 :
4460 INPUT "PLEASE ENTER A UNIQUE NAME FOR THE BOAT FILE.",Bd$
4470 FOR D=1 TO Nblock
4480   G1(D,1)=I(0,Abs)
4490   G1(D,2)=Z(0,Ord)
4500 NEXT D
4510 CREATE BOAT Bd$, (2*Nblock),9
4520 ASSIGN PPath TO Bd$
4530 OUTPUT PPath USING Format$;G1()
4540 ASSIGN PPath TO I
4550 PRINT
4560 PRINT "BOAT file: ";Bd$,"Nblock";" points","Data format: M1.000E"
4570 IF Bq=3 THEN 4370
4580 IF Bq=6 THEN 4430
4590 DEALLOCATE G(1)
4600 MASS STORAGE IS ":HPB2901,700,0"
4610 BEEP $126.94,,1
4620 PRINT "      END"
4630 SUBEND
4640 :
4650 :
4660 :
4670 SUB Dec(I,Z$(I))
4680   OPTION BASE 1
4690   COM /Array/ Raw(4096),A(512),B(512),E(512),Z(512,4)
4700 :
4710 : THIS SUBROUTINE ENSURES THAT ALL VALUES HAVE THE
4720 : CORRECT FIELD LENGTH FOR OUTPUT
4730 :
4740 Long=5
4750 DecI=0#
4760 Per9="."
4770 FOR J=1 TO 4
4780   Zz=Z(J,J)
4790   IF Zz<0 THEN Zz=$VAL$(!DROUND(FNRound(Zz,3),5))
4800   IF Zz>0 THEN 4800
4810   Zz=$VAL$(DROUND(Zz,5))
4820   IF Zz<1 THEN 4930
4830   GOTO 4980
4840   Z$(J)=Zz#
4850   Long=6
4860 NEXT J
4870 GOTO 5070

```

```

4880      FOR ZZ<0
4890      IF LEN(Zz$)>Long THEN Zz#=Zz$[1,Long]
4900      IF LEN(Zz$)<Long THEN Zz#=Zz$&Dec#
4910      IF LEN(Zz$)><Long THEN 4900
4920      GOTO 4840
4930      FOR 0<ZZ<1
4940      IF LEN(Zz$)>Long THEN Zz#=Zz$[1,Long-1]
4950      IF LEN(Zz$)<Long THEN Zz#=Dec$&ZZ#
4960      IF LEN(Zz$)<<Long THEN 5040
4970      GOTO 4840
4980      FOR ZZ|1
4990      P$="N"
5000      FDR F=LEN(Zz$) TD 1 STEP -1
5010      IF Zz#(F,F$)=".." THEN P$="Y"
5020      NEXT F
5030      IF P$="N" AND LEN(Zz$)>Long THEN Zz#=Zz$&Per $
5040      IF Zz<1.E+5 AND LEN(Zz$)<Long THEN Zz#=Zz$&Dec $
5050      IF Zz<1.E+5 AND LEN(Zz$)<<Long THEN 5040
5060      GOTO 4840
5070      SUBEND
5080
5090
5100
5110 DEF FNRound(Z,N)
5120   Nu=INT(Z*10^N#+.5)           ! ROUNDING FDR Z<0
5130   Nu=Nu/(10^N#)
5140   RETURN Nu
5150 FNEND
5160
5170
5180
5190 SUB Mem
5200   OPTION BASE 1
5210   CON /Array/ Raw(4096),A15(2),B(512),E(512),I(512,4)
5220   CON /Stat/ Amp,Node,Nav,Nblock,Sigma
5230
5240   ! THIS SUBROUTINE EVALUATES THE ERROR TERM CALCULATED
5250   ! IN SUBROUTINE PROPS IN ORDER TO ELIMINATE THOSE FIRST
5260   ! VALUES THAT HAVE SI OR MORE ERROR
5270
5280   Mt=0
5290   FOR I=1 TO Nblock
5300     Mt=1
5310     IF (E(I)<.05 AND I(1,3)>0.) THEN GOTO 5330
5320   NEXT I
5330   Nblock=Nblock-Mt
5340   IF Nblock=0 THEN GOTO 5410
5350   FOR J=I TO Nblock
5360     Z(J,1)=Z(J+Mt,1)
5370     Z(J,2)=Z(J+Mt,2)
5380     Z(J,3)=Z(J+Mt,3)
5390     Z(J,4)=Z(J+Mt,4)
5400   NEXT J
5410   SUBEND
5420
5430
5440
5450 SUB Graf_set(Tscale)
5460   CON /Stat/ Amp,Node,Nav,Nblock,Sigma
5470
5480   READ X$,Y$,Xx1,Xx2,Yy1,Yy2
5490   IF Node=2 THEN READ X$,Y$,Xx1,Xx2,Yy1,Yy2
5500   IF Node=2 THEN Xx2=Tscale
5510   GINIT
5520   GRAPHICS OFF
5530   VIEWPORT 0,130,15,100
5540   PEN 1
5550   LDIR PI/2
5560   LDIB 6
5570   HMOVE 0,.5?
5580   LABEL Y$
```

```

5590 LDIR 0
5600 LORG 4
5610 MOVE 65,15
5620 LABEL I#
5630 CSIZE 3.7,.5
5640 MOVE 15,15
5650 LABEL Ix1
5660 MOVE 127,15
5670 LABEL Ix2
5680 LORG 2
5690 MOVE 0,29
5700 LABEL Yy1
5710 MOVE 0,98
5720 LABEL Yy2
5730 IF Mode=2 THEN 5780
5740   Ix1=LGT(Ix1)
5750   Ix2=LGT(Ix2)
5760   Yy1=LGT(Yy1)
5770   Yy2=LGT(Yy2)
5780 VIEWPORT 15,120,20,100
5790 WINDOW Ix1,Ix2,Yy1,Yy2
5800 FRAME
5810 IF Mode=1 THEN 5840
5820 MOVE 0,Yy1
5830 DRAW 0,Yy2
5840
5850 DATA "TMETA","NEAT FLUX",10,100,IE4,IE6
5860 DATA "TIME"," THETA",-2,20,30,70
5870 SUBEND
5880 '
5890 '
5900 '
5910 SUB Scr_Plot(B(I#))
5920   OPTION BASE 1
5930   COM /Stat/ Amp,Mode,Nav,Nblock,Sigaa
5940   Er$="N"
5950   Istart=1
5960   IF Mode=2 THEN 6030
5970   FOR I=I TO Nblock
5980     IF G(I,1)<0 OR G(I,2)<0 THEN Istart=I+1
5990     IF Istart>=I+1 THEN 6020
6000     G(I,1)=GT(G(I,1))
6010     G(I,2)=LGT(G(I,2))
6020   NEXT I
6030   LINE TYPE 1
6040   PEN 1
6050   ALPMA OFF
6060   GRAPHICS ON
6070   MOVE G(Istart,1),G(Istart,2)
6080   FOR I=Istart TO Nblock
6090     DRAW G(I,1),G(I,2)
6100   NEXT I
6110   MOVE 0,0
6120   IF Er$="Y" THEN 6190
6130   IF Mode=I THEN DISP " *** LOG-LOG SCALING *** "
6140   WAIT 5
6150   INPUT " ERASE THIS PLOT (Y/N) ? ",Er$
6160   IF Er$<>"Y" THEN 6190
6170   PEN 1
6180   GOTO 6070
6190   GRAPHICS OFF
6200   ALPMA ON
6210 SUBEND

```

APPENDIX B

Program PRESSURE: Pressure Data Analysis

This program was written in Hewlett-Packard BASIC, Version 2.0, and run on the HP 9816 microcomputer. Experimental parameters are included in the voltage input data set, similar to the pressure transient option of program BOIL. Manipulation of data provided by the digital oscilloscope is as described in Appendix A; however, since the entire capacity of the oscilloscope is used to record the pressure signal, separation of data by input channel is not necessary. The program structure is identical to that of BOIL, and the output is arranged such that instantaneous pressures are reported at the same experimental times as the output from BOIL.

```

1   ##### PRESSURE #####
2
3   ## PROGRAM CONVERTS VOLTAGE DATA MEASURED FROM A PRESSURE
4   ## TRANSDUCER (VIA A CHARGE AMPLIFIER) TO A PRESSURE HISTORY
5   ## OF THE PRESSURE VESSEL. VOLTAGE DATA IS ORIGINALLY INPUT
6   ## FROM THE NICOLET DIGITAL OSCILLOSCOPE, BUT THESE DATA ARE
7   ## ALSO STORED ON A DISC FOR FUTURE REFERENCE.
8   ## -->NOTE-- D-SCOPE IS CURSOR TRIGGERED.
9
10  ## 11 O.SCHMIOT          KSU    SEP 1984
12  ## 13 update: "quick & dirty" plot (O.SCHMIOT) KSU JAN 1985
14
15
160 OPTION BASE 1
170 COM /Stat/ Ch0,Drift,Nav,Nblock,Pperv,Ta,Tau,Vnore
180 CON /Array/ A(1025),Raw(4096)
190 DIM Title$(80)
200
210 PRINT CHR$(12)
220 INPUT "RESET GRAPHICS (Y/N) ?";Reset$
230 INPUT "WHAT IS THE RUN NUMBER ?";Title$
240 Title$="RUN NUMBER "+Title$
250 PRINT Title$
260
270 !       MAIN PROGRAM
280
290 CALL Inpt(N$)
300 Tscale=Tau*14000
310 IF Reset$="Y" THEN CALL Graf_Set(Raw(6),Tscale)
320 PRINT Title$, " ", " ", "SOURCE DATA FILE: ";N$
330 PRINT
340 PRINT "AVERAGING DATA - - - ";Nav; " POINT AVERAGING"
350 CALL Avg
360 PRINT "CALCULATING AMP DRIFT"
370 CALL Amp_drift
380 PRINT "CALCULATING PRESSURE HISTORY"
390 CALL Pressure
400 CALL Outp(N$,Title$)
410 INPUT "RECALCULATE WITH SAME SOURCE DATA (Y/N) ?";Ans$
420 IF Ans$()>"Y" THEN 400
430 PRINT CHR$(12)
440 GOTO 270
450
460 SUB Inpt(N$)
470   OPTION BASE 1
480   COM /Stat/ Ch0,Drift,Nav,Nblock,Pperv,Ta,Tau,Vnore
490   CON /Array/ A(1025),Raw(4096)
500   DIM Raw$(4096)(5)
510   INPUT "DATA SOURCE - - - SCOPE = 1, BDAT FILE = 2";Tt
520   CALL Reader(Tt,N$,Raw$(1))
530   FOR I=2 TO 4096
540     Raw(I)=VAL(Raw$(I))
550   NEXT I
560   Vnore=Raw(2)
570   Ch0=Raw(3)
580   Tau=Raw(4)
590   Ta=Raw(5)
600   BEEP 2197.26,.3
610   Nav=B
620   INPUT "ENTER [4,8,16] POINT RUNNING AVERAGE (DEFAULT=8) ";Nav
630   Nch=4096-Ch0-Nav/2
640   Nblock=INT(Nch/Nav)
650   PRINT CHR$(12)
660   PRINT Raw$(1),Raw(2),Raw(3),Raw(4),Raw(5),Raw(6),Raw(7)
670   PRINT
680   SUBEND
690
700

```

```

710 SUB Reader (t$,Name$,Raw$(1))
720   OPTION BASE 1
730   PRINT
740   PRINT "PLEASE INSERT DATA DISC INTO DISC DRIVE 0"
750   INPUT "PLEASE ENTER A UNIQUE NAME FOR THE BOAT FILE.",Name$
760   DISP "WORKING, PLEASE WAIT."
770   MASS STORAGE IS "1:HPB2#01,700,0"
780   IF T$=2 THEN 1000
790
800   ASSIGN PScope TO 9
810   CONTROL 9,3;960
820   ASSIGN PScope;FORMAT ON
830   CONTROL 9,5;5
840   CONTROL 9,4;2
850   OUTPUT PScope;CHR$(1);
860   OUTPUT PScope;CHR$(69);CHR$(48);CHR$(68);CHR$(49);CHR$(68);CHR$(48);
870   OUTPUT PScope;CHR$(79);CHR$(52);CHR$(48);CHR$(57);CHR$(54)
880   OUTPUT PScope;CHR$(2);
890   ENTER PScope USING "5h,X,";Raw$(1)
900   CONTROL 9,5;0
910   ASSIGN PScope TO #
920   CALL Scope set(Raw$(1))
930   DISP "WORKING, PLEASE WAIT."
940   CREATE BOAT Name$,40%;5
950   ASSIGN #Path TO Name$
960   OUTPUT #Path USING "5A";Raw$(1)
970   ASSIGN #Path TO #
980   SUBEXIT
990
1000   ASSIGN #Path TO Name$
1010   ENTER #Path USING "5A";Raw$(1)
1020   ASSIGN #Path TO #
1030   SUBEND
1040
1050
1060
1070 SUB Scope set(Raw$(1))
1080   OPTION BASE 1
1090   BEEP 1627,60,.3
1100   INPUT "ENTER TIME FOR FIRST DATA POINT (sec)",Chito
1110   INPUT "ENTER TIME OF EVENT INITIATION (sec)",Event0
1120   INPUT "ENTER TIME INCREMENT, e.g. 5E-3 FOR 20 SEC RUN",Tau
1130   INPUT "ENTER VOLTAGE RANGE (V)",Range
1140   INPUT "ENTER INITIAL PRESSURE (psig)",Po
1150   INPUT "ENTER FINAL PRESSURE (psig)",Pf
1160   INPUT "ENTER AMBIENT TEMPERATURE (C)",Ta
1170
1180   Raw$(1)="PRESS" ! For error if read by "BOIL"
1190   Raw$(2)=VAL$1!Range/2000! ! Vnorm
1200   Raw$(3)=VAL$1!ABS(Chito)-ABS(Event0))/Tau ! Ch0
1210   Raw$(4)=VAL$1!Tau
1220   Raw$(5)=VAL$1!Ta
1230   Raw$(6)=VAL$1!Po
1240   Raw$(7)=VAL$1!Pf
1250   SUBEND
1260
1270
1280
1290 SUB Avg
1300   OPTION BASE 1
1310   COM /Stat/ Ch0,Drift,Nav,Nblock,Pprev,Ta,Tau,Vnorm
1320   COM /Array/ A1!025),Raw$(40%)
1330
1340 ! THIS SUBROUTINE CALCULATES THE RUNNING AVERAGES OF THE DATA
1350
1360   Adj=INT(Nav/2)-1
1370   Jstart=Ch0-Adj
1380   FOR I=1 TO Nblock
1390     Sum=0
1400     Jend=Jstart+Nav-1
1410     FOR J=Jstart TO Jend
1420       Sum=Sum+Raw$(J)!Vnorm ! CONVERT TO TRUE VOLTAGE
1430     NEXT J
1440     A111=Sum/Nav ! AND AVERAGE
1450     Jstart=Jend+1
1460   NEXT I
1470   SUBEND

```

```

1480 :
1490 :
1500 :
1510 SUB Amp_drift
1520   OPTION BASE 1
1530   COM /Stat/ Cho,Drift,Nav,Nblock,Pperv,Ta,Tau,Vnorm
1540   COM /Array/ A(1025),Raw(4096)
1550 :
1560   ! THIS SUBROUTINE CALCULATES THE DRIFT IN THE CHARGE AMP SIGNAL
1570   ! IT IS ASSUMED THAT DEPRESSURIZATION IS COMPLETE BY THE TIME
1580   ! OF INTEREST FOR THIS CALCULATION
1590 :
1600   Suxx=0
1610   Suxx2=0
1620   Suyy=0
1630   Suyy2=0
1640   Iz=4
1650   FOR I=(Nblock-15) TO (Nblock-2)           ! TIME
1660     T=Tau*Nav*I(-1)
1670     Sux=Suxx+T
1680     Suxx2=Suxx2+T^2
1690     Suyy=Suyy+A(I)
1700     Suyy2=Suyy2+A(I)^2
1710   NEXT I
1720   Drift=ROUND((Suyy-(Suxx+Suyy)/Iz)/(Suxx2-(Suxx^2)/Iz),6)
1730 SUBEND
1740 :
1750 :
1760 :
1770 SUB Pressure
1780   OPTION BASE 1
1790   COM /Stat/ Cho,Drift,Nav,Nblock,Pperv,Ta,Tau,Vnorm
1800   COM /Array/ A(1025),Raw(4096)
1810   DIM Test(1025)
1820 :
1830   I=0
1840   Amin=100
1850   FOR I=1 TO Nblock                         ! ADJUST VOLTAGE FOR DRIFT
1860     Drift=Tau*Nav*I(-1)*Drift
1870     Test(I)=A(I)-Drift
1880     IF Test(I)>Amin THEN 1910
1890     Amin=Test(I)
1900     I=I+1
1910   NEXT I
1920   Pperv=ROUND((Raw(6)-Raw(7))/(A(I)-Amin),6)    ! psi/volt
1930 :
1940   IF I=0 THEN BEEP 2197.26,.3
1950   PRINT " ", "DRIFT = ";Drift;" Volts per second," " , "PSI/VOLT = ";Pperv
1960   NewDrift
1970   INPUT "Enter new value for DRIFT or accept default",New
1980   IF NewDrift THEN 2030
1990   Drift=New
2000   I=1
2010   DISP "RECALCULATING ---> PSI/VOLT"
2020   GOTO 1840
2030   FOR I=1 TO Nblock
2040     A(I)=Raw(6)-(Test(I)-Drift)*Pperv           ! CONVERT TO PRESSURE
2050     IF I>Imin THEN A(I)=A(Imin)
2060   NEXT I
2070 SUBEND
2080 :
2090 :
2100 :
2110 SUB Dsize(M$,Titles)
2120   OPTION BASE 1
2130   COM /Stat/ Cho,Drift,Nav,Nblock,Pperv,Ta,Tau,Vnorm
2140   COM /Array/ A(1025),Raw(4096)
2150   DIM Add1$(16),He1$(801),He2$(801),He3$(801),Inb$(5),St$(801)
2160   DIM T1$(801),T2$(801),Out$(3)(801),I$(14)I10]
2170 :
2180   Istart=16\Nav+1                            ! FILE SIZE INFORMATION
2190   Step=(Istart-1)\#2
2200   Size=INT(Nblock\Step+.5)
2210   ALLOCATE G(Size,2)
2220   G(1,1)=0
2230   G(1,2)=Raw(6)

```

```

2240   J=I
2250   FOR I=start TO Nblock STEP Step
2260     J=J+1
2270     IF J>Size THEN 2300
2280     G(J,1)=TauNavl(I-1)           ! TIME
2290     G(J,2)=A(I)                 ! PRESSURE
2300   NEXT I
2310
2320   PRINT
2330   PRINT " ****"
2340   PRINT " **** the ""QUICK & DIRTY"" screen plot will be"
2350   PRINT " **** PSIG v TIME regardless of output units choice"
2360   INPUT "ENTER PRESSURE UNITS FOR OUTPUT :  K = kPa, P = psig",Unit$ 
2370   BEEP 1027,60,.3
2380   PRINT CHR$(121)                ! "QUICK & DIRTY" PLOT
2390   CALL Scr_Plot(G(),Size)        ! PSIG v TIME
2400
2410   IF Unit$="P" THEN 2470
2420     DISP "CONVERTING    psig ----> kPa "
2430     Pperv=Pperv*14.6964*01.325
2440     FOR I=1 TO Size             ! CONVERT TO kPa (absolute)
2450       G(I,2)=(G(I,2)/14.6964*I)+01.325
2460     NEXT I
2470   INPUT "Do you wish to have a HARO COPY of the numbers ? (Y/N) ",Ans$ 
2480   IF Ans$="Y" THEN 3000
2490   PRINT Title$, " ", "SOURCE DATA FILET ";N$ 
2500   PRINT
2510   PRINT "#### PLEASE INSERT A DISC INTO DISC DRIVE 1"
2520   PRINT
2530   PRINT "AN ASCII FILE WILL BE CREATED ON THE DISC. THIS FILE CAN THEN"
2540   PRINT "BE TRANSFERED TO THE MAIN COMPUTER FOR PRINT OUT"
2550   INPUT "PLEASE ENTER A UNIQUE NAME FOR THE ASCII FILE ",As$ 
2560   Add$=" "
2570   Inb$=" "
2580   Sts$="          *****          *****          *****          *****"
2590   He1$="          TIME          PRESSURE          TIME          PRESSURE"
2600   He2$="          (s)          (psig)          (s)          (psig)"
2610   He3$="          PAGE "
2620   !$=Add$%"AMBIENT TEMP. = %VAL$(Ta%) C"
2630   T2$=Add$%"PSI PER VOLT = %VAL$(ROUND(Pperv,b)) "
2640   IF Unit$="P" THEN 2670
2650   He4$="          (s)          (kPa)          (s)          (kPa) "
2660   T2$=Add$%"kPa PER VOLT = %VAL$(ROUND(Pperv,b)) "
2670   Istart=1
2680   Iend=45
2690   Npg=1
2700   MASS STORAGE IS "HPB2901,700,I"
2710   CREATE ASCII Asf,b0
2720   ASSIGN #Path TO Asf
2730   OUTPUT #Path;Add$%Title$,Inb$,T1$,T2$,Inb$ 
2740   OUTPUT #Path;Sts$,Inb$,He1$,He2$ 
2750   OUTPUT #Path;Inb$,St$,Inb$ 
2760   FOR I=Istart TO Iend STEP 3
2770     CALL Decl,G($),Z($),Size)
2780     Out$(1)=Add$%Z$(1)%Inb$%Z$(2)%Add$%Z$(3)%Inb$%Z$(4)
2790     IF I<Size THEN CALL Dec(I+1,6$(1),Z$(1),Size)
2800     Out$(2)=Add$%Z$(1)%Inb$%Z$(2)%Add$%Z$(3)%Inb$%Z$(4)
2810     IF I+2<Size THEN CALL Dec(I+2,6$(1),Z$(1),Size)
2820     Out$(3)=Add$%Z$(1)%Inb$%Z$(2)%Add$%Z$(3)%Inb$%Z$(4)
2830     IF I+1=Size THEN Out$(3)=Add$%
2840     IF I+2=Size THEN Out$(3)=Add$%
2850     OUTPUT #Path;Out$(1),Out$(2),Out$(3)
2860   NEXT I
2870   IF Iend=Size THEN 2970
2880   OUTPUT #Path;Inb$,Inb$,Inb$,Inb$,Inb$,Inb$,Inb$,Inb$ 
2890   Npg=Npg+1
2900   T1$=Add$%Title$%He3$%VAL$(Npg)
2910   Istart=Iend+45
2920   Iend=Istart+44
2930   IF Iend>Size THEN Iend=Size
2940   OUTPUT #Path;T1$,Inb$,St$,Inb$,Inb$,He1$ 
2950   OUTPUT #Path;He2$,Inb$,St$,Inb$,Inb$ 
2960   GOTO 2760
2970   ASSIGN #Path TO #
2980   MASS STORAGE IS "HPB2901,700,O"
2990   BEEP 1302.08,J

```

```

3000
3010 INPUT "Do you wish to have a PLOT of the numbers ? (Y/N)",Ans$
3020 IF Ans$<>"N" THEN 3200
3030 PRINT CHR$(12)
3040 PRINT Title$, " , ", "SOURCE DATA FILE : ";Ns
3050 PRINT
3060 PRINT "***** PLEASE INSERT A DISC INTO DISC DRIVE !"
3070 PRINT
3080 PRINT "A BOAT FILE WILL BE CREATED ON THE DISC. THIS FILE CAN THEN"
3090 PRINT "BE PLOTTED USING THE GENERAL PLOTTING PROGRAM"
3100 INPUT "PLEASE ENTER A UNIQUE NAME FOR THE BOAT FILE ",Bd$
3110 MASS STORAGE IS "HPB290I,700,I"
3120 CREATE BOAT Bd$, (2#Size),?
3130 ASSIGN #Path TO Bd#
3140 Format$="M1.000E#"
3150 OUTPUT #Path USING Format$;G(#)
3160 ASSIGN #Path TO I
3170 MASS STORAGE IS "HPB290I,700,0"
3180 PRINT
3190 PRINT "BOAT file: ";Bd$,Size;" points","Data format: M1.000E"
3200 DEALLOCATE G()
3210 REEP 512#,94,1
3220 PRINT " END"
3230 SUBEND
3240
3250
3260
3270 SUB DecI(Z$(I),Z$(I),Size)
3280 OPTION BASE 1
3290
3300 THIS SUBROUTINE ENSURES THAT ALL VALUES HAVE THE
3310 CORRECT FIELD LENGTH FOR OUTPUT
3320
3330 Ii=1
3340 Ai=0
3350 Dec$="0"
3360 Per$="."
3370 Z$(3)= ""
3380 Z$(4)= ""
3390 Long=5
3400 FOR J=1 TO 2
3410   Izz(Ii,J)
3420   IF Izz<0 THEN Zz$=VAL$(ROUND(FNround(Izz,3),5))
3430   IF Izz>0 THEN 3550
3440   Zz$=VAL$(ROUND(Izz,5))
3450   IF Izz<1.E-5 THEN Zz$=".000000"
3460   IF Izz>1.0 THEN 3600
3470   GOTO 3650
3480   Zz$|A|=Izz
3490   Long=6
3500 NEXT J
3510 IF Ii>I OR I+45>Size THEN 3740
3520 A=2
3530 Ii=I+45
3540 GOTO 3390
3550 FOR ZZ<0
3560   IF LEN(Izz$)<Long THEN Zz$=Zz$|I,Long|
3570   IF LEN(Izz$)<Long THEN Zz$=Zz$&Dec$
3580   IF LEN(Izz$)<Long THEN 3570
3590 GOTO 3480
3600 FOR 0<ZZ<
3610   IF LEN(Izz$)<Long THEN Zz$=Zz$|I,Long-1|
3620   IF LEN(Izz$)<Long THEN Izz=Dec$|Izz
3630   IF LEN(Izz$)<Long THEN 3710
3640 GOTO 3480
3650 FOR ZZ>
3660   Ps="N"
3670   FOR F=LEN(Izz$) TO I STEP -1
3680     IF Izz$|F,F|=",." THEN Ps="Y"
3690   NEXT F
3700   IF Ps="N" AND LEN(Izz$)<Long THEN Zz$=Zz$&Per$|
3710   IF Izz<1.E-5 AND LEN(Izz$)<Long THEN Zz$=Zz$&Dec$|
3720   IF Izz<1.E-5 AND LEN(Izz$)<Long THEN 3710
3730   GOTO 3480
3740 SUBEND

```

```

3750 :
3760 :
3770 :
3780      DEF FNRound(I,Mp)
3790      Nu=INT(I*10^Mp+.5)           ! ROUNDING FOR I()
3800      Nu=Nu/(10^Mp)
3810      RETURN Nu
3820      FNEND
3830 :
3840 :
3850 :
3860 SUB Graf_Set(P2,Tscale)
3870   GINIT
3880   GRAPHICS OFF
3890   VIEWPORT 0,130,15,100
3900   PEN 1
3910   LDUR PI/2
3920   LORG 6
3930   MOVE 0,57
3940   LABEL "PRESSURE (psig)"
3950   LOIR 0
3960   LORG 4
3970   MOVE 65,15
3980   LABEL "TIME (s)"
3990   CSIZE 3,7,.5
4000   MOVE 7,15
4010   LABEL "0"
4020   MOVE 128,15
4030   LABEL Tscale
4040   LORG 2
4050   MOVE 0,20
4060   LABEL "-5"
4070   MOVE 0,98
4080   LABEL P2
4090   VIEWPORT 7,130,20,100
4100   WINDOW 0,Tscale,-5,P2
4110   FRAME
4120   ARIES 1,1,0,0,5,5,2
4130 SUSEND
4140 :
4150 :
4160 :
4170 SUB Scr_Plot(G(),Nodata)
4180   OPTION BASE 1
4190   Err$="N"
4200   LINE TYPE 1
4210   PEN 1
4220   ALPHA OFF
4230   GRAPHICS ON
4240   MOVE G(1,1),G(1,2)
4250   FOR I=1 TO Nodata
4260     IF G(I,1)=0 AND I>1 THEN 4280
4270     DRAN G(I,1),G(I,2)
4280   NEXT I
4290   MOVE 0,0
4300   IF Err$="Y" THEN 4360
4310   WAIT 5
4320   INPUT *        ERASE THIS PLOT (Y/N)?,Err$
4330   IF Err$<>"Y" THEN 4360
4340   PEN -1
4350   GOTO 4240
4360   GRAPHICS OFF
4370   ALPHA ON
4380 SUSEND

```

APPENDIX C

System Performance

Control System Performance

The ability of the control system to provide a constant power delivery (superficial heat flux) to the test element is illustrated in Fig. C1. It will be noted that, in spite of the substantial change in wire temperature (and the rapidity at which this change is possible), with associated change in wire resistance, the control system provides constant power delivery.

Pressure Measurement System Performance

The ability of the pressure measurement system to yield an accurate pressure history of an experiment depends on proper setup for test conditions. Best accuracy requires flush mounting of the pressure transducer to the test section. However, this was not possible due to the necessity of providing cooling capability for the transducer with the cooling adaptor. The choice of the amplifier time constant also affects the accuracy, and a dramatic effect on the voltage signal measured for a given pressure drop. Use of the short and medium time constant settings resulted in signal decay during the pressure transient, while use of the log time constant introduced the complication of signal drift (Fig. C2).

The effect of temperature on the measure voltage signal is illustrated in Fig. C3. The figure compares measurements at an ambient temperature $T_a = 27^\circ\text{C}$ to measurements at $T_a = 100^\circ\text{C}$. For the long time constant setting, the drift is adversely affected by increasing temperature (no significant difference in behavior was found in the medium and short time constant cases). Additionally, as seen in Fig.




FIG. C1. Control system performance for a 20 s run. The straight line is the heat flux as a function of time. The curve is the test heater temperature as a function of time. Results are from run AP3-3, with ambient temperature $T_a = 100^\circ\text{C}$.




FIG. C.2. Effect of pressure transducer amplifier time constant on the signal measured for a 0.377 to 0.101 kPa pressure drop at $T_a = 100^\circ\text{C}$.




FIG. C3. Effect of ambient temperature on the signal measured for a 0.377 to 0.101 MPa pressure drop. The dashed line is the signal measured at $T_a = 27^\circ\text{C}$. The solid line is the signal measured at $T_a = 100^\circ\text{C}$.

C4, there was little consistency in the value of the drift beyond the individual run. Therefore, the analysis program determined the average drift for each run and corrected the data for this drift, then translated the data from voltage units to pressure units based on the observed pressure drop. Using the same data as Fig. C3, these two steps are illustrated in Figs. C5 and C6, comparing the results from a test with significant drift to the results from a test with zero drift. Figure C7 also illustrates the effect of ambient temperature on the pressure transient, comparing results for $T_a = 95^{\circ}\text{C}$ to results for $T_a = 100^{\circ}\text{C}$.




FIG. C4. Representative measurements of the pressure transducer amplifier drift at constant pressure and $T_a = 100^\circ\text{C}$. The solid line is the drift of the corresponding signal shown in FIG. C3, the short dash-long dash line is data from run AP1-6, the dashed line is data from run AP9-1, and the dotted line is data from run AP10-1.




FIG. C5. Drift corrected signals for a 0.377 to 0.101 MPa pressure drop. The dashed line is the zero-drift signal measured at $T_3 = 27^\circ\text{C}$. The solid line is the signal measured at $T_2 = 100^\circ\text{C}$ corrected for drift by the prescription of data analysis program PRESSURE.




FIG. C6. Translation of data from units of voltage to units of pressure. The dashed line is the pressure history for $T_a = 27^\circ\text{C}$. The solid line is the drift-corrected pressure history for $T_a = 100^\circ\text{C}$.




FIG. C7. Effect of ambient temperature on a 0.377 to 0.101 MPa pressure drop. The dashed line is the pressure history for $T_a = 95^\circ\text{C}$. The solid line is the pressure history for $T_a = 100^\circ\text{C}$.

APPENDIX D

Selected Listings of Experimental Pressure Data

Representative runs for series 1-8 (Table 5.2)

RUN NUMBER AP-2-2

AMBIENT TEMP. = 100°C
FRA. PER VOLT = 199.197

RUN NUMBER AP-2-B

AMBIENT TEMP. = 100°C
FRA. PER VOLT = 199.66

TIME 451	PRESSURE (kPa)	TIME (53)	PRESSURE (kPa)	TIME (51)	PRESSURE (kPa)	TIME (53)	PRESSURE (kPa)
0.000	370.57	7.120	105.73	0.000	515.01	7.100	179.56
0.080	364.21	7.280	105.37	0.030	510.68	7.200	157.3
0.240	364.21	7.440	105.31	0.240	444.29	7.440	106.45
0.400	362.69	7.600	105.18	0.460	450.94	7.600	105.65
0.560	313.32	7.760	104.64	0.560	439.05	7.760	105.37
0.720	311.92	7.920	104.47	0.720	410.12	7.920	104.42
0.880	258.72	8.080	104.25	0.880	397.00	8.080	103.90
1.040	277.10	8.240	104.43	1.040	374.46	8.240	103.57
1.207	265.57	8.400	104.33	1.200	358.83	8.400	103.05
1.360	279.74	8.560	104.00	1.360	362.66	8.560	103.04
1.520	259.09	8.720	104.71	1.520	329.40	8.720	103.03
1.680	235.13	8.880	103.73	1.680	316.04	8.880	102.95
1.840	225.75	9.040	103.52	1.840	301.02	9.040	102.65
2.000	216.77	9.200	103.27	2.000	290.78	9.200	102.77
2.160	205.73	9.360	103.34	2.160	279.27	9.360	102.74
2.320	200.47	9.520	103.17	2.320	267.77	9.520	103.03
2.480	192.76	9.680	103.15	2.480	256.07	9.680	101.58
2.640	185.57	9.840	103.30	2.640	246.40	9.840	101.33
2.803	178.57	10.00	103.13	2.800	236.56	10.00	101.33
2.960	172.32	10.16	103.15	2.960	226.63	10.16	101.33
3.120	165.32	10.32	103.17	3.120	211.43	10.32	101.33
3.280	159.03	10.48	103.20	3.280	209.01	10.48	101.33
3.440	154.64	10.64	102.92	3.440	200.29	10.64	101.33
3.600	149.61	10.80	103.13	3.600	192.11	10.80	101.33
3.760	145.10	10.95	103.14	3.760	184.31	10.95	101.33
3.920	141.06	11.12	103.07	3.920	177.41	11.12	101.33
4.080	137.11	11.28	102.92	4.080	170.33	11.28	101.33
4.240	139.25	11.44	102.55	4.240	164.84	11.44	101.33
4.400	136.56	11.60	101.83	4.400	161.94	11.60	101.33
4.560	137.27	11.76	101.71	4.560	158.49	11.76	101.33
4.720	128.71	11.92	101.72	4.720	154.76	11.92	101.33
4.880	125.38	12.08	101.33	4.880	146.65	12.08	101.33
5.040	123.89	12.24	101.33	5.040	143.50	12.24	101.33
5.200	120.90	12.40	101.33	5.200	138.02	12.40	101.33
5.360	118.48	12.55	101.33	5.360	132.87	12.55	101.33
5.520	116.79	12.72	101.33	5.520	127.15	12.72	101.33
5.680	115.32	12.88	101.33	5.680	123.41	12.88	101.33
5.840	113.99	13.04	101.33	5.840	119.51	13.04	101.33
6.000	112.67	13.20	101.33	6.000	115.37	13.20	101.33
6.160	111.38	13.36	101.33	6.160	115.81	13.36	101.33
6.320	110.35	13.52	101.33	6.320	111.67	13.52	101.33
6.480	109.37	13.68	101.33	6.480	112.02	13.68	101.33
6.640	109.13	13.84	101.33	6.640	110.42	13.84	101.33
6.800	108.03	14.00	101.33	6.800	109.21	14.00	101.33
6.960	107.46	14.16	101.33	6.960	107.97	14.16	101.33

RUN NUMBER AP-3-S

AMBIENT TEMP. = 800 C
KPA PER VOLT = 763.102

TIME 151	PRESSURE 1KPA	TIME 151	PRESSURE 1KPA

0.000	446.06	7.120	105.25
0.050	434.21	7.240	131.94
0.100	412.79	7.440	104.18
0.150	393.93	7.500	101.74
0.200	376.39	7.760	103.00
0.250	360.36	7.720	101.93
0.300	347.89	8.080	101.37
0.350	330.60	9.240	101.37
0.400	316.78	10.400	101.37
0.450	303.62	8.560	101.37
0.500	292.15	8.720	101.37
0.550	280.22	8.800	101.37
0.600	268.87	9.040	101.37
0.650	258.46	9.200	101.37
0.700	248.25	9.360	101.37
0.750	238.17	9.520	101.37
0.800	229.75	9.680	101.37
0.850	220.24	9.840	101.37
0.900	211.76	10.00	101.37
0.950	202.76	10.07	101.37
1.000	194.93	10.14	101.37
1.050	187.80	10.22	101.37
1.100	180.49	10.44	101.37
1.150	173.80	10.64	101.37
1.200	166.85	10.83	101.37
1.250	160.80	10.96	101.37
1.300	154.66	11.12	101.37
1.350	155.85	11.28	101.37
1.400	149.63	11.48	101.37
1.450	144.40	11.60	101.37
1.500	139.40	11.76	101.37
1.550	134.50	11.97	101.37
1.600	131.76	12.08	101.37
1.650	129.00	12.24	101.37
1.700	127.23	12.36	101.37
1.750	126.65	12.47	101.37
1.800	121.39	12.56	101.37
1.850	118.74	12.72	101.37
1.900	116.56	12.89	101.37
1.950	113.78	13.04	101.37
2.000	111.00	13.20	101.37
2.050	109.03	13.36	101.37
2.100	107.77	13.57	101.37
2.150	107.57	13.67	101.37
2.200	106.59	13.86	101.37
2.250	105.89	14.00	101.37
2.300	105.41	14.16	101.37

RUN NUMBER AP4-3

AIRLINE TEMP = 100 C
SPA PER VELT = 763.127

RUN NUMBER AP4-3

AIRLINE TEMP = 100 C
SPA PER VELT = 763.127

TIME (S)	PRESSURE (KPA)	TIME (S)	PRESSURE (KPA)
0.000	583.96	7.120	125.42
0.490	567.73	7.280	123.34
0.980	538.46	7.440	123.02
1.470	509.27	7.600	121.62
1.960	483.22	7.760	120.17
2.450	459.63	7.920	119.02
2.940	437.40	8.080	117.44
3.430	416.87	8.240	117.13
3.920	397.45	8.400	116.42
4.410	379.12	8.560	115.92
4.900	360.83	8.720	114.70
5.390	344.56	8.880	113.92
5.880	331.06	9.040	113.62
6.370	318.63	9.200	111.93
6.860	306.93	9.360	111.55
7.350	294.32	9.520	110.90
7.840	282.53	9.682	110.13
8.330	269.59	9.840	109.64
8.820	257.37	10.00	109.45
9.310	244.72	10.16	108.56
9.800	236.35	10.32	107.97
10.290	228.75	10.48	107.52
10.780	217.50	10.64	107.17
11.270	206.83	10.80	106.89
11.760	195.86	11.12	106.67
12.250	194.26	11.17	106.37
12.740	187.95	11.28	106.02
13.230	186.45	11.44	105.82
13.720	177.96	11.60	105.57
14.210	168.66	11.76	105.31
14.700	161.00	11.92	104.77
15.190	159.64	12.08	104.32
15.680	155.91	12.24	103.90
16.170	152.12	12.40	103.35
16.660	149.54	12.56	102.76
17.150	146.72	12.72	102.03
17.640	143.45	12.88	101.47
18.130	141.00	13.04	102.47
18.620	138.49	13.20	102.36
19.110	136.92	13.36	102.70
19.600	134.53	13.52	102.70
20.090	132.21	13.68	102.73
20.580	130.53	13.84	102.17
21.070	129.70	14.00	101.87
21.560	127.43	14.05	101.75
22.050	127.43	14.15	101.75

RUN NUMBER AP4-3

AIRLINE TEMP = 100 C
SPA PER VELT = 763.127

RUN NUMBER APT-5

PAGE 2

AMBIENT TEMP = 100 C
KPA PER VOLT = 995.493

RUN NUMBER	TIME (S)	PRESSURE (kPa)	TIME (S)	PRESSURE (kPa)
0+0.00	377.11	7+1.20	146.05	10+81
0+0.40	373.43	7+2.30	144.14	14+49
0+0.80	362.36	7+4.40	142.64	10+34
0+1.20	354.04	7+6.00	141.26	14+64
0+1.60	344.92	7+7.60	139.70	10+10
0+2.00	336.05	7+9.20	137.85	107.91
0+2.40	327.38	7+10.80	136.14	15.12
1+0.40	319.23	8+0.50	135.30	15.20
1+2.00	311.31	8+4.00	135.16	103.41
1+2.80	303.93	8+5.60	135.92	102.42
1+3.20	296.44	8+5.60	132.22	102.54
1+5.80	289.08	8+3.80	130.04	16.24
1+8.40	282+22	9+0.40	129.48	16.40
2+0.00	275+72	9+2.00	128.95	16+56
2+1.60	267+33	9+3.60	126.15	16+72
2+2.00	263.15	9+5.20	125.49	101+95
2+4.80	260.67	9+5.80	124.30	101+89
2+6.40	253.64	9+8.40	121.55	17.64
2+8.00	247.51	10+0.0	122+12	17.20
2+8.60	241+68	10+0.0	121+8	101+97
3+1.20	236+09	11+9+50	113+59	17.62
3+1.83	231+00	10+2.2	118+59	101+77
3+2.40	222+90	10+4.4	117+84	17.84
3+3.00	220+57	10+6.4	116+80	101+66
3+3.60	216+20	10+8.0	116+54	101+77
3+4.20	211+37	10+9.6	115+13	101+44
4+0.80	201+55	11+1.2	114+46	101+32
4+1.40	207+94	11+4.8	113+59	15+80
4+2.00	198+79	11+6.0	112+88	18+96
4+2.60	194+90	11+7.6	112+20	19+12
4+3.20	191+08	11+9.2	111+20	101+32
4+3.80	187+01	12+0.0	110+59	19+44
5+0.40	183+00	12+2.4	110+05	101+32
5+1.00	179+48	12+4.0	109+29	17+64
5+1.60	176+57	12+5.6	108+83	101+32
5+2.20	173+40	12+7.2	108+25	101+32
5+2.80	170+27	12+8.8	107+69	101+32
5+3.40	167+04	13+2.4	107+0	101+32
6+0.00	163+93	13+6.5	106+65	101+32
6+1.60	161+08	13+1.0	106+13	101+32
6+2.20	159+26	13+2.4	105+82	101+32
6+3.80	155+36	13+6.0	105+91	101+32
6+4.40	152+71	13+6.4	105+55	101+32
6+5.00	150+20	14+0.0	105+24	101+32
6+5.60	147+75	14+4.8	104+92	101+32

RUN NUMBER AP9-2

AMBIENT TEMP. = 100 C
KPA PER VOLT = 853.596

RUN NUMBER AP9-2

AMBIENT TEMP. = 100 C
KPA PER VOLT = 943.150

TIME (S)	PRESSURE (KPA)	TIME (S)	PRESSURE (KPA)
0.000	377.11	7.130	129.75
0.080	311.12	7.280	127.34
0.240	360.72	7.440	125.06
0.400	350.55	7.600	122.72
0.560	360.91	7.760	121.52
0.720	331.57	7.920	120.21
0.880	362.57	8.080	119.02
1.040	314.66	8.240	118.23
1.200	306.39	8.400	118.56
1.360	298.78	8.560	112.56
1.520	291.36	8.720	111.54
1.680	286.17	8.880	110.24
1.840	277.58	9.040	109.10
2.000	271.06	9.200	108.06
2.160	266.49	9.360	107.02
2.320	258.23	9.520	106.28
2.480	251.90	9.680	105.56
2.640	245.97	9.840	104.94
2.800	240.13	10.00	104.16
2.960	234.86	10.16	103.72
3.120	229.58	10.32	103.26
3.280	224.12	10.48	102.82
3.440	218.49	10.64	102.50
3.600	211.53	10.80	102.25
3.760	204.85	10.96	102.09
3.920	198.10	11.12	101.73
4.080	193.81	11.28	101.44
4.240	197.50	11.44	101.23
4.400	190.69	11.60	101.33
4.560	185.42	11.76	101.33
4.720	191.13	11.92	101.13
4.880	176.85	12.08	101.33
5.040	173.78	12.24	101.33
5.200	168.61	12.40	101.33
5.360	168.96	12.56	101.33
5.520	161.28	12.72	101.33
5.680	151.66	12.88	101.33
5.840	154.46	13.04	101.33
6.000	150.36	13.20	101.13
6.160	147.50	13.36	101.33
6.320	144.20	13.52	101.33
6.480	141.15	13.68	101.33
6.640	138.06	13.84	101.33
6.800	135.08	14.00	101.33
6.960	132.29	14.16	101.33

TIME (S)	PRESSURE (KPA)	TIME (S)	PRESSURE (KPA)
0.000	0.000	377.11	377.11
0.080	0.080	372.54	372.54
0.240	0.240	367.87	367.87
0.400	0.400	350.08	350.08
0.560	0.560	339.59	339.59
0.720	0.720	329.83	329.83
0.880	0.880	319.80	319.80
1.040	1.040	311.80	311.80
1.200	1.200	302.90	302.90
1.360	1.360	294.77	294.77
1.520	1.520	286.71	286.71
1.680	1.680	279.33	279.33
1.840	1.840	272.40	272.40
2.000	2.000	265.26	265.26
2.160	2.160	258.68	258.68
2.320	2.320	252.07	252.07
2.480	2.480	245.94	245.94
2.640	2.640	239.91	239.91
2.800	2.800	233.97	233.97
2.960	2.960	226.32	226.32
3.120	3.120	221.25	221.25
3.280	3.280	214.88	214.88
3.440	3.440	212.70	212.70
3.600	3.600	207.70	207.70
3.760	3.760	202.94	202.94
3.920	3.920	198.29	198.29
4.080	4.080	193.80	193.80
4.240	4.240	189.46	189.46
4.400	4.400	184.16	184.16
4.560	4.560	180.00	180.00
4.720	4.720	175.27	175.27
4.880	4.880	172.89	172.89
5.040	5.040	169.05	169.05
5.200	5.200	165.44	165.44
5.360	5.360	161.15	161.15
5.520	5.520	156.71	156.71
5.680	5.680	152.67	152.67
5.840	5.840	151.39	151.39
6.000	6.000	150.99	150.99
6.160	6.160	147.67	147.67
6.320	6.320	144.54	144.54
6.480	6.480	141.87	141.87
6.640	6.640	139.38	139.38
6.800	6.800	136.82	136.82
6.960	6.960	134.53	134.53

TIME
(S)

AMB TEMP. = 100 C
KPA/VOLT = 943.150

PRESSURE
(KPA)

AMB TEMP. = 100 C
KPA/VOLT = 853.596

TIME
(S)

AMB TEMP. = 100 C
KPA/VOLT = 943.150

PRESSURE
(KPA)

RUN NUMBER AP9-B

AMBIENT TEMP. = 100 E
kPa PER VOLT = 02.4, T₀₂ = 762

RUN NUMBER AP9-B

TIME (s)	PRESSURE (kPa)	TIME (s)	PRESSURE (kPa)	TIME (s)	PRESSURE (kPa)	TIME (s)	PRESSURE (kPa)
0.000	317.11	7.120	132.37	14.32	103.19	18.43	103.04
0.080	311.38	7.380	129.92	14.45	103.15	18.45	103.05
2.240	359.92	7.440	127.81	14.76	103.16	18.46	103.06
0.400	349.53	7.600	125.63	15.12	102.99	18.47	103.07
0.560	319.42	7.620	123.66	15.20	103.08	18.48	103.08
0.720	330.66	7.620	121.79	15.44	102.78	18.49	102.62
0.880	321.56	8.080	120.01	15.60	102.77	18.50	102.72
1.040	312.87	8.240	118.40	15.76	102.77	18.51	102.77
1.200	304.33	8.400	116.64	15.92	102.85	18.52	102.85
1.360	297.09	8.560	115.37	16.08	102.82	18.53	102.82
1.520	299.32	8.720	114.06	16.28	102.89	18.54	102.89
1.680	282.37	9.300	113.04	16.40	102.34	18.55	102.34
1.840	275.53	9.460	112.32	16.56	102.07	18.56	102.07
2.000	268.67	9.700	111.50	16.72	101.91	18.57	101.91
2.160	262.18	9.960	111.50	16.89	101.94	18.58	101.94
2.320	255.76	9.920	110.97	17.04	101.99	18.59	101.99
2.480	249.95	9.680	110.65	17.20	101.79	18.60	101.79
2.640	243.92	9.440	109.47	17.36	101.82	18.61	101.82
2.800	237.99	10.000	109.55	17.52	101.75	18.62	101.75
2.960	232.51	10.16	108.75	17.68	101.72	18.63	101.72
3.120	226.49	10.32	108.25	17.84	101.68	18.64	101.68
3.280	221.72	10.48	107.99	18.00	101.71	18.65	101.71
3.440	216.81	10.64	107.75	18.16	101.74	18.66	101.74
3.600	211.76	10.80	107.54	18.32	101.82	18.67	101.82
3.760	206.24	10.96	107.34	18.48	101.87	18.68	101.87
3.920	202.00	11.12	106.45	18.64	101.95	18.69	101.95
4.080	191.35	11.28	105.92	18.80	101.91	18.96	101.91
4.240	192.76	11.44	105.70	18.96	101.88	19.12	101.88
4.400	188.75	11.60	105.47	19.12	101.87	19.28	101.87
4.560	193.87	11.76	105.31	19.28	101.87	19.44	101.87
4.720	184.36	11.92	105.01	19.44	101.88	19.60	101.88
4.880	179.82	12.08	104.93	19.60	101.92	19.77	101.92
5.040	173.98	12.24	104.87	19.77	101.97	19.94	101.97
5.200	169.53	12.40	104.91	19.94	102.05	20.11	102.05
5.360	165.44	12.56	104.93	20.11	102.11	20.28	102.11
5.520	161.53	12.72	104.93	20.36	102.18	20.43	102.18
5.680	157.78	12.88	104.93	20.51	102.25	20.58	102.25
5.840	154.37	13.04	104.98	20.67	102.32	20.74	102.32
6.000	151.06	13.20	104.96	20.83	102.39	20.80	102.39
6.160	148.07	13.36	104.92	20.99	102.46	20.87	102.46
6.320	145.15	13.52	104.97	21.15	102.52	21.04	102.52
6.480	142.30	13.68	105.68	21.31	102.68	21.21	102.68
6.640	139.49	13.84	105.34	21.47	102.73	21.37	102.73
6.800	137.51	14.00	105.03	21.63	102.74	21.53	102.74
6.960	134.89	14.16	105.20	21.79	102.80	21.69	102.80

APPENDIX E

Selected Listings of Experimental Temperature Data

First run in each of series 1-8 (Table 5.3). THETA is the platinum heater temperature less the ambient temperature. The NUSSELT NUMBER is based on the superficial heat flux.

RUN NUMBER AP2-3

H.U.H. NUMBER AP2-3

PAGE 2

RUN NUMBER	PIPE LENGTH	WIRE DIAMETER	AIR/CO ₂ MIXTURE	AMBENT TEMP.	PRESSURE	INITIAL PRESS.	SIGNS	TIME	HEAT FLUX	THE TA (°C)	HEAT FLUX	THE TA (°C)	HUSSLT NUMBER	HUSSLT NUMBER
	m	m	%	m	Pa	Pa	%	153	W/m ²	153	W/m ²	153	W/m ²	153
0	-0.096	-0.00075	-0.00075	-0.00075	-0.00075	-0.00075	-0.00075	0.0-0.40	42.850	50.0-93	3.1580	3.1580	3.1407	3.1407
0.2-0.40	42.850	50.0-40	2.66552	6.7900	42.850	50.0-61	3.1864	7.6-7.60	42.4950	46.815	3.3780	3.3780	3.4071	3.4071
0.4-0.60	42.850	50.0-60	2.66552	7.120	42.850	49.653	3.1864	7.6-7.60	42.4950	47.213	3.2147	3.2147	3.4071	3.4071
0.5-0.60	42.850	50.0-50	2.66552	7.6-7.60	42.4950	47.480	3.1330	7.6-7.60	42.4950	46.815	3.3780	3.3780	3.4071	3.4071
0.5-0.80	42.850	50.0-40	2.66552	7.6-7.60	42.4950	46.422	3.1330	7.6-7.60	42.4950	46.422	3.1330	3.1330	3.4071	3.4071
0.6-0.80	42.850	50.0-30	2.66552	7.9-7.90	42.8470	46.376	3.3918	7.9-7.90	42.8470	46.376	3.3918	3.3918	3.4071	3.4071
0.7-0.80	42.850	50.0-20	2.66552	8.0-0.80	42.8460	46.0-64	3.3918	8.0-0.80	42.8460	46.0-64	3.3918	3.3918	3.4071	3.4071
0.8-0.80	42.850	50.0-10	2.66552	8.240	42.8460	47.179	3.3529	8.240	42.8460	47.179	3.3529	3.3529	3.4071	3.4071
0.9-0.80	42.850	50.0-0	2.66552	8.4-0.00	42.8460	46.4-64	3.4044	8.4-0.00	42.8460	46.4-64	3.4044	3.4044	3.4071	3.4071
0.9-1.80	42.850	50.0-30	2.66552	8.5-5.60	42.4950	46.8-62	3.3756	8.5-5.60	42.4950	46.8-62	3.3756	3.3756	3.4071	3.4071
1.0-1.80	42.850	50.0-20	2.66552	8.7-7.20	42.4950	47.0-09	3.3650	8.7-7.20	42.4950	47.0-09	3.3650	3.3650	3.4071	3.4071
1.1-1.80	42.850	50.0-10	2.66552	8.8-8.80	42.4950	46.6-67	3.3881	8.8-8.80	42.4950	46.6-67	3.3881	3.3881	3.4071	3.4071
1.2-1.80	42.850	50.0-0	2.66552	9.0-0.40	42.4950	46.106	3.4309	9.0-0.40	42.4950	46.106	3.4309	3.4309	3.4071	3.4071
1.3-2.0	42.850	50.0-10	2.66552	9.2-0.00	42.8450	45.9-91	3.4447	9.2-0.00	42.8450	45.9-91	3.4447	3.4447	3.4071	3.4071
1.4-2.0	42.850	50.0-0	2.66552	9.3-0.00	42.4950	46.2-20	3.4192	9.3-0.00	42.4950	46.2-20	3.4192	3.4192	3.4071	3.4071
1.5-2.0	42.850	50.0-0	2.66552	9.5-0.00	42.4950	46.2-21	3.4231	9.5-0.00	42.4950	46.2-21	3.4231	3.4231	3.4071	3.4071
1.6-2.0	42.850	50.0-0	2.66552	9.6-0.00	42.4950	46.3-62	3.4117	9.6-0.00	42.4950	46.3-62	3.4117	3.4117	3.4071	3.4071
1.7-2.0	42.850	50.0-0	2.66552	9.8-0.00	42.4950	46.5-17	3.4007	9.8-0.00	42.4950	46.5-17	3.4007	3.4007	3.4071	3.4071
1.8-2.0	42.850	50.0-0	2.66552	10.0-0.00	42.4950	46.3-15	3.415	10.0-0.00	42.4950	46.3-15	3.415	3.415	3.4071	3.4071
1.9-2.0	42.850	50.0-0	2.66552	10.5-0.00	42.4950	46.2-44	3.412	10.5-0.00	42.4950	46.2-44	3.412	3.412	3.4071	3.4071
2.0-2.0	42.850	50.0-0	2.66552	10.8-0.00	42.4950	45.6-93	3.4625	10.8-0.00	42.4950	45.6-93	3.4625	3.4625	3.4071	3.4071
2.1-2.0	42.850	50.0-0	2.66552	11.0-0.00	42.4950	45.9-91	3.4447	11.0-0.00	42.4950	45.9-91	3.4447	3.4447	3.4071	3.4071
2.2-2.0	42.850	50.0-0	2.66552	11.2-0.00	42.4950	46.1-51	3.4277	11.2-0.00	42.4950	46.1-51	3.4277	3.4277	3.4071	3.4071
2.3-2.0	42.850	50.0-0	2.66552	11.4-0.00	42.4950	46.1-51	3.4277	11.4-0.00	42.4950	46.1-51	3.4277	3.4277	3.4071	3.4071
2.4-2.0	42.850	50.0-0	2.66552	11.6-0.00	42.4950	46.3-09	3.4075	11.6-0.00	42.4950	46.3-09	3.4075	3.4075	3.4071	3.4071
2.5-2.0	42.850	50.0-0	2.66552	11.8-0.00	42.4950	46.5-09	3.4075	11.8-0.00	42.4950	46.5-09	3.4075	3.4075	3.4071	3.4071
2.6-2.0	42.850	50.0-0	2.66552	12.0-0.00	42.4950	46.7-59	3.4075	12.0-0.00	42.4950	46.7-59	3.4075	3.4075	3.4071	3.4071
2.7-2.0	42.850	50.0-0	2.66552	12.2-0.00	42.4950	47.0-09	3.3544	12.2-0.00	42.4950	47.0-09	3.3544	3.3544	3.4071	3.4071
2.8-2.0	42.850	50.0-0	2.66552	12.4-0.00	42.4950	47.2-15	3.3544	12.4-0.00	42.4950	47.2-15	3.3544	3.3544	3.4071	3.4071
2.9-2.0	42.850	50.0-0	2.66552	12.6-0.00	42.4950	47.4-13	3.3544	12.6-0.00	42.4950	47.4-13	3.3544	3.3544	3.4071	3.4071
3.0-2.0	42.850	50.0-0	2.66552	12.8-0.00	42.4950	3.5845	3.3544	12.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.1-2.0	42.850	50.0-0	2.66552	13.0-0.00	42.4950	3.5845	3.3544	13.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.2-2.0	42.850	50.0-0	2.66552	13.2-0.00	42.4950	3.5845	3.3544	13.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.3-2.0	42.850	50.0-0	2.66552	13.4-0.00	42.4950	3.5845	3.3544	13.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.4-2.0	42.850	50.0-0	2.66552	13.6-0.00	42.4950	3.5845	3.3544	13.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.5-2.0	42.850	50.0-0	2.66552	13.8-0.00	42.4950	3.5845	3.3544	13.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.6-2.0	42.850	50.0-0	2.66552	14.0-0.00	42.4950	3.5845	3.3544	14.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.7-2.0	42.850	50.0-0	2.66552	14.2-0.00	42.4950	3.5845	3.3544	14.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.8-2.0	42.850	50.0-0	2.66552	14.4-0.00	42.4950	3.5845	3.3544	14.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
3.9-2.0	42.850	50.0-0	2.66552	14.6-0.00	42.4950	3.5845	3.3544	14.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.0-2.0	42.850	50.0-0	2.66552	14.8-0.00	42.4950	3.5845	3.3544	14.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.1-2.0	42.850	50.0-0	2.66552	15.0-0.00	42.4950	3.5845	3.3544	15.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.2-2.0	42.850	50.0-0	2.66552	15.2-0.00	42.4950	3.5845	3.3544	15.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.3-2.0	42.850	50.0-0	2.66552	15.4-0.00	42.4950	3.5845	3.3544	15.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.4-2.0	42.850	50.0-0	2.66552	15.6-0.00	42.4950	3.5845	3.3544	15.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.5-2.0	42.850	50.0-0	2.66552	15.8-0.00	42.4950	3.5845	3.3544	15.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.6-2.0	42.850	50.0-0	2.66552	16.0-0.00	42.4950	3.5845	3.3544	16.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.7-2.0	42.850	50.0-0	2.66552	16.2-0.00	42.4950	3.5845	3.3544	16.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.8-2.0	42.850	50.0-0	2.66552	16.4-0.00	42.4950	3.5845	3.3544	16.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
4.9-2.0	42.850	50.0-0	2.66552	16.6-0.00	42.4950	3.5845	3.3544	16.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.0-2.0	42.850	50.0-0	2.66552	16.8-0.00	42.4950	3.5845	3.3544	16.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.1-2.0	42.850	50.0-0	2.66552	17.0-0.00	42.4950	3.5845	3.3544	17.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.2-2.0	42.850	50.0-0	2.66552	17.2-0.00	42.4950	3.5845	3.3544	17.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.3-2.0	42.850	50.0-0	2.66552	17.4-0.00	42.4950	3.5845	3.3544	17.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.4-2.0	42.850	50.0-0	2.66552	17.6-0.00	42.4950	3.5845	3.3544	17.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.5-2.0	42.850	50.0-0	2.66552	17.8-0.00	42.4950	3.5845	3.3544	17.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.6-2.0	42.850	50.0-0	2.66552	18.0-0.00	42.4950	3.5845	3.3544	18.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.7-2.0	42.850	50.0-0	2.66552	18.2-0.00	42.4950	3.5845	3.3544	18.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.8-2.0	42.850	50.0-0	2.66552	18.4-0.00	42.4950	3.5845	3.3544	18.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
5.9-2.0	42.850	50.0-0	2.66552	18.6-0.00	42.4950	3.5845	3.3544	18.6-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
6.0-2.0	42.850	50.0-0	2.66552	18.8-0.00	42.4950	3.5845	3.3544	18.8-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
6.1-2.0	42.850	50.0-0	2.66552	19.0-0.00	42.4950	3.5845	3.3544	19.0-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
6.2-2.0	42.850	50.0-0	2.66552	19.2-0.00	42.4950	3.5845	3.3544	19.2-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
6.3-2.0	42.850	50.0-0	2.66552	19.4-0.00	42.4950	3.5845	3.3544	19.4-0.00	42.4950	3.5845	3.3544	3.3544	3.4071	3.4071
6.4-2.0	42.850	50.												

PAGE 3

卷之三

TIME [S]	HEAT FLUX [W/M ²]	THETA [C]	MUSSETT NUMBER
-------------	----------------------------------	--------------	-------------------

卷之三

WIRE LENGTH = .096 M
WIRE DIAMETER = .0025 M
AMBIENT TEMP. = 100 C
PRESSURE = DECOMPRESSION FROM 515.01 KPA
INITIAL RES15 = .316156 OHMS AT 160 C
SIGMA

TIME [S]	HEAT FLUX [W/m ²]	THETA [E]	HUSSEL NUMBER
-1.86	4.25150	59.033	2.6188
-1.68	4.25500	59.991	2.6805
-1.52	4.25150	59.997	2.6193
-1.36	4.25150	59.987	2.6189
-1.20	4.25500	59.979	2.6192
-1.04	4.25500	59.980	2.6191
-0.80	4.25250	59.980	2.6191
-0.72	4.25150	59.982	2.6189
-0.56	4.25150	59.983	2.6189
-0.40	4.25350	59.946	2.6194
-0.24	4.25250	59.947	2.6194
0.00	4.25000	59.945	2.6193
0.080	4.25150	60.002	2.6182
0.240	4.25250	60.022	2.6181
0.400	4.25350	60.003	2.6182
0.560	4.25500	60.002	2.6184
0.720	4.25450	60.038	2.6167
0.880	4.25370	60.036	2.6183
1.040	4.25350	60.002	2.6182
1.200	4.25380	60.013	2.6180
1.360	4.25370	60.016	2.6178
1.520	4.25350	59.984	2.6192
1.680	4.25390	59.930	2.6237
1.840	4.25390	59.873	2.6244
2.000	4.25390	59.341	2.6256
2.160	4.25390	59.000	2.6274
2.320	4.25400	59.762	2.6292
2.480	4.25360	59.089	2.6374
2.640	4.25420	59.600	2.6364
2.800	4.25380	59.456	2.6262
2.960	4.25440	59.273	2.6551
3.120	4.25260	59.165	2.6750
3.280	4.25260	59.082	2.6805
3.440	4.25260	58.929	2.6862
3.600	4.25640	58.084	2.6717
3.760	4.25260	58.703	2.6767
3.920	4.25360	58.503	2.6687
4.080	4.25360	58.280	2.6680
4.240	4.25260	58.117	2.7075
4.400	4.25150	57.935	2.7194
4.560	4.25150	57.776	2.7200
4.720	4.25260	57.700	2.7200

RUN NUMBER AP-3-1

PAGE 2

RUN NUMBER AP-3-1

PAGE 3

TIME (S)	HEAT FLUX (W/cm ²)	THETA (°C)	NUSSELT NUMBER
4.380	423460	5.7-94.2	2-7117
5.040	423340	5.1-371	2-7186
5.240	423570	57-696	2-7957
5.360	423190	56-875	2-7624
5.520	423570	56-510	2-7763
5.680	423340	56-516	2-7780
5.840	423350	54-209	2-7950
6.000	423330	55-167	2-8374
6.160	423560	55-307	2-8005
6.320	423350	55-201	2-8461
6.480	423350	55-405	2-8345
6.640	423490	54-205	2-8354
6.800	423480	54-004	2-8230
6.960	423330	54-013	2-7065
7.120	423490	51-180	2-9154
7.280	423490	51-877	2-9155
7.440	423470	51-872	2-9156
7.600	423460	53-584	2-9114
7.760	423470	52-672	2-9052
7.920	423460	51-152	2-9048
8.080	423460	51-553	3-0046
8.240	423460	51-950	3-0317
8.400	423470	51-954	3-0333
8.560	423460	51-952	3-0303
8.720	423460	51-767	3-0330
8.880	423470	51-0159	3-0159
9.040	423460	50-006	3-0172
9.200	423450	50-672	3-0163
9.360	423450	50-889	3-0165
9.520	423450	50-124	3-0123
9.680	423450	50-935	3-0094
9.840	423420	50-558	3-0137
10.000	423440	50-500	3-01052
10.160	423440	51-767	3-0159
10.320	423440	50-948	3-0125
10.480	423450	50-086	3-0172
10.640	423470	51-050	3-0169
10.800	423460	50-642	3-0116
10.960	423450	50-124	3-0004
11.120	423430	50-935	3-0120
11.280	423410	50-227	3-0120
11.440	423380	49-446	3-0184
11.600	423400	48-073	3-2136
11.760	423420	49-718	3-1509
11.920	423400	49-717	3-1509
12.080	423410	49-447	3-1583
12.240	423390	49-124	3-1583
12.400	423410	49-102	3-1455

TIME (S)	HEAT FLUX (W/cm ²)	THETA (°C)	NUSSELT NUMBER
12.56	423390	43-516	3-2124
12.72	423380	43-525	3-2098
12.88	423400	43-951	3-2033
13.04	423380	43-958	3-2112
13.20	423350	43-761	3-2203
13.36	423360	43-917	3-1847
13.52	423360	43-952	3-2079
13.68	423320	43-201	3-2576
13.84	423270	43-752	3-2761
14.00	423220	44-776	3-9059
14.16	423240	46-039	3-4099
14.32	423260	46-312	3-3899
14.48	423260	45-036	3-4559
14.64	423210	45-540	3-4471
14.80	423250	46-536	3-3632
14.96	423200	44-004	3-5591
15.12	423230	46-100	3-4053
15.28	423320	46-016	3-3675
15.44	423350	46-858	3-3504
15.60	423320	46-313	3-3899
15.76	423210	46-746	3-1872
15.92	423210	45-920	3-3932
16.08	423250	46-219	3-3676
16.24	423210	46-619	3-3678
16.40	423220	46-386	3-3476
16.56	423210	45-933	3-4160
16.72	423210	45-971	3-4141
16.88	423230	45-457	3-4084
17.04	423190	45-438	3-4531
17.20	423220	45-204	3-4631
17.36	423210	45-707	3-4346
17.52	423230	45-617	3-4441
17.68	423200	45-828	3-4241
17.84	423210	45-039	3-4225
18.00	423280	45-971	3-4225
18.16	423280	45-725	3-4233
18.32	423280	45-709	3-4225

RUN NUMBER AP3-7

RUN NUMBER AP3-7

PAGE 2

WIRE LENGTH = .056 M
WIRE DIAMETER = .0025 M
AMBIENT TEMP. = 100 C
PRESSURE = DECOMPRESSION FROM 400.06 KPA
INITIAL RESS. = .316133 GAMS AT 155.9 C
SLIUM = C

TIME (S)	HEAT FLUX (W/m²)	THETA (IC)	HUSSLT HUNGER	TIME (S)	HEAT FLUX (W/m²)	THETA (IC)	HUSSLT NUMBER
-1.84	61820	59.027	2.5937	-8.80	41840	56.536	2.7455
-1.68	41810	59.027	2.5936	-8.04	41840	55.382	2.7776
-1.52	41810	59.027	2.5934	-5.20	41850	55.207	2.8118
-1.36	41820	59.017	2.5934	-3.34	41850	54.456	2.8506
-1.20	41830	59.017	2.5934	-5.52	41860	54.041	2.8906
-1.04	41840	59.008	2.5940	-5.68	41870	53.975	2.8755
-0.88	41840	59.003	2.5940	-5.94	41880	53.940	2.8678
-0.72	41810	59.003	2.5940	-6.00	41890	54.119	2.8676
-0.56	41820	59.002	2.5940	-6.16	41890	54.139	2.8666
-0.40	41820	59.017	2.5940	-6.32	41890	53.484	2.8018
-0.24	41830	59.008	2.5940	-6.48	41890	53.352	2.8018
-0.08	41840	59.003	2.5944	-6.64	41890	53.214	2.9162
0.08	41840	59.003	2.5944	-6.80	41870	52.094	2.9328
0.24	41860	59.003	2.5943	-6.96	41870	52.094	2.9229
0.40	418610	59.003	2.5943	-7.12	41870	52.094	2.9463
0.56	41860	59.002	2.5943	-7.28	41870	52.095	2.9675
0.72	41860	59.002	2.5943	-7.44	41870	52.121	2.9558
0.88	41860	59.002	2.5943	-7.60	41870	52.125	2.9732
1.04	41860	59.013	2.5953	-7.60	41850	52.120	2.9732
1.20	418610	59.013	2.5953	-7.92	41850	51.772	2.9973
1.36	41860	59.013	2.5953	-8.08	41830	51.434	3.0226
1.52	41860	59.013	2.5953	-8.24	41830	51.404	3.0181
1.68	41860	59.014	2.5955	-8.40	41830	51.392	3.0076
1.84	41860	59.014	2.5955	-8.56	41830	51.454	3.0155
2.00	41860	59.014	2.5955	-8.72	41830	51.198	3.0307
2.16	41860	59.014	2.5955	-8.88	41830	51.553	3.0991
2.32	41860	59.014	2.5955	-9.04	41830	51.233	3.0736
2.48	41860	59.014	2.5955	-9.20	41830	51.172	3.0736
2.64	41860	59.014	2.5955	-9.36	41830	51.172	3.0736
2.80	41860	59.014	2.5955	-9.52	41830	51.172	3.0736
2.96	41860	59.014	2.5955	-9.68	41830	51.172	3.0736
3.12	41860	59.014	2.5955	-9.84	41830	51.172	3.0736
3.28	41860	59.014	2.5955	-10.00	41830	51.172	3.0736
3.44	41860	59.014	2.5955	-10.16	41830	51.172	3.0736
3.60	41860	59.014	2.5955	-10.32	41830	51.172	3.0736
3.76	41860	59.014	2.5955	-10.48	41830	51.172	3.0736
3.92	41860	59.014	2.5955	-10.64	41830	51.172	3.0736
4.08	41860	59.014	2.5955	-10.80	41830	51.172	3.0736
4.24	41860	59.014	2.5955	-10.96	41830	51.172	3.0736
4.40	41860	59.014	2.5955	-11.12	41830	51.172	3.0736
4.56	41860	59.014	2.5955	-11.28	41830	51.172	3.0736
4.72	41860	59.014	2.5955	-11.44	41830	51.172	3.0736
4.88	41860	59.014	2.5955	-11.60	41830	51.172	3.0736
5.04	41860	59.014	2.5955	-11.76	41830	51.172	3.0736
5.20	41860	59.014	2.5955	-11.92	41830	51.172	3.0736
5.36	41860	59.014	2.5955	-12.08	41830	51.172	3.0736
5.52	41860	59.014	2.5955	-12.24	41830	51.172	3.0736
5.68	41860	59.014	2.5955	-12.40	41830	51.172	3.0736

RUN NUMBER AP-3-7

PAGE 3

RUN NUMBER AP-4-6

TIME 151	HEAT FLUX 1W/cm ²	THETA ECI	NUSSELT NUMBER
12.56	4.1200	48.700	3.1059
12.72	4.1310	49.425	3.1393
12.88	4.1310	49.447	3.1379
13.04	4.1290	48.732	3.1838
13.20	4.1310	48.631	3.1904
13.36	4.1300	49.080	3.1613
13.52	4.1340	49.144	3.1571
13.68	4.1320	49.335	3.1451
13.84	4.1290	48.167	3.2211
14.00	4.1320	49.193	3.1542
14.16	4.1320	48.777	3.1905
14.32	4.1320	49.071	3.1620
14.48	4.1370	3.1942	3.1575
14.64	4.1290	3.7653	3.2555
14.80	4.1370	3.7003	3.3010
14.96	4.1280	4.6512	3.3156
15.12	4.1320	4.6088	3.3664
15.28	4.1320	4.68849	3.2111
15.44	4.1240	4.6379	3.2455
15.60	4.1300	4.64964	3.2042
15.76	4.1240	4.7059	3.2871
15.92	4.11260	4.63320	3.3489
16.08	4.11270	4.65375	3.3311
16.24	4.11250	4.63329	3.3496
16.40	4.11290	4.63300	3.3510
16.56	4.11300	4.61762	3.3140
16.72	4.11240	4.6265	3.2826
16.88	4.1210	4.7102	3.2939
17.04	4.1200	4.61775	3.2369
17.20	4.18360	4.71240	3.2817
17.36	4.18240	4.7121	3.2926
17.52	4.18240	4.5322	3.4232
17.68	4.19250	4.53912	3.5329
17.84	4.18210	4.6120	3.6128
18.00	4.18260	4.61318	3.5149
18.16	4.18220	4.34410	3.5736
18.32	4.18240	43.474	3.5521

WIRE LENGTH = .096 m	WIRE DIAMETER = .00025 m	AMBIENT TEMP. = 100 C	PRESSURE FROM 503.96 kPa
INITIAL RESIS. = +316095 OHMS AT 150.9 C			
SIGMA = 0			

RUN NUMBER AP-4-6	TIME (S)	HEAT FLUX [W/m ²]	THETA [deg]	NUSSELT NUMBER
-1.84	408170	60.049	2.5213	
-1.68	408160	60.046	2.5211	
-1.52	408160	60.046	2.5207	
-1.36	408200	60.065	2.5207	
-1.20	408120	60.069	2.5210	
-1.04	408170	60.055	2.5210	
-0.88	408170	60.067	2.5205	
-0.72	408160	60.057	2.5206	
-0.56	408160	60.057	2.5216	
-0.40	408160	60.057	2.5218	
-0.24	408160	60.037	2.5219	
-0.08	408150	60.044	2.5214	
0.12	408170	60.045	2.5213	
0.28	408150	60.021	2.5223	
0.56	408150	60.009	2.5224	
0.72	408150	60.021	2.5222	
0.88	408140	60.021	2.5221	
1.04	408150	59.994	2.5235	
1.20	408140	59.978	2.5240	
1.36	408130	59.952	2.5251	
1.52	408120	59.950	2.5251	
1.68	408120	59.950	2.5229	
1.84	408130	59.977	2.5233	
2.00	408160	59.926	2.5264	
2.16	408160	59.911	2.5261	
2.32	408150	59.907	2.5271	
2.48	408160	59.895	2.5273	
2.64	408150	59.889	2.5273	
2.80	408120	59.877	2.5271	
2.96	408120	59.868	2.5233	
3.12	408180	59.876	2.5233	
3.28	408120	59.873	2.5280	
3.44	408180	59.852	2.5281	
3.60	408150	59.801	2.5116	
3.76	408170	59.801	2.5117	
3.92	408120	59.799	2.5115	
4.08	408140	59.759	2.5333	
4.24	408160	59.693	2.5361	
4.40	408160	59.650	2.5463	
4.56	408130	59.680	2.5623	
4.72	408130	59.601	2.5658	

RUN NUMBER AP4-6

PAGE 2

RUN NUMBER AP4-6

PAGE 3

TIME [5]	HEAT FLUX [W/WIN]	THETA [C]	NUSSELT NUMBER
4.380	4.08110	59.921	2.5691
5.040	4.08130	58.631	2.4790
5.200	4.08140	58.745	2.4771
5.360	4.08120	59.547	2.4855
5.520	4.08110	58.434	2.5905
5.680	4.08100	57.759	2.6208
5.840	4.08120	57.203	2.6461
6.000	4.08110	57.326	2.6405
6.160	4.08130	57.782	2.6428
6.320	4.08120	57.109	2.6507
6.480	4.08100	57.090	2.6514
6.640	4.08120	56.729	2.6565
6.800	4.08100	56.131	2.6967
6.960	4.08100	56.170	2.6943
7.120	4.08100	55.971	2.7043
7.280	4.08100	55.730	2.7150
7.440	4.08100	55.200	2.7422
7.600	4.08100	54.944	2.7524
7.760	4.08100	54.209	2.7920
7.920	4.08100	54.024	2.7948
8.080	4.08100	54.024	2.8012
8.240	4.08100	53.599	2.8237
8.400	4.08100	53.586	2.8244
8.560	4.08100	53.729	2.8369
8.720	4.08100	53.970	2.8393
8.880	4.08100	53.337	2.8413
9.040	4.08100	54.409	2.8024
9.200	4.08100	54.024	2.8012
9.360	4.08100	54.342	2.8111
9.520	4.08100	53.043	2.8109
9.680	4.08100	53.399	2.8341
9.840	4.08100	53.323	2.8360
1.000	4.08100	53.555	2.8257
1.016	4.08101	53.582	2.8144
1.032	4.08100	53.773	2.8140
1.048	4.08100	53.784	2.8137
1.064	4.08100	53.668	2.8201
1.120	4.08100	54.054	2.8995
1.136	4.08100	53.819	2.8122
1.152	4.08100	53.054	2.8525
1.168	4.08100	53.952	2.8050
1.184	4.08100	53.750	2.8153
1.200	4.08100	53.675	2.8197
1.216	4.08100	53.851	2.8102
1.232	4.08100	53.745	2.8152
1.248	4.08100	53.924	2.8061
1.264	4.08100	54.021	2.8027
1.280	4.08100	53.708	2.8177

RUN NUMBER AP4-6	TIME [5]	HEAT FLUX [W/WIN]	THETA [C]	NUSSELT NUMBER	TIME [5]	HEAT FLUX [W/WIN]	THETA [C]	NUSSELT NUMBER
1.256	4.08100	52.790	2.4658	2.4333	1.272	4.08100	53.410	2.4877
1.282	4.08100	52.807	2.4887	2.4645	1.288	4.08100	52.242	2.4958
1.304	4.07980	51.923	2.4145	2.4078	1.304	4.07980	51.900	2.4915
1.320	4.07980	51.380	2.4951	2.4078	1.320	4.07980	52.003	2.4915
1.336	4.07980	51.380	2.4951	2.4078	1.336	4.07980	52.003	2.4915
1.352	4.07980	51.380	2.4951	2.4078	1.352	4.07980	52.003	2.4915
1.368	4.07980	51.380	2.4951	2.4078	1.368	4.07980	51.900	2.4915
1.384	4.07980	51.380	2.4951	2.4078	1.384	4.07980	52.175	2.4805
1.400	4.07980	51.490	2.4892	2.4078	1.400	4.07980	52.117	2.4892
1.416	4.07980	51.490	2.4892	2.4078	1.416	4.07980	52.117	2.4892
1.432	4.08200	52.075	2.4951	2.4078	1.432	4.08200	52.075	2.4951
1.448	4.07980	52.365	2.4900	2.4078	1.448	4.07980	52.405	2.4866
1.464	4.08100	52.405	2.4769	2.4078	1.464	4.08100	52.405	2.4769
1.480	4.08100	52.087	2.4865	2.4078	1.480	4.08100	52.087	2.4865
1.496	4.07980	52.723	2.4870	2.4078	1.496	4.07980	52.723	2.4870
1.512	4.08000	52.307	2.4882	2.4078	1.512	4.08000	52.307	2.4882
1.528	4.07980	51.395	2.4942	2.4078	1.528	4.07980	51.395	2.4942
1.544	4.07970	51.710	2.4925	2.4078	1.544	4.07970	51.710	2.4925
1.560	4.07970	51.004	2.4925	2.4078	1.560	4.07970	51.004	2.4925
1.576	4.07980	52.526	2.4850	2.4078	1.576	4.07980	52.526	2.4850
1.592	4.08100	52.759	2.4884	2.4078	1.592	4.08100	52.759	2.4884
1.608	4.07980	52.715	2.4866	2.4078	1.608	4.07980	52.715	2.4866
1.624	4.07990	52.467	2.4836	2.4078	1.624	4.07990	52.467	2.4836
1.640	4.07980	52.426	2.4810	2.4078	1.640	4.07980	52.426	2.4810
1.656	4.08010	52.261	2.4895	2.4078	1.656	4.08010	52.261	2.4895
1.672	4.07980	52.169	2.4918	2.4078	1.672	4.07980	52.169	2.4918
1.688	4.07970	51.911	2.4951	2.4078	1.688	4.07970	51.911	2.4951
1.704	4.08010	52.446	2.4822	2.4078	1.704	4.08010	52.446	2.4822
1.720	4.07980	51.476	2.4976	2.4078	1.720	4.07980	51.476	2.4976
1.736	4.07980	51.459	2.4959	2.4078	1.736	4.07980	51.459	2.4959
1.752	4.07980	51.491	2.4974	2.4078	1.752	4.07980	51.491	2.4974
1.768	4.07980	52.229	2.4874	2.4078	1.768	4.07980	52.229	2.4874
1.784	4.07980	52.229	2.4874	2.4078	1.784	4.07980	52.229	2.4874
1.800	4.07980	51.777	2.4952	2.4078	1.800	4.07980	51.777	2.4952
1.816	4.07980	51.950	2.4950	2.4078	1.816	4.07980	51.950	2.4950
1.832	4.07970	51.950	2.4950	2.4078	1.832	4.07970	51.950	2.4950

卷之三

卷之三

PAGE 3

RUN NUMBER AP-4

PAGE 2

RUN NUMBER AP-4

TIME (S)	HEAT FLUX (W/cm²)	THETA ICL	NUSSELT NUMBER	TIME EST	HEAT FLUX (W/cm²)	THETA ICL	NUSSELT NUMBER
4.880	419270	59.314	2.6219	12.56	419200	54.76	2.0392
5.040	419270	59.270	2.6210	12.72	419200	54.836	2.0386
5.120	419260	59.243	2.6210	12.88	419230	54.853	2.0510
5.360	419250	59.200	2.6208	13.04	419210	54.857	2.0501
5.520	419280	59.183	2.6276	13.20	419180	54.819	2.0510
5.680	419270	59.149	2.6279	13.36	419190	53.974	2.0390
5.840	419242	59.076	2.6314	13.52	419200	53.986	2.0484
6.000	419270	59.094	2.6317	13.68	419210	53.926	2.0393
6.160	419270	59.087	2.6329	13.84	419190	53.781	2.0391
6.320	419270	59.012	2.6353	14.00	419220	53.967	2.0381
6.480	419270	59.073	2.6369	14.16	419210	53.717	2.0395
6.640	419270	59.052	2.6369	14.32	419200	53.679	2.0397
6.800	419270	58.991	2.6405	14.48	419200	53.841	2.0379
6.960	419270	58.881	2.6412	14.64	419190	53.543	2.0390
7.120	419270	58.632	2.6435	14.80	419210	54.193	2.0393
7.280	419270	58.786	2.6435	14.96	419190	53.541	2.0390
7.440	419250	58.760	2.6465	15.12	419210	53.694	2.0395
7.600	419270	58.717	2.6480	15.28	419210	53.493	2.0366
7.760	419270	58.640	2.6512	15.44	419210	53.787	2.0390
7.920	419270	58.633	2.6525	15.60	419210	53.623	2.0390
8.080	419270	58.593	2.6525	15.76	419200	53.866	2.0366
8.240	419260	58.593	2.6550	15.92	419210	53.640	2.0397
8.400	419270	58.500	2.6550	16.08	419240	54.061	2.0366
8.560	419260	58.586	2.6556	16.24	419240	54.076	2.0375
8.720	419270	58.523	2.6584	16.40	419260	54.265	2.0357
8.880	419270	58.429	2.6618	16.56	419220	54.500	2.0485
9.040	419270	58.270	2.6641	16.72	419240	54.545	2.0493
9.200	419270	57.4672	2.6693	16.88	419277	54.607	2.0377
9.360	419270	56.982	2.71312	17.04	419240	54.4139	2.0323
9.520	419240	56.997	2.71427	17.20	419240	54.593	2.0484
9.680	419270	56.630	2.71458	17.36	419230	54.582	2.0484
9.840	419270	56.727	2.71412	17.52	419250	54.275	2.0352
10.000	419270	56.422	2.71533	17.68	419200	54.552	2.0350
10.160	419270	56.422	2.71595	17.84	419220	54.705	2.0492
10.320	419270	56.444	2.71705	18.00	419230	54.413	2.0378
10.480	419240	56.044	2.71747	18.16	419200	54.542	2.0309
10.640	419270	54.946	2.72998	18.32	419260	54.564	2.0350
10.800	419270	54.507	2.73234	18.32			
10.960	419270	55.076	2.73237				
11.120	419270	55.126	2.73206				
11.280	419270	55.126	2.73070				
11.440	419270	55.457	2.73157				
11.600	419270	56.129	2.73222				
11.760	419270	55.334	2.73202				
11.920	419270	55.334	2.73115				
12.080	419270	55.023	2.73281				
12.240	419270	54.305	2.73032				
12.400	419270	54.674	2.0446				

RUN NUMBER AP-8-7

RUN NUMBER AP-8-7

PAGE 2

WIRE LENGTH	0.026 M	WIRE DIAMETER	0.0005 M	AMBIENT TEMP.	100 C	MAX 1400-2, DECOMPRESSION FROM 377.11 KPA	HUSSELL NUMBER
INITIAL PRESSURE	1.01909	INITIAL RESS.	0.10000	SIGNAL	0	LAD G	
-1.84	417990	60.242	2.5728	4.880	418220	59.616	2+0.00
-1.68	410000	60.261	2.5729	5.040	417890	59.586	2+0.19
-1.52	410020	60.260	2.5727	5.200	417890	59.539	2+0.46
-1.36	410020	60.268	2.5728	5.360	418010	59.532	2+0.44
-1.20	410020	60.273	2.5725	5.520	418010	59.490	2+0.03
-1.04	410020	60.272	2.5724	5.680	418010	59.455	2+0.07
-0.88	418010	60.280	2.5721	5.840	418010	59.434	2+0.08
-0.72	418010	60.273	2.5725	6.000	418010	59.416	2+0.09
-0.56	418020	60.282	2.5721	6.160	417990	59.399	2+0.12
-0.40	418000	60.291	2.5716	6.320	418000	59.381	2+0.10
-0.24	410010	60.300	2.5713	6.480	418000	59.307	2+0.13
-0.08	410010	60.295	2.5715	6.640	418000	59.332	2+0.13
0.08	410000	60.306	2.5711	6.800	418020	59.296	2+0.14
0.24	418020	60.316	2.5711	6.960	418020	59.283	2+0.15
0.40	418020	60.320	2.5725	7.120	418030	59.238	2+0.17
0.56	418000	60.328	2.5721	7.280	418000	59.232	2+0.17
0.72	410010	60.330	2.5716	7.440	417990	59.184	2+0.05
0.88	410010	60.330	2.5715	7.600	418010	59.164	2+0.07
1.04	410000	60.336	2.5711	7.760	418000	59.108	2+0.21
1.20	418020	60.346	2.5704	7.920	418020	59.063	2+0.25
1.36	410020	60.319	2.5702	8.080	418010	59.034	2+0.26
1.52	410020	60.327	2.5702	8.240	417970	58.968	2+0.36
1.68	410030	60.331	2.5701	8.400	418010	58.716	2+0.46
1.84	418000	60.304	2.5711	8.560	417970	58.490	2+0.54
2.00	418020	60.287	2.5719	8.720	418020	58.375	2+0.56
2.16	418010	60.273	2.5724	8.880	417980	58.309	2+0.68
2.32	418010	60.281	2.5716	9.040	417980	58.275	2+0.62
2.48	414000	60.253	2.5731	9.200	418000	58.128	2+0.73
2.64	414000	60.254	2.5731	9.360	417980	57.947	2+0.74
2.80	410020	60.262	2.5731	9.520	417970	57.767	2+0.66
2.96	417990	60.265	2.5730	9.680	418000	57.616	2+0.64
3.12	410020	60.267	2.5729	9.840	417980	57.408	2+0.61
3.28	418020	59.975	2.5853	10.000	417950	57.192	2+0.59
3.44	418000	59.974	2.5866	10.160	417970	57.150	2+0.57
3.60	410000	59.973	2.5871	10.320	417990	57.139	2+0.55
3.76	418020	59.971	2.5873	10.480	417980	57.130	2+0.52
3.92	410000	59.971	2.5873	10.640	417980	57.130	2+0.52
4.08	418020	59.971	2.5875	10.800	417980	57.130	2+0.52
4.24	417990	59.972	2.5876	10.960	417950	57.130	2+0.51
4.40	418000	59.972	2.5875	11.120	417970	57.130	2+0.49
4.56	410000	59.972	2.5878	11.280	417990	57.130	2+0.47
4.72	418020	59.971	2.5877	11.440	417980	56.973	2+0.42

RUN NUMBER APB-7 PAGE 3

RUN NUMBER APB-4

 TIME HEAT FLUX THE TA
 (S) (W/HM)

 WIRE LENGTH = 0.045 M
 WIRE DIAMETER = 0.0125 M
 AMBIENT TEMP. = 100 C
 PRESSURE NUMBER = PA 370.3, DECOMPRESSION FROM 377.11 KPA
 INITIAL REFLX = .316198 OHMS AT 180 C
 SIGNA = C

	RUN NUMBER	TIME	HEAT FLUX	THE TA	NUSSELT NUMBER	TIME	HEAT FLUX	THE TA	NUSSELT NUMBER
		(S)	(W/HM)	(C)		(S)	(W/HM)	(C)	
1.2, 56	417950	56.502	2.7437						
1.2, 72	417960	56.163	2.7602						
1.3, 80	417960	56.142	2.7712						
1.3, 04	417960	56.172	2.7596						
1.3, 20	417960	56.155	2.7754						
1.3, 36	417960	56.140	2.7312						
1.3, 52	417960	56.145	2.7761						
1.2, 68	417960	56.185	2.7741						
1.3, 84	417960	56.185	2.7607						
1.4, 00	417970	56.134	2.7667						
1.4, 16	417970	56.140	2.7646						
1.4, 32	417970	56.142	2.7646						
1.4, 48	417980	56.149	2.7343						
1.4, 64	417980	56.150	2.7702						
1.4, 80	417980	56.027	2.7672						
1.4, 96	417980	56.183	2.7445						
1.5, 12	417990	56.190	2.7114						
1.5, 28	417990	56.139	2.7114						
1.5, 44	417990	56.137	2.7114						
1.5, 60	417970	56.110	2.7602						
1.5, 76	417950	56.145	2.7542						
1.5, 92	417950	56.155	2.7542						
1.6, 08	417990	56.031	2.7671						
1.6, 24	417980	56.140	2.7666						
1.6, 40	417960	56.140	2.7608						
1.6, 56	417960	56.140	2.7608						
1.6, 72	417970	56.140	2.7608						
1.6, 88	417970	56.139	2.7608						
1.7, 16	417960	56.139	2.7713						
1.7, 32	417980	56.139	2.7582						
1.7, 48	417980	56.139	2.7582						
1.7, 64	417980	56.139	2.7582						
1.7, 80	417980	56.139	2.7582						
1.8, 00	417960	56.139	2.7614						
1.8, 16	417960	55.773	2.7797						
1.8, 32	417980	56.209	2.7582						

RUN NUMBER A/P-9-4 PAGE 3

TIME (S)	HEAT FLUX (W/M²)	THETA (°C)	NUSSELT NUMBER	TIME (S)	HEAT FLUX (W/M²)	THETA (°C)	NUSSELT NUMBER
64.80	417800	50.914	3.0445	141.6	417800	41.875	3.7016
64.40	417800	50.000	3.0799	141.2	417800	41.403	3.7334
63.00	417800	49.874	3.1078	140.8	417800	42.111	3.6411
62.60	417800	49.874	3.1189	140.4	417800	41.427	3.7016
71.20	417850	48.824	3.2125	148.0	417800	41.867	3.6667
72.80	417820	48.300	3.3451	149.6	417850	42.145	3.6776
74.40	417820	48.295	3.3477	151.2	417840	41.364	3.7649
76.00	417890	48.310	3.3978	152.8	417890	40.429	3.8174
77.60	417890	47.512	3.2901	154.4	417790	41.760	3.7105
79.20	417880	46.520	3.3549	156.0	417780	42.000	3.6826
80.80	417850	44.817	3.4894	157.6	417770	41.980	3.6913
82.40	417810	42.417	3.6058	159.2	417720	41.443	3.7097
84.00	417850	43.477	3.5648	160.8	417780	42.971	3.6062
85.60	417850	43.054	3.5999	162.4	417790	42.443	3.6418
87.20	417860	42.967	3.5253	164.0	417850	42.228	3.6880
88.80	417910	45.431	3.3970	165.6	417850	41.924	3.6581
90.40	417950	43.667	3.5492	167.2	417600	41.466	3.7016
92.00	417860	44.053	3.5103	168.8	417880	41.565	3.7264
93.60	417840	43.882	3.5319	170.4	417790	41.155	3.7047
95.20	417830	43.591	3.5955	172.0	417820	41.755	3.7098
96.80	417800	44.059	3.5177	173.6	417880	40.434	3.7932
98.40	417800	43.370	3.5777	175.2	417820	41.237	3.7664
100.00	417800	44.156	3.5057	176.8	417650	41.501	3.7329
101.60	417800	44.156	3.5007	178.4	417890	42.412	3.8529
103.2	417820	43.997	3.5224	180.0	417650	41.060	3.8821
104.8	417770	42.275	3.6655	181.6	417810	41.498	3.7685
106.4	417750	42.193	3.6725	183.2	417130	42.457	3.6868
108.0	417760	42.216	3.6744	184.8	41730	42.106	3.6795
109.6	417770	42.857	3.6158	186.4	417750	41.799	3.7071
111.2	417790	42.772	3.6352	188.0	417750	41.432	3.7197
112.8	417760	41.972	3.6916	189.6	417730	42.156	3.6755
114.4	417800	42.235	3.6416	191.2	417750	41.085	3.7172
116.0	417800	42.489	3.6295	192.8	417750	41.339	3.6946
117.6	417800	42.005	3.6295	194.4	417780	41.229	3.7166
119.2	417720	41.598	3.6972	196.0	417780	42.069	3.6448
120.8	417660	41.219	3.6193	197.6	417780	42.741	3.6257
122.4	417640	41.272	3.6112	199.2	417780	42.106	3.6795
124.0	41750	41.420	3.2409	200.8	417780	41.799	3.7071
125.6	41750	41.712	3.1575	202.4	417750	41.432	3.7197
127.2	41780	41.463	3.7382	204.0	417730	42.156	3.6755
128.8	41780	41.385	3.7451	205.6	417750	41.085	3.7172
130.4	417910	42.598	3.7306	207.2	417750	41.339	3.6946
132.0	417870	41.598	3.6253	208.8	417780	42.069	3.6448
133.6	417910	42.852	3.6531	210.4	417780	42.741	3.6257
135.2	417880	41.302	3.7523	212.0	417780	42.106	3.6795
136.8	417910	41.713	3.7164	213.6	417780	41.432	3.7197
138.4	417910	41.774	3.7283	215.2	417780	42.156	3.6755
140.0	417810	41.654	3.7205	216.8	417780	41.085	3.7172

INITIATION OF SUBCOOLED POOL BOILING
DURING PRESSURE TRANSIENTS

by

DONALD L. SCHMIDT

B.S., Kansas State University, 1983

AN ABSTRACT OF A MASTER'S THESIS

submitted in partial fulfillment of the
requirements for the degree

MASTER OF SCIENCE

Department of Nuclear Engineering

KANSAS STATE UNIVERSITY

Manhattan, Kansas

1985

ABSTRACT

An experimental investigation of boiling initiation during pressure transients has been made. A platinum wire heating element of dimensions 0.25 mm diameter and 9.6 cm length was immersed in distilled and degassed water. Maximum pressures from 0.377 to 1.48 MPa were applied with the water and test element temperatures at 100°C before heating the platinum wire to 160°C. The wire experienced constant superficial heat fluxes of approximately 0.42 MW/m² while the system was subjected to near-exponential decompressions to atmospheric pressure. Pressure reduction periods were approximately 4 and 6.6 s, and pressure transients were reproducible over most of the pressure drop. Boiling initiation times provided conditions for boiling initiation which depended on the pressure-temperature history of the test element and the surrounding fluid. These conditions tended to be overpredicted by a model accounting for the deactivating effect of pre-pressurization on potential nucleation sites. Reactivation of nucleation sites and recovery of the test element temperature to steady-state were seen to be strongly affected by increases in the maximum pressure applied.